



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER


Client Name: Woodburn School District
1390 Meridian Drive
Woodburn, OR 97071

Reference Number: **16-15891**

Project: French Prairie

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
County:

Analyst: mvp
Date Received: 7/6/2016
Report Date: 7/20/2016
Approved By: bj
Authorized by:


Lawrence J Henderson, PhD
Director of Laboratories, Vice President

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_37882	7/6/2016	Hall A	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
16_37883	7/6/2016	Hall A	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
16_37884	7/6/2016	Hall A	1030	LEAD	0.007	mg/L	0.015	0.001	200.8	4072	
16_37885	7/6/2016	Staff Room	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37886	7/6/2016	Staff Room	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37887	7/6/2016	Commons	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
16_37888	7/6/2016	Hall B	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
16_37889	7/6/2016	Hall B	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
16_37890	7/6/2016	Boy's Locker Room	1030	LEAD	0.020	mg/L	0.015	0.001	200.8	4072	
16_37891	7/6/2016	Hall C	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
16_37892	7/6/2016	Kitchen	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37893	7/6/2016	Kitchen	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
16_37894	7/6/2016	Room 34	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37895	7/6/2016	Room 34	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37896	7/6/2016	Hall D	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
16_37897	7/6/2016	Room 25	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
16_37898	7/6/2016	Room 24	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Lawrence J Henderson at the above phone number.

INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_37899	7/6/2016	Gym	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
16_37900	7/6/2016	Gym	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
16_37901	7/6/2016	Gym	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
16_37902	7/6/2016	Gym	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.