



Burlington, WA Corporate Laboratory (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)  
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425


## INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Client Name: Woodburn School District  
1390 Meridian Drive  
Woodburn, OR 97071

Reference Number: **16-15757**  
Project: Heritage

System Name:  
System ID Number:  
DWP Source Number:  
Multiple Sources:  
Sample Type: D - Drinking Water  
Sample Purpose: Investigative or Other  
County:

Analyst: mvp  
Date Received: 7/6/2016  
Report Date: 7/20/2016  
Approved By: bj  
Authorized by:

  
Lawrence J Henderson, PhD  
Director of Laboratories, Vice President

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_37586	7/6/2016	Kitchen W Sink	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
16_37587	7/6/2016	Kitchen E Sink	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
16_37588	7/6/2016	HE Gym W Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37589	7/6/2016	HE Gym E Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37590	7/6/2016	Cafe fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37591	7/6/2016	Music Rm 1 Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37592	7/6/2016	Staff Rm Sink	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37593	7/6/2016	Staff Rm Water Filter	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37594	7/6/2016	Rm 9	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37595	7/6/2016	Rm 6	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37596	7/6/2016	Rm 8	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37597	7/6/2016	Rm 4	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37598	7/6/2016	Pod Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37599	7/6/2016	Rm 7	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37600	7/6/2016	Rm 3	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37601	7/6/2016	Rm 5	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37602	7/6/2016	Rm 2	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

**NOTES:**

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Lawrence J Henderson at the above phone number.

## INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_37603	7/6/2016	Rm 17	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37604	7/6/2016	Rm 13	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37605	7/6/2016	Rm 10	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
16_37606	7/6/2016	Rm 14	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37607	7/6/2016	Rm 11	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37608	7/6/2016	Rm 12	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37609	7/6/2016	Rm 16	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37610	7/6/2016	Rm 15	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37611	7/6/2016	Rm 21	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37612	7/6/2016	Rm 19	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37613	7/6/2016	Pod Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37614	7/6/2016	Rm 25	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37615	7/6/2016	Rm 24	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37616	7/6/2016	Rm 20	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37617	7/6/2016	Rm 18	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37618	7/6/2016	Rm 22	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37619	7/6/2016	Rm 23	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37620	7/6/2016	A1 Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37621	7/6/2016	A2 Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37622	7/6/2016	A3 Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37623	7/6/2016	A4 Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37624	7/6/2016	A5 Sink Staff	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37625	7/6/2016	A5 Water Filter	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

**NOTES:**

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

**These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.**