



Burlington, WA Corporate Laboratory (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)  
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

## LEAD & COPPER RULE REPORT

Client Name: Woodburn School District  
1390 Meridian Drive  
Woodburn, OR 97071

Reference Number: **17-14191**

Project: High School

System Name:  
System ID Number:  
DWP Source Number:  
Multiple Sources:  
Sample Type:  
Sample Purpose: Investigative or Other  
County:

Analyst: bj  
Date Received: 6/15/2017  
Report Date: 6/26/2017  
Approved By: anp  
Authorized by:

Thanh B Phan  
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
17_32667	6/15/2017	#1 - Tennis Courts Restroom area	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.160	mg/L	1.3	0.005	200.8	4072	
17_32668	6/15/2017	#2 - Baseball fields Restroom area	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.148	mg/L	1.3	0.005	200.8	4072	
17_32669	6/15/2017	#3 - Athletic Trainer adjacent to Concession	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.015	mg/L	1.3	0.005	200.8	4072	
17_32670	6/15/2017	#4 - CLC Kitchen	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.128	mg/L	1.3	0.005	200.8	4072	
17_32671	6/15/2017	#5 - CLC D.F.	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.145	mg/L	1.3	0.005	200.8	4072	
17_32672	6/15/2017	#6 - Web SS Office Sink	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.037	mg/L	1.3	0.005	200.8	4072	
17_32673	6/15/2017	#7 - Web SS Hall D.F. Left	1030	LEAD	0.008	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.006	mg/L	1.3	0.005	200.8	4072	
17_32674	6/15/2017	#8 - Web SS Hall D.F. Right	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	ND	mg/L	1.3	0.005	200.8	4072	
17_32675	6/15/2017	#9 - Large Common D.F. West Left	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.057	mg/L	1.3	0.005	200.8	4072	
17_32676	6/15/2017	#10 - Large Common D.F. West Right	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.064	mg/L	1.3	0.005	200.8	4072	

**NOTES:**

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

## LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
17_32677	6/15/2017	#11 - Large Common D.F. East Left	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.051	mg/L	1.3	0.005	200.8	4072	
17_32678	6/15/2017	#12 - Large Common D.F. East Right	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.056	mg/L	1.3	0.005	200.8	4072	
17_32679	6/15/2017	#13 - Kitchen Sink	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.042	mg/L	1.3	0.005	200.8	4072	
17_32680	6/15/2017	#14 - Kitchen Kettle	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.120	mg/L	1.3	0.005	200.8	4072	
17_32681	6/15/2017	#15 - Kitchen Sink	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.021	mg/L	1.3	0.005	200.8	4072	
17_32682	6/15/2017	#16 - Kitchen Sink	1030	LEAD	0.013	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.077	mg/L	1.3	0.005	200.8	4072	
17_32683	6/15/2017	#17 - Kitchen Dish Washer	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.024	mg/L	1.3	0.005	200.8	4072	
17_32684	6/15/2017	#18 - Kitchen Sink	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.034	mg/L	1.3	0.005	200.8	4072	
17_32685	6/15/2017	#19 - Gym Hall D.F. Left	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.146	mg/L	1.3	0.005	200.8	4072	
17_32686	6/15/2017	#20 - Gym Hall D.F. Right	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.148	mg/L	1.3	0.005	200.8	4072	
17_32687	6/15/2017	#21 - Large Gym Athletic Ice machine #707	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	ND	mg/L	1.3	0.005	200.8	4072	
17_32688	6/15/2017	#22 - Small Gym - Laundry Ice machine #728	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	ND	mg/L	1.3	0.005	200.8	4072	
17_32689	6/15/2017	#23 - Work Room Left	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.180	mg/L	1.3	0.005	200.8	4072	
17_32690	6/15/2017	#24 - Work Room Right	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.105	mg/L	1.3	0.005	200.8	4072	
17_32691	6/15/2017	#25 - WAAST copy Room #303	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.193	mg/L	1.3	0.005	200.8	4072	

**NOTES:**

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

**These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.**

## LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
17_32692	6/15/2017	#26 - Lectorium Hallway D.F. Left	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.176	mg/L	1.3	0.005	200.8	4072	
17_32693	6/15/2017	#27 - Lectorium Hallway D.F. Right	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.174	mg/L	1.3	0.005	200.8	4072	
17_32694	6/15/2017	#28 - WACA Staff Lounge #405	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.170	mg/L	1.3	0.005	200.8	4072	
17_32695	6/15/2017	#29 - AIS Short Hall D.F. Left	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.109	mg/L	1.3	0.005	200.8	4072	
17_32696	6/15/2017	#30 - AIS Short Hall D.F. Right	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.106	mg/L	1.3	0.005	200.8	4072	
17_32697	6/15/2017	#31 - AIS Long Hall D.F. Left	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.048	mg/L	1.3	0.005	200.8	4072	
17_32698	6/15/2017	#32 - AIS Long Hall D.F. Right	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.052	mg/L	1.3	0.005	200.8	4072	
17_32699	6/15/2017	#33 - AIS Staff Lounge	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.108	mg/L	1.3	0.005	200.8	4072	
17_32700	6/15/2017	#34 - AIS Long Hall D.F. END Left	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.118	mg/L	1.3	0.005	200.8	4072	
17_32701	6/15/2017	#35 - AIS Long Hall D.F. END Right	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.121	mg/L	1.3	0.005	200.8	4072	

**NOTES:**

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

**These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.**