



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



LEAD & COPPER RULE REPORT

Client Name: Woodburn School District
1390 Meridian Drive
Woodburn, OR 97071

Reference Number: **18-20389**

Project: Washington

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 6/8/2018
Report Date: 6/19/2018
Approved By: anp
Authorized by:

Thanh B Phan
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41492	6/6/2018	Wash-1 - Staff R	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.006	mg/L	1.3	0.005	200.8	4072	
18_41493	6/6/2018	Wash-2 - Office	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.009	mg/L	1.3	0.005	200.8	4072	
18_41494	6/6/2018	Wash-3 - W Hall	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.012	mg/L	1.3	0.005	200.8	4072	
18_41495	6/6/2018	Wash-4 - Rm-4	1030	LEAD	0.009	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.011	mg/L	1.3	0.005	200.8	4072	
18_41496	6/6/2018	Wash-5 - E Hall	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.005	mg/L	1.3	0.005	200.8	4072	
18_41497	6/6/2018	Wash-6 - Rm-11	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.009	mg/L	1.3	0.005	200.8	4072	
18_41498	6/6/2018	Wash-7 - Rm-12	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.005	mg/L	1.3	0.005	200.8	4072	
18_41499	6/6/2018	Wash-8 - Music Rm	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.017	mg/L	1.3	0.005	200.8	4072	
18_41500	6/6/2018	Wash-9 - Rm-13	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.005	mg/L	1.3	0.005	200.8	4072	
18_41501	6/6/2018	Wash-10 - Rm-14	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.010	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41502	6/6/2018	Wash-11 - Rm-15	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	ND	mg/L	1.3	0.005	200.8	4072	
18_41503	6/6/2018	Wash-12 - Breezeway 1 S	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	ND	mg/L	1.3	0.005	200.8	4072	
18_41504	6/6/2018	Wash-13 - Breezeway 2 T	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	ND	mg/L	1.3	0.005	200.8	4072	
18_41505	6/6/2018	Wash-14 - Rm-16	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	ND	mg/L	1.3	0.005	200.8	4072	
18_41506	6/6/2018	Wash-15 - Rm-17	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	ND	mg/L	1.3	0.005	200.8	4072	
18_41507	6/6/2018	Wash-16 - Gym-1 S	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.067	mg/L	1.3	0.005	200.8	4072	
18_41508	6/6/2018	Wash-17 - Gym-2 T	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.067	mg/L	1.3	0.005	200.8	4072	
18_41509	6/6/2018	Wash-19 - N Commons	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.014	mg/L	1.3	0.005	200.8	4072	
18_41510	6/6/2018	Wash-20 - Kitchen W	1030	LEAD	0.014	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.067	mg/L	1.3	0.005	200.8	4072	
18_41511	6/6/2018	Wash-21 - Kitchen 6D	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.007	mg/L	1.3	0.005	200.8	4072	
18_41512	6/6/2018	Wash-22 - Kitchen ST	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.160	mg/L	1.3	0.005	200.8	4072	
18_41513	6/6/2018	Wash-23 - Kitchen SP	1030	LEAD	0.007	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.013	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.