



Burlington, WA Corporate Laboratory (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)  
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



## LEAD & COPPER RULE REPORT

Client Name: Woodburn School District  
1390 Meridian Drive  
Woodburn, OR 97071

Reference Number: **18-20405**

Project: French Prairie

System Name:  
System ID Number:  
DWP Source Number:  
Multiple Sources:  
Sample Type:  
Sample Purpose: Investigative or Other  
County:

Analyst: bj  
Date Received: 6/8/2018  
Report Date: 6/19/2018  
Approved By: anp  
Authorized by:

Thanh B Phan  
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41550	6/7/2018	FP 1 - Commons	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.098	mg/L	1.3	0.005	200.8	4072	
18_41551	6/7/2018	FP 2 - Hall A1	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.053	mg/L	1.3	0.005	200.8	4072	
18_41552	6/7/2018	FP 3 - Hall A2	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.052	mg/L	1.3	0.005	200.8	4072	
18_41553	6/7/2018	FP 4 - Hall A3	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.026	mg/L	1.3	0.005	200.8	4072	
18_41554	6/7/2018	FP 5 - Hall B1	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.051	mg/L	1.3	0.005	200.8	4072	
18_41555	6/7/2018	FP 6 - Hall B2	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.047	mg/L	1.3	0.005	200.8	4072	
18_41556	6/7/2018	FP 8 - Gym 2	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.010	mg/L	1.3	0.005	200.8	4072	
18_41557	6/7/2018	FP 11 - Boys Locker R	1030	LEAD	0.010	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.007	mg/L	1.3	0.005	200.8	4072	
18_41558	6/7/2018	FP 12 - Hall C	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.198	mg/L	1.3	0.005	200.8	4072	
18_41559	6/7/2018	FP 13 - Rm 34	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.211	mg/L	1.3	0.005	200.8	4072	

**NOTES:**

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

## LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41560	6/7/2018	FP 14 - Hall D	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.121	mg/L	1.3	0.005	200.8	4072	
18_41561	6/7/2018	FP 15 - Rm 36	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.213	mg/L	1.3	0.005	200.8	4072	
18_41562	6/7/2018	FP 16 - Rm 25	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.242	mg/L	1.3	0.005	200.8	4072	

**NOTES:**

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

**These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.**