



Burlington, WA Corporate Laboratory (a)
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
 540 SW Third Street - Corvallis, OR 97333 - 541.753.4946
Bend, OR Microbiology (e)
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



LEAD & COPPER RULE REPORT

Client Name: **Woodburn School District**
 1390 Meridian Drive
 Woodburn, OR 97071

Reference Number: **18-20420**
 Project: **Lincoln**

System Name:
 System ID Number:
 DWP Source Number:
 Multiple Sources:
 Sample Type:
 Sample Purpose: **Investigative or Other**
 County:

Analyst: **bj**
 Date Received: **6/8/2018**
 Report Date: **6/22/2018**
 Approved By: **anp**
 Authorized by:

Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41581	6/7/2018	L-1 - Gym F	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.021	mg/L	1.3	0.005	200.8	4072	
18_41582	6/7/2018	L-2 - Rm 42	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.120	mg/L	1.3	0.005	200.8	4072	
18_41583	6/7/2018	L-3 - Rm 1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.208	mg/L	1.3	0.005	200.8	4072	
18_41584	6/7/2018	L-5 - Front Hallway F	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.009	mg/L	1.3	0.005	200.8	4072	
18_41585	6/7/2018	L-6 - Rm 6	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.161	mg/L	1.3	0.005	200.8	4072	
18_41586	6/7/2018	L-7 - Rm 10	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.103	mg/L	1.3	0.005	200.8	4072	
18_41587	6/7/2018	L-8 - Rm 14	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.049	mg/L	1.3	0.005	200.8	4072	
18_41588	6/7/2018	L-9 - Rm 16	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.154	mg/L	1.3	0.005	200.8	4072	
18_41589	6/7/2018	L-10 - Rm 18	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.138	mg/L	1.3	0.005	200.8	4072	
18_41590	6/7/2018	L-11 - N Hallway F	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.079	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41591	6/7/2018	L-12 - Rm 19	1030	LEAD	0.026	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.630	mg/L	1.3	0.005	200.8	4072	
18_41592	6/7/2018	L-13 - Rm 20	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.164	mg/L	1.3	0.005	200.8	4072	
18_41593	6/7/2018	L-14 - Rm 17	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.158	mg/L	1.3	0.005	200.8	4072	
18_41594	6/7/2018	L-15 - Rm 15	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.097	mg/L	1.3	0.005	200.8	4072	
18_41595	6/7/2018	L-16 - Back Hall F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.038	mg/L	1.3	0.005	200.8	4072	
18_41596	6/7/2018	L-17 - Back Hall F2	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.035	mg/L	1.3	0.005	200.8	4072	
18_41597	6/7/2018	L-20 - Staff Rm 33	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.024	mg/L	1.3	0.005	200.8	4072	
18_41598	6/7/2018	L-21 - Kitchen HS	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.103	mg/L	1.3	0.005	200.8	4072	
18_41599	6/7/2018	L-22 - Kitchen P1	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.143	mg/L	1.3	0.005	200.8	4072	
18_41600	6/7/2018	L-23 - Kitchen DS	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.038	mg/L	1.3	0.005	200.8	4072	
18_41601	6/7/2018	L-24 - Kitchen DR	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.059	mg/L	1.3	0.005	200.8	4072	
18_41602	6/7/2018	L-25 - Kitchen Ket	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.268	mg/L	1.3	0.005	200.8	4072	
18_41603	6/7/2018	L-26 - Kitchen P2	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.025	mg/L	1.3	0.005	200.8	4072	
18_41604	6/7/2018	L-27 - Kitchen P3	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.051	mg/L	1.3	0.005	200.8	4072	
18_41605	6/7/2018	L-28 - Kitchen Sprayer	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.039	mg/L	1.3	0.005	200.8	4072	
18_41606	6/7/2018	L-29 - Cafeteria 2F	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

