



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



LEAD & COPPER RULE REPORT

Client Name: Woodburn School District
1390 Meridian Drive
Woodburn, OR 97071

Reference Number: **18-20522**

Project: Heritage/Valor

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 6/8/2018
Report Date: 6/25/2018
Approved By: anp
Authorized by:

Lawrence J Henderson, PhD
Director of Laboratories, Vice President

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41859	6/6/2018	H-1 - Prep Sink-1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.146	mg/L	1.3	0.005	200.8	4072	
18_41860	6/6/2018	H-2 - Prep Sink-2	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.115	mg/L	1.3	0.005	200.8	4072	
18_41861	6/6/2018	H-3 - Gym F-1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.164	mg/L	1.3	0.005	200.8	4072	
18_41862	6/6/2018	H-4 - Gym F-2	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.162	mg/L	1.3	0.005	200.8	4072	
18_41863	6/6/2018	H-5 - Rm 1 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.171	mg/L	1.3	0.005	200.8	4072	
18_41864	6/6/2018	H-6 - Staff Sink	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.068	mg/L	1.3	0.005	200.8	4072	
18_41865	6/6/2018	H-7 - Rm-2	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.179	mg/L	1.3	0.005	200.8	4072	
18_41866	6/6/2018	H-8 - Rm-13	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.190	mg/L	1.3	0.005	200.8	4072	
18_41867	6/6/2018	H-9 - Rm-22	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.184	mg/L	1.3	0.005	200.8	4072	
18_41868	6/6/2018	H-10 - Rm-3	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.183	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41869	6/6/2018	H-11 - E Pod	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.183	mg/L	1.3	0.005	200.8	4072	
18_41870	6/6/2018	H-12 - Rm-4	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.245	mg/L	1.3	0.005	200.8	4072	
18_41871	6/6/2018	H-13 - Rm-5	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.204	mg/L	1.3	0.005	200.8	4072	
18_41872	6/6/2018	H-14 - Rm-6	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.208	mg/L	1.3	0.005	200.8	4072	
18_41873	6/6/2018	H-15 - Rm-7	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.202	mg/L	1.3	0.005	200.8	4072	
18_41874	6/6/2018	H-16 - Cafe F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.089	mg/L	1.3	0.005	200.8	4072	
18_41875	6/6/2018	H-17 - HR-5	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.108	mg/L	1.3	0.005	200.8	4072	
18_41876	6/6/2018	H-18 - Rm-11	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.198	mg/L	1.3	0.005	200.8	4072	
18_41877	6/6/2018	H-19 - Rm-21	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.229	mg/L	1.3	0.005	200.8	4072	
18_41878	6/6/2018	H-20 - Rm-24	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.239	mg/L	1.3	0.005	200.8	4072	
18_41879	6/6/2018	H-21 - Rm-12	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.252	mg/L	1.3	0.005	200.8	4072	
18_41880	6/6/2018	H-22 - Rm-15	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.220	mg/L	1.3	0.005	200.8	4072	
18_41881	6/6/2018	H-23 - Rm-16	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.231	mg/L	1.3	0.005	200.8	4072	
18_41882	6/6/2018	H-24 - G Pod Sink	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.214	mg/L	1.3	0.005	200.8	4072	
18_41883	6/6/2018	H-25 - Rm-17	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.217	mg/L	1.3	0.005	200.8	4072	
18_41884	6/6/2018	H-26 - Rm-8	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41884	6/6/2018	H-26 - Rm-8	1022	COPPER	0.232	mg/L	1.3	0.005	200.8	4072	
18_41885	6/6/2018	H-27 - Rm-9	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.193	mg/L	1.3	0.005	200.8	4072	
18_41886	6/6/2018	H-28 - E Pod Sink	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.225	mg/L	1.3	0.005	200.8	4072	
18_41887	6/6/2018	H-29 - Rm-10	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.200	mg/L	1.3	0.005	200.8	4072	
18_41888	6/6/2018	H-31 - Rm-20	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.209	mg/L	1.3	0.005	200.8	4072	
18_41889	6/6/2018	H-32 - Rm-18	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.179	mg/L	1.3	0.005	200.8	4072	
18_41890	6/6/2018	H-33 - A Staff S	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.041	mg/L	1.3	0.005	200.8	4072	
18_41891	6/6/2018	H-34 - F Pod S	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.210	mg/L	1.3	0.005	200.8	4072	
18_41892	6/6/2018	H-35 - Rm 34 S	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.043	mg/L	1.3	0.005	200.8	4072	
18_41893	6/6/2018	H-36 - A F3	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.039	mg/L	1.3	0.005	200.8	4072	
18_41894	6/6/2018	H-37 - A F4	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.039	mg/L	1.3	0.005	200.8	4072	
18_41895	6/6/2018	H-38 - Rm 25 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.226	mg/L	1.3	0.005	200.8	4072	
18_41896	6/6/2018	H-39 - Rm 23 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.231	mg/L	1.3	0.005	200.8	4072	
18_41897	6/6/2018	H-40 - Rm 14 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.247	mg/L	1.3	0.005	200.8	4072	
18_41898	6/6/2018	H-41 - Rm 19 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.258	mg/L	1.3	0.005	200.8	4072	
18_41899	6/6/2018	H-42 - A F2	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.024	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41900	6/6/2018	H-43 - A F1 Tall	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.013	mg/L	1.3	0.005	200.8	4072	
18_41901	6/6/2018	V1 - GL F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.079	mg/L	1.3	0.005	200.8	4072	
18_41902	6/6/2018	V2 - BL F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.072	mg/L	1.3	0.005	200.8	4072	
18_41903	6/6/2018	V3 - Gym F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.182	mg/L	1.3	0.005	200.8	4072	
18_41904	6/6/2018	V4 - Gym F2	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.178	mg/L	1.3	0.005	200.8	4072	
18_41905	6/6/2018	V5 - Cafe F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.086	mg/L	1.3	0.005	200.8	4072	
18_41906	6/6/2018	V6 - Cafe F2	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.071	mg/L	1.3	0.005	200.8	4072	
18_41907	6/6/2018	V7 - Cafe F3	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.117	mg/L	1.3	0.005	200.8	4072	
18_41908	6/6/2018	V8 - Band F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.226	mg/L	1.3	0.005	200.8	4072	
18_41909	6/6/2018	V9 - HR S	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.124	mg/L	1.3	0.005	200.8	4072	
18_41910	6/6/2018	V10 - A6 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.083	mg/L	1.3	0.005	200.8	4072	
18_41911	6/6/2018	V11 - Rm 101 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.219	mg/L	1.3	0.005	200.8	4072	
18_41912	6/6/2018	V12 - Staff Rm S	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.147	mg/L	1.3	0.005	200.8	4072	
18_41913	6/6/2018	V13 - D Pod F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.107	mg/L	1.3	0.005	200.8	4072	
18_41914	6/6/2018	V14 - Rm 106 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.160	mg/L	1.3	0.005	200.8	4072	
18_41915	6/6/2018	V15 - Rm 103 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41915	6/6/2018	V15 - Rm 103 F1	1022	COPPER	0.222	mg/L	1.3	0.005	200.8	4072	
18_41916	6/6/2018	V16 - Rm 108 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.147	mg/L	1.3	0.005	200.8	4072	
18_41917	6/6/2018	V17 - Rm 109 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.136	mg/L	1.3	0.005	200.8	4072	
18_41918	6/6/2018	V18 - Rm 107 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.197	mg/L	1.3	0.005	200.8	4072	
18_41919	6/6/2018	V19 - U Pod F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.161	mg/L	1.3	0.005	200.8	4072	
18_41920	6/6/2018	V20 - Rm 206 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.206	mg/L	1.3	0.005	200.8	4072	
18_41921	6/6/2018	V21 - Rm 208 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.207	mg/L	1.3	0.005	200.8	4072	
18_41922	6/6/2018	V22 - Rm 207 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.126	mg/L	1.3	0.005	200.8	4072	
18_41923	6/6/2018	V23 - Rom 209 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.174	mg/L	1.3	0.005	200.8	4072	
18_41924	6/6/2018	V24 - Rm 210 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.168	mg/L	1.3	0.005	200.8	4072	
18_41925	6/6/2018	V25 - U Pod S	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.185	mg/L	1.3	0.005	200.8	4072	
18_41926	6/6/2018	V26 - Rm 212 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.161	mg/L	1.3	0.005	200.8	4072	
18_41927	6/6/2018	V27 - Rm 211 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.177	mg/L	1.3	0.005	200.8	4072	
18_41928	6/6/2018	V28 - Rm 201 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.182	mg/L	1.3	0.005	200.8	4072	
18_41929	6/6/2018	V29 - Rm 203 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.107	mg/L	1.3	0.005	200.8	4072	
18_41930	6/6/2018	V30 - Rm 204 F1	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.212	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.