

## McKinley

LOCATION_ID	SAMPLE_ID	LOCATION	DATE	LEAD RESULT (ppb)
McKinley/27121.009	22431700-01DW22A	North hall	6/1/2022	ND
McKinley/27121.009	22431700-02BF22A	North hall	6/1/2022	ND
McKinley/27121.009	22431700-03KF22A	Kitchen, hot pot	6/1/2022	9.81
McKinley/27121.009	22431700-04KF22A	Kitchen, dish sprayer	6/1/2022	1.59
McKinley/27121.009	22431700-05DW22A	Gym	6/1/2022	0.554
McKinley/27121.009	22431700-06CF22A	E301	6/1/2022	128
McKinley/27121.009	22431700-06CF22C	E301 (post mitigation)	9/9/2022	0.664
McKinley/27121.009	22431700-07DW22A	E301	6/1/2022	4.46
McKinley/27121.009	22431700-08CF22A	E303	6/1/2022	32.0
McKinley/27121.009	22431700-08CF22B	E303 (post mitigation)	8/23/2022	0.665
McKinley/27121.009	22431700-09DW22A	E303	6/1/2022	6.05
McKinley/27121.009	22431700-10CF22A	E305	6/1/2022	31.1
McKinley/27121.009	22431700-10CF22B	E305 (post mitigation)	8/23/2022	0.645
McKinley/27121.009	22431700-11DW22A	E305	6/1/2022	9.03
McKinley/27121.009	22431700-12CF22A	E307	6/1/2022	13.1
McKinley/27121.009	22431700-13DW22A	E307	6/1/2022	6.78
McKinley/27121.009	22431700-14CF22A	E309	6/1/2022	19.1
McKinley/27121.009	22431700-14CF22C	E309 (post mitigation)	9/9/2022	0.425
McKinley/27121.009	22431700-15DW22A	E309	6/1/2022	12.8
McKinley/27121.009	22431700-16CF22A	E311	6/1/2022	4.49
McKinley/27121.009	22431700-17DW22A	E311	6/1/2022	1.68
McKinley/27121.009	22431700-18CF22A	E313	6/1/2022	1.09
McKinley/27121.009	22431700-19DW22A	E313	6/1/2022	3.08
McKinley/27121.009	22431700-20CF22A	E315	6/1/2022	1.39
McKinley/27121.009	22431700-21DW22A	E315	6/1/2022	2.19
McKinley/27121.009	22431700-22CF22A	S208	6/1/2022	1.65
McKinley/27121.009	22431700-23DW22A	S208	6/1/2022	4.17
McKinley/27121.009	22431700-24CF22A	S206	6/1/2022	0.577
McKinley/27121.009	22431700-25DW22A	S206	6/1/2022	1.61
McKinley/27121.009	22431700-26SF22A	S210	6/1/2022	10.9
McKinley/27121.009	22431700-27DW22A	Hall	6/1/2022	0.711
McKinley/27121.009	22431700-28CF22A	S204	6/1/2022	0.868
McKinley/27121.009	22431700-29DW22A	S204	6/1/2022	2.69
McKinley/27121.009	22431700-30CF22A	S202	6/1/2022	0.831
McKinley/27121.009	22431700-31DW22A	S202	6/1/2022	1.94
McKinley/27121.009	22431700-32CF22A	W124	6/1/2022	0.818
McKinley/27121.009	22431700-33DW22A	W124	6/1/2022	7.89
McKinley/27121.009	22431700-34CF22A	W122	6/1/2022	1.30
McKinley/27121.009	22431700-35DW22A	W122	6/1/2022	11.0
McKinley/27121.009	22431700-36CF22A	W118	6/1/2022	1.04
McKinley/27121.009	22431700-37DW22A	W118	6/1/2022	9.24
McKinley/27121.009	22431700-38CF22A	W114	6/1/2022	53.7
McKinley/27121.009	22431700-38CF22B	W114 (post mitigation)	8/23/2022	0.237

McKinley/27121.009	22431700-39DW22A	W114		6/1/2022	7.91
McKinley/27121.009	22431700-40CF22A	W112		6/1/2022	17.4
McKinley/27121.009	22431700-40CF22C	W112	(post mitigation)	9/9/2022	2.86
McKinley/27121.009	22431700-41DW22A	W112		6/1/2022	2.01
McKinley/27121.009	22431700-42CF22A	W110		6/1/2022	5.47
McKinley/27121.009	22431700-43DW22A	W110		6/1/2022	2.81
McKinley/27121.009	22431700-44DW22A	West hall		6/1/2022	0.976
McKinley/27121.009	22431700-45CF22A	W108		6/1/2022	0.594
McKinley/27121.009	22431700-46DW22A	W108		6/1/2022	2.26
McKinley/27121.009	22431700-47SF22A	W106		6/1/2022	0.632
McKinley/27121.009	22431700-48NS22A	W101		6/1/2022	2.95
McKinley/27121.009	22431700-49SF22A	Library		6/1/2022	5.02
McKinley/27121.009	22431700-50SF22A	N408		6/1/2022	6.67
McKinley/27121.009	22431700-51DW22A	N408		6/1/2022	3.56
McKinley/27121.009	22431700-52DW22A	East hall		6/1/2022	1.92
McKinley/27121.009	22431700-53CF22A	E302		6/1/2022	30.4
McKinley/27121.009	22431700-53CF22C	E302	(post mitigation)	9/9/2022	1.22
McKinley/27121.009	22431700-54DW22A	E302		6/1/2022	1.74
McKinley/27121.009	22431700-55CF22A	E304		6/1/2022	20.1
McKinley/27121.009	22431700-55CF22B	E304	(post mitigation)	8/23/2022	0.556
McKinley/27121.009	22431700-56DW22A	E304		6/1/2022	1.76
McKinley/27121.009	22431700-57CF22A	E306		6/1/2022	1.17
McKinley/27121.009	22431700-58DW22A	E306		6/1/2022	6.71
McKinley/27121.009	22431700-59CF22A	E308		6/1/2022	14.3
McKinley/27121.009	22431700-60DW22A	E308		6/1/2022	5.47
McKinley/27121.009	22431700-61CF22A	East alcove		6/1/2022	3.11
McKinley/27121.009	22431700-62DW22A	East alcove		6/1/2022	15.3
McKinley/27121.009	22431700-62DW22B	East alcove	(post-mitigation)	8/23/2022	3.93
McKinley/27121.009	22431700-63CF22A	S205		6/1/2022	1.41
McKinley/27121.009	22431700-64DW22A	S205		6/1/2022	2.07
McKinley/27121.009	22431700-65CF22A	S203		6/1/2022	3.44
McKinley/27121.009	22431700-66DW22A	S203		6/1/2022	8.33
McKinley/27121.009	22431700-67CF22A	West alcove		6/1/2022	4.52
McKinley/27121.009	22431700-68DW22A	West alcove		6/1/2022	7.98
McKinley/27121.009	22431700-69CF22A	W115		6/1/2022	79.9
McKinley/27121.009	22431700-69CF22B	W115	(post mitigation)	8/23/2022	ND
McKinley/27121.009	22431700-70DW22A	W115		6/1/2022	4.32
McKinley/27121.009	22431700-71CF22A	W113		6/1/2022	120
McKinley/27121.009	22431700-71CF22B	W113	(post mitigation)	8/23/2022	0.448
McKinley/27121.009	22431700-72DW22A	W113		6/1/2022	6.77
McKinley/27121.009	22431700-73CF22A	W111		6/1/2022	77.3
McKinley/27121.009	22431700-73CF22B	W111	(post mitigation)	8/23/2022	0.490
McKinley/27121.009	22431700-74DW22A	W111		6/1/2022	11.2
McKinley/27121.009	22431700-75CF22A	M501		6/1/2022	9.61
McKinley/27121.009	22431700-75CF22A(B)	M501		6/1/2022	8.00
McKinley/27121.009	22431700-76DW22A	M501		6/1/2022	1.19
McKinley/27121.009	22431700-76DW22A(B)	M501		6/1/2022	0.478

McKinley/27121.009	22431700-77CF22A	M502	6/1/2022	8.57
McKinley/27121.009	22431700-78DW22A	M502	6/1/2022	0.731
McKinley/27121.009	22431700-79CF22A	M503	6/1/2022	6.67
McKinley/27121.009	22431700-80DW22A	M503	6/1/2022	0.299
McKinley/27121.009	22431700-81CF22A	M504	6/1/2022	12.0
McKinley/27121.009	22431700-82DW22A	M504	6/1/2022	3.74
McKinley/27121.009	22431700-83CF22A	M505	6/1/2022	14.2
McKinley/27121.009	22431700-84DW22A	M505	6/1/2022	2.13
McKinley/27121.009	22431700-07DW22B	E301	8/23/2022	0.977
McKinley/27121.009	22431700-09DW22B	E303	8/23/2022	0.841
McKinley/27121.009	22431700-11DW22B	E305	8/23/2022	2.11
McKinley/27121.009	22431700-12CF22B	E307	8/23/2022	0.433
McKinley/27121.009	22431700-13DW22B	E307	8/23/2022	0.899
McKinley/27121.009	22431700-48NS22B	Main office, nurse office	8/23/2022	1.56
McKinley/27121.009	22431700-49SF22B	Library N406	8/23/2022	12.1
McKinley/27121.009	22431700-50SF22B	N408	8/23/2022	2.17
McKinley/27121.009	22431700-51DW22B	N408	8/23/2022	3.39
McKinley/27121.009	22431700-56DW22B	E304	8/23/2022	0.471
McKinley/27121.009	22431700-72DW22B	W113	8/23/2022	0.495
McKinley/27121.009	22431700-74DW22B	W111	8/23/2022	0.812