

Elmonica Post Re-Pipe

LOCATION_ID	SAMPLE_ID	LOCATION	DATE	LEAD RESULT (ppb)
Elmonica Elementary/27121.017	22430900-01DW22A	B122	8/12/2022	7.60
Elmonica Elementary/27121.017	22430900-02CF22A	B120	8/12/2022	6.49
Elmonica Elementary/27121.017	22430900-03CF22A	B112	8/12/2022	11.4
Elmonica Elementary/27121.017	22430900-04CF22A	B110	8/12/2022	5.37
Elmonica Elementary/27121.017	22430900-05CF22A	B108	8/12/2022	ND
Elmonica Elementary/27121.017	22430900-06CF22A	B102	8/12/2022	10.5
Elmonica Elementary/27121.017	22430900-07CF22A	B102	8/12/2022	7.52
Elmonica Elementary/27121.017	22430900-08SF22A	Staff lounge	8/12/2022	0.855
Elmonica Elementary/27121.017	22430900-09CF22A	A122	8/12/2022	3.36
Elmonica Elementary/27121.017	22430900-10CF22A	A120	8/12/2022	3.03
Elmonica Elementary/27121.017	22430900-11CF22A	A118	8/12/2022	7.29
Elmonica Elementary/27121.017	22430900-12CF22A	A116	8/12/2022	50.1
Elmonica ES/27121.017	22430900-12CF22B	A116 <i>(post mitigation)</i>	9/9/2022	0.262
Elmonica ES/27121.017	22430900-32DW22A	A116	9/9/2022	0.800
Elmonica Elementary/27121.017	22430900-13CF22A	A114	8/12/2022	3.72
Elmonica Elementary/27121.017	22430900-14CF22A	A112	8/12/2022	5.49
Elmonica Elementary/27121.017	22430900-15CF22A	A108	8/12/2022	5.40
Elmonica Elementary/27121.017	22430900-16CF22A	A106	8/12/2022	5.02
Elmonica Elementary/27121.017	22430900-17CF22A	A104	8/12/2022	5.60
Elmonica Elementary/27121.017	22430900-18CF22A	A102	8/12/2022	3.54
Elmonica Elementary/27121.017	22430900-19CF22A	A100	8/12/2022	14.9
Elmonica ES/27121.017	22430900-01DW22B	B128	9/9/2022	0.707
Elmonica ES/27121.017	22430900-20DW22A	B130	9/9/2022	1.15
Elmonica ES/27121.017	22430900-21DW22A	B124	9/9/2022	3.79
Elmonica ES/27121.017	22430900-22DW22A	B122	9/9/2022	0.967
Elmonica ES/27121.017	22430900-23DW22A	B116	9/9/2022	1.35
Elmonica ES/27121.017	22430900-24DW22A	B106	9/9/2022	0.674
Elmonica ES/27121.017	22430900-25DW22A	A100	9/9/2022	0.246
Elmonica ES/27121.017	22430900-26DW22A	A102	9/9/2022	1.19
Elmonica ES/27121.017	22430900-27DW22A	A104	9/9/2022	0.877
Elmonica ES/27121.017	22430900-28DW22A	A106	9/9/2022	0.906
Elmonica ES/27121.017	22430900-29DW22A	A108	9/9/2022	1.42
Elmonica ES/27121.017	22430900-30DW22A	A112	9/9/2022	0.960
Elmonica ES/27121.017	22430900-31DW22A	A114	9/9/2022	1.36
Elmonica ES/27121.017	22430900-33DW22A	A118	9/9/2022	0.496
Elmonica ES/27121.017	22430900-34DW22A	A120	9/9/2022	0.607
Elmonica ES/27121.017	22430900-35DW22A	A122	9/9/2022	0.857