

Chehalem Post Re-Pipe

LOCATION_ID	SAMPLE_ID	LOCATION	DATE	LEAD RESULT (ppb)
Cehalem/27121.017	22430600-01DW22A	Gym	8/11/2022	1.04
Cehalem/27121.017	22430600-02DW22A	Main hall	8/11/2022	1.17
Cehalem/27121.017	22430600-03DW22A	Café	8/11/2022	0.275
Cehalem/27121.017	22430600-04KF22A	Kitchen, pot filler	8/11/2022	10.5
Cehalem/27121.017	22430600-05KF22A	Kitchen, prep sink	8/11/2022	1.65
Cehalem/27121.017	22430600-06SF22A	Office 1	8/11/2022	1.55
Cehalem/27121.017	22430600-07NS22A	Health	8/11/2022	0.775
Cehalem/27121.017	22430600-08CF22A	A100	8/11/2022	1.65
Cehalem/27121.017	22430600-09CF22A	A102	8/11/2022	6.62
Cehalem/27121.017	22430600-10CF22A	A104	8/11/2022	4.79
Cehalem/27121.017	22430600-11CF22A	A106	8/11/2022	4.52
Cehalem/27121.017	22430600-12CF22A	A108	8/11/2022	5.21
Cehalem/27121.017	22430600-13CF22A	A110	8/11/2022	2.57
Cehalem/27121.017	22430600-14CF22A	A112	8/11/2022	5.46
Cehalem/27121.017	22430600-15CF22A	A114	8/11/2022	7.14
Cehalem/27121.017	22430600-16CF22A	A116	8/11/2022	2.95
Cehalem/27121.017	22430600-17CF22A	A118	8/11/2022	3.34
Cehalem/27121.017	22430600-18CF22A	A120	8/11/2022	3.51
Cehalem/27121.017	22430600-19DW22A	A120	8/11/2022	2.02
Cehalem/27121.017	22430600-20CF22A	A122	8/11/2022	0.746
Cehalem/27121.017	22430600-21DW22A	A122	8/11/2022	1.01
Cehalem ES/27121.017	22430600-09DW22B	A118	9/9/2022	0.858
Cehalem ES/27121.017	22430600-13DW22B	A116	9/9/2022	1.26
Cehalem ES/27121.017	22430600-17DW22B	A114	9/9/2022	0.707
Cehalem ES/27121.017	22430600-21DW22B	A112	9/9/2022	1.15
Cehalem ES/27121.017	22430600-25DW22B	A110	9/9/2022	0.740
Cehalem ES/27121.017	22430600-29DW22B	A108	9/9/2022	1.54
Cehalem ES/27121.017	22430600-33DW22B	A106	9/9/2022	1.98
Cehalem ES/27121.017	22430600-37DW22B	A104	9/9/2022	0.642
Cehalem ES/27121.017	22430600-41DW22B	A102	9/9/2022	1.00
Cehalem ES/27121.017	22430600-45DW22B	A100	9/9/2022	1.16