



**ROCKFORD BOARD OF EDUCATION
INVITATION FOR BID ON SUPPLIES, MATERIALS, EQUIPMENT OR SERVICES
FOR SCHOOL DISTRICT NO. 205
ROCKFORD, ILLINOIS**

IFB No. **23-19 Sterling Holley Garage Renovations**

DATE: **October 3, 2022**

RE: **ADDENDUM NO. 2**

To All Bidders:

Included are modifications, clarifications and/or corrections for the Project Manual and are hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

If you plan to hand deliver your IFB submission on the due date, please note you must check in on the 1st floor prior to coming to the bid opening. Please allow time for this as late submission will not be accepted.

Refer all questions relative to the business aspect, Instructions to Bidders, Special Conditions, and questions concerning the technical aspect of the documents to the Director of Purchasing by email at purchasingdeptstaff@rps205.com.

ROCKFORD BOARD OF EDUCATION

By: Dane Youngblood
Director of Purchasing



ADDENDUM

TO: PROSPECTIVE BIDDERS
RE: ADDENDUM # 2
RPS PROJECT NUMBER: 2212 BFA #1155
FOR: IBF #23-19
Bus Maintenance Remodel for RSP205
ADDRESS: Sterling Holley Center
2000 Christina Street
Rockford, IL
DATE: 10-03-2022

Please attach Addendum 2 to the above Drawings, and kindly take same into consideration in preparing your proposal.

By 
Rob C. Belles,
Belles Firm of Architecture Inc.

This addendum consists of 2 text pages including this sheet.

Project Number: 2212 BFA #1155
IBF #23-19
For: Bus Maintenance Remodel for RSP205
Sterling Holley Center
Christina Street
Rockford, IL

Addendum 2
Page 2

QUESTIONS / CLARIFICATION

1) Q: "Want to clarification that alternate bid should be to remove existing coating system and install clear sealer? per note 5 on A6."

A: Correct. At 101 and 102, remove existing coating and install clear sealer.

2) Q: "In manual it is calling for waterproofing floor system, in drawings A6 , calls for epoxy flake system. Which system should we quote?"

A: There are three types of flooring. 1-Vinyl Tile, primarily in the office area. 2-Clear concrete sealer, primarily in the shop. 3- Epoxy, in the tool room and toilets.

Epoxy is to be a flake system per the note on A6. The final appearance should match the existing toilet rooms at The Operations Support Center, 5052 28th Avenue, 61109.