



## State of Vermont

### LAND USE PERMIT

CASE NO: WW-3-0026  
 APPLICANT: MARION CROSS SCHOOL  
 ADDRESS: CHURCH STREET  
 NORWICH, VT 05055

LAWS/REGULATIONS INVOLVED:  
 Environmental Protection  
 Rules, effective  
 September 10, 1982.

This project, consisting of renovations and additions to an existing school to accommodate a total of 500 students and staff on Route 5, Norwich, Vermont is hereby approved under the requirements of the regulations named above subject to the following conditions:

1. The project must be completed as shown on the plans prepared by Kenneth LeClair, P.E., two sheets entitled:
  - A. "Sewage Disposal System, Marion Cross School" dated April 21, 1988, revised June 30, 1988;
  - B. "Topographic Map As Requested, Marion Cross School" dated June 9, 1988;
 which have been stamped APPROVED by the Division of Protection. No alteration of these plans shall be allowed except where written application has been made to the Agency of Environmental Conservation and approval obtained.
2. A copy of the approved plans and the Land Use Permit shall remain on the project during all phases of construction and, upon request, shall be made available for inspection by State or Local personnel.
3. No alterations to the existing building other than those indicated on the approved plan, which would change or affect the interior waste plumbing, water supply, or wastewater disposal shall be allowed without prior review and approval from the Agency of Environmental Conservation.
4. This Land Use Permit does not relieve you, as applicant, from obtaining all applicable approvals that may be required from the Department of Labor and Industry, the Department of Health or the Town prior to construction.
5. This permit shall in no way relieve you of the obligations of Title 10 Chapter 48, Subchapter 4, for the protection of groundwater.
6. The project is approved for the existing connection to the municipal water system. No other means of obtaining water is permitted without prior review and written approval.
7. The wastewater disposal system shall be constructed as shown on the APPROVED plan and shall be operated at all times in a manner that will not permit the discharge of effluent onto the surface of the ground or into the waters of the State. No construction (buildings, roads, water lines, etc.) that might interfere with the installation or operation of the sewage disposal field or its replacement area is permitted. All isolation distances as set forth in Environmental Protection Rules, Chapter 8, Section 8-08, and Chapter 7, Appendix 7-D, shall be adhered to.
8. The installation of the wastewater disposal system shall be inspected by a registered engineer who shall report in writing prior to use, or occupancy, that the work has been done in accordance with the approved plans and the permit.
9. Prior to covering any interior plumbing the Department of Labor and Industries shall be notified at 828-2106 so that they may inspect the work.
10. The wastewater disposal system shall be constructed, maintained and operated as described in Indirect Discharge Permit #ID-9-0021 issued by Patrick Parenteau, Commissioner on August 2, 1988.
11. There shall be no siamese connection installed on the sprinkler system. No antifreeze or chemicals shall be added to the sprinkler line.

PATRICK A. PARENTEAU, COMMISSIONER  
 DEPARTMENT OF ENVIRONMENTAL  
 CONSERVATION

DATE: AUGUST 11, 1988

BY Daniel Wilson for Karen Thompson  
 REGIONAL ENGINEER

cc: Norwich Town Planning & Board of Selectmen  
 Don Robisky, Chief of Engineering Services  
 Kenneth LeClair, P.E.  
 Department of Labor & Industry