

Any fixture that tested over the action level of 0.015 mg/L, was disabled, repairs made and retested

Project	Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Analyte	Result	EPA Action Level	Units	Project number
Heritage	H1 Kitchen W Sink	7/6/16 6:10 AM	7/15/16	37586	LEAD	0.002	0.015	mg/L	16-15757
Heritage	H2 Kitchen E Sink	7/6/16 6:12 AM	7/15/16	37587	LEAD	0.002	0.015	mg/L	16-15757
Heritage	H3 HE Gym W Fountain	7/6/16 6:13 AM	7/15/16	37588	LEAD	ND	0.015	mg/L	16-15757
Heritage	H3 HE Gym E Fountain	7/6/16 6:14 AM	7/15/16	37589	LEAD	ND	0.015	mg/L	16-15757
Heritage	H4 Music Rm 1 Fountain	7/6/16 6:15 AM	7/15/16	37591	LEAD	ND	0.015	mg/L	16-15757
Heritage	H4 Cafe fountain	7/6/16 6:17 AM	7/15/16	37590	LEAD	ND	0.015	mg/L	16-15757
Heritage	H5 Staff Rm Sink	7/6/16 6:22 AM	7/15/16	37592	LEAD	ND	0.015	mg/L	16-15757
Heritage	H5 Staff Rm Water Filter	7/6/16 6:23 AM	7/15/16	37593	LEAD	ND	0.015	mg/L	16-15757
Heritage	H6 Rm 4	7/6/16 6:24 AM	7/15/16	37597	LEAD	ND	0.015	mg/L	16-15757
Heritage	H6 Pod Fountain	7/6/16 6:25 AM	7/15/16	37598	LEAD	ND	0.015	mg/L	16-15757
Heritage	H6 Rm 2	7/6/16 6:26 AM	7/15/16	37602	LEAD	ND	0.015	mg/L	16-15757
Heritage	H6 Rm 3	7/6/16 6:27 AM	7/15/16	37600	LEAD	ND	0.015	mg/L	16-15757
Heritage	H6 Rm 5	7/6/16 6:28 AM	7/15/16	37601	LEAD	ND	0.015	mg/L	16-15757
Nellie	N1 Room 17	7/6/16 6:30 AM	7/19/16	38808	LEAD	0.008	0.015	mg/L	16-16116
Heritage	H6 Rm 7	7/6/16 6:31 AM	7/15/16	37599	LEAD	ND	0.015	mg/L	16-15757
Heritage	H6 Rm 9	7/6/16 6:32 AM	7/15/16	37594	LEAD	ND	0.015	mg/L	16-15757
Heritage	H6 Rm 8	7/6/16 6:32 AM	7/15/16	37596	LEAD	ND	0.015	mg/L	16-15757
Heritage	H6 Rm 6	7/6/16 6:33 AM	7/15/16	37595	LEAD	ND	0.015	mg/L	16-15757
High School	HS-1 Kitchen H.S.	7/6/16 6:35 AM	7/18/16	38716	LEAD	0.002	0.015	mg/L	16-16101
Heritage	H7 Rm 10	7/6/16 6:35 AM	7/15/16	37605	LEAD	0.004	0.015	mg/L	16-15757
Nellie	N2 Staff Room	7/6/16 6:36 AM	7/19/16	38809	LEAD	ND	0.015	mg/L	16-16116
Heritage	H7 Rm 11	7/6/16 6:36 AM	7/15/16	37607	LEAD	ND	0.015	mg/L	16-15757
Heritage	H7 Rm 12	7/6/16 6:38 AM	7/15/16	37608	LEAD	ND	0.015	mg/L	16-15757
Heritage	H7 Rm 13	7/6/16 6:39 AM	7/15/16	37604	LEAD	ND	0.015	mg/L	16-15757
Washington	1 Room 16	7/6/16 6:40 AM	7/15/16	37844	LEAD	0.006	0.015	mg/L	16-15883
Washington	2 Room 17	7/6/16 6:41 AM	7/15/16	37845	LEAD	0.006	0.015	mg/L	16-15883
Heritage	H7 Rm 15	7/6/16 6:41 AM	7/15/16	37610	LEAD	ND	0.015	mg/L	16-15757
Nellie	N3 Room 18	7/6/16 6:42 AM	7/19/16	38810	LEAD	0.006	0.015	mg/L	16-16116
Heritage	H7 Rm 17	7/6/16 6:43 AM	7/15/16	37603	LEAD	ND	0.015	mg/L	16-15757
Heritage	H7 Rm 16	7/6/16 6:44 AM	7/15/16	37609	LEAD	ND	0.015	mg/L	16-15757
Washington	3 Outside Fountain	7/6/16 6:45 AM	7/15/16	37846	LEAD	0.005	0.015	mg/L	16-15883
Heritage	H7 Rm 14	7/6/16 6:45 AM	7/15/16	37606	LEAD	ND	0.015	mg/L	16-15757
Washington	4 Outside Fountain	7/6/16 6:46 AM	7/15/16	37847	LEAD	0.005	0.015	mg/L	16-15883
Heritage	H8 Rm 19	7/6/16 6:46 AM	7/15/16	37612	LEAD	ND	0.015	mg/L	16-15757
Nellie	N4 Room 19	7/6/16 6:48 AM	7/19/16	38811	LEAD	0.003	0.015	mg/L	16-16116
Heritage	H8 Rm 18	7/6/16 6:48 AM	7/15/16	37617	LEAD	ND	0.015	mg/L	16-15757
Heritage	H8 Rm 20	7/6/16 6:49 AM	7/15/16	37616	LEAD	ND	0.015	mg/L	16-15757
Washington	5 Room 15	7/6/16 6:50 AM	7/15/16	37848	LEAD	0.005	0.015	mg/L	16-15883
Heritage	H8 Pod Fountain	7/6/16 6:50 AM	7/15/16	37613	LEAD	ND	0.015	mg/L	16-15757

Heritage	H8 Rm 21	7/6/16 6:51 AM	7/15/16	37611	LEAD	ND	0.015	mg/L	16-15757
Washington	6 Room 13	7/6/16 6:52 AM	7/15/16	37849	LEAD	0.009	0.015	mg/L	16-15883
Heritage	H8 Rm 22	7/6/16 6:52 AM	7/15/16	37618	LEAD	ND	0.015	mg/L	16-15757
Nellie	N5 Kinder Hallway Tall Fountain	7/6/16 6:54 AM	7/19/16	38812	LEAD	0.001	0.015	mg/L	16-16116
Washington	7 Room 14	7/6/16 6:54 AM	7/18/16	37850	LEAD	0.007	0.015	mg/L	16-15883
Heritage	H8 Rm 25	7/6/16 6:54 AM	7/15/16	37614	LEAD	ND	0.015	mg/L	16-15757
Nellie	N6 Kinder Hallway Short Fountain	7/6/16 6:56 AM	7/19/16	38813	LEAD	0.001	0.015	mg/L	16-16116
Heritage	H8 Rm 23	7/6/16 6:56 AM	7/15/16	37619	LEAD	ND	0.015	mg/L	16-15757
Washington	8 Music Room 21	7/6/16 6:57 AM	7/18/16	37851	LEAD	0.008	0.015	mg/L	16-15883
Heritage	H8 Rm 24	7/6/16 6:57 AM	7/15/16	37615	LEAD	ND	0.015	mg/L	16-15757
Heritage	A A1 Fountain	7/6/16 6:57 AM	7/15/16	37620	LEAD	ND	0.015	mg/L	16-15757
Heritage	A A2 Fountain	7/6/16 6:58 AM	7/15/16	37621	LEAD	ND	0.015	mg/L	16-15757
Heritage	A A3 Fountain	7/6/16 6:59 AM	7/15/16	37622	LEAD	ND	0.015	mg/L	16-15757
Nellie	N7 Room 2	7/6/16 7:00 AM	7/19/16	38814	LEAD	0.004	0.015	mg/L	16-16116
Lincoln	L2 Room 2	7/6/16 7:00 AM	7/18/16	38775	LEAD	0.030	0.015	mg/L	16-16111
Lincoln	L3 Hallway	7/6/16 7:00 AM	7/18/16	38776	LEAD	0.007	0.015	mg/L	16-16111
Lincoln	L4 Office	7/6/16 7:00 AM	7/18/16	38777	LEAD	0.003	0.015	mg/L	16-16111
Lincoln	L5 Office	7/6/16 7:00 AM	7/18/16	38778	LEAD	ND	0.015	mg/L	16-16111
Lincoln	L1 Room 1	7/6/16 7:00 AM	7/19/16	38774	LEAD	0.001	0.015	mg/L	16-16111
Lincoln	L6 Room 6	7/6/16 7:00 AM	7/19/16	38779	LEAD	0.001	0.015	mg/L	16-16111
Lincoln	L10 Room 10	7/6/16 7:00 AM	7/19/16	38780	LEAD	0.001	0.015	mg/L	16-16111
Heritage	A A4 Fountain	7/6/16 7:00 AM	7/15/16	37623	LEAD	ND	0.015	mg/L	16-15757
Heritage	A A5 Sink Staff	7/6/16 7:01 AM	7/15/16	37624	LEAD	ND	0.015	mg/L	16-15757
Heritage	A A5 Water Filter	7/6/16 7:02 AM	7/15/16	37625	LEAD	ND	0.015	mg/L	16-15757
Washington	9 Room 11	7/6/16 7:03 AM	7/18/16	37852	LEAD	0.008	0.015	mg/L	16-15883
Nellie	N8 Room 3	7/6/16 7:04 AM	7/19/16	38815	LEAD	0.011	0.015	mg/L	16-16116
Valor	L Girl's Locker Room	7/6/16 7:04 AM	7/18/16	37936	LEAD	ND	0.015	mg/L	16-15908
Valor	L Boy's Locker Room	7/6/16 7:05 AM	7/18/16	37937	LEAD	ND	0.015	mg/L	16-15908
Washington	10 Room 12	7/6/16 7:05 AM	7/18/16	37853	LEAD	0.007	0.015	mg/L	16-15883
Nellie	N9 Room 5	7/6/16 7:08 AM	7/19/16	38816	LEAD	0.006	0.015	mg/L	16-16116
Valor	V1 VA Gym S Fountain	7/6/16 7:09 AM	7/18/16	37938	LEAD	ND	0.015	mg/L	16-15908
Valor	V1 VA Gym N Fountain	7/6/16 7:10 AM	7/18/16	37939	LEAD	ND	0.015	mg/L	16-15908
Valor	V2 VA Cafe E Fountain	7/6/16 7:11 AM	7/18/16	37942	LEAD	ND	0.015	mg/L	16-15908
Nellie	N10 Room 6	7/6/16 7:12 AM	7/19/16	38817	LEAD	0.009	0.015	mg/L	16-16116
Valor	V2 VA Cafe W Fountain	7/6/16 7:12 AM	7/18/16	37940	LEAD	ND	0.015	mg/L	16-15908
Washington	11 Hallway	7/6/16 7:12 AM	7/18/16	37854	LEAD	0.006	0.015	mg/L	16-15883
Valor	V2 VA Cafe Middle Fountain	7/6/16 7:13 AM	7/18/16	37941	LEAD	ND	0.015	mg/L	16-15908
Valor	V3 VA Band/Music	7/6/16 7:14 AM	7/18/16	37943	LEAD	ND	0.015	mg/L	16-15908
High School	HS-2 Webbs Hall	7/6/16 7:15 AM	7/18/16	38717	LEAD	0.004	0.015	mg/L	16-16101
Nellie	N11 Room 7	7/6/16 7:16 AM	7/19/16	38818	LEAD	0.007	0.015	mg/L	16-16116
High School	HS-3 Webbs Hall	7/6/16 7:16 AM	7/18/16	38718	LEAD	0.004	0.015	mg/L	16-16101
Washington	12 Hallway	7/6/16 7:16 AM	7/18/16	37855	LEAD	0.005	0.015	mg/L	16-15883

Valor	V4 A6	7/6/16 7:17 AM	7/18/16	37944	LEAD	ND	0.015	mg/L	16-15908
Valor	V4 Office Filter Water	7/6/16 7:18 AM	7/18/16	37945	LEAD	ND	0.015	mg/L	16-15908
High School	HS-4 Webbs Office	7/6/16 7:19 AM	7/18/16	38719	LEAD	0.001	0.015	mg/L	16-16101
Valor	V4 Room 101	7/6/16 7:19 AM	7/18/16	37948	LEAD	ND	0.015	mg/L	16-15908
Lincoln	L11 Hallway	7/6/16 7:20 AM	7/19/16	38781	LEAD	ND	0.015	mg/L	16-16111
Lincoln	L12 Hallway	7/6/16 7:20 AM	7/19/16	38782	LEAD	ND	0.015	mg/L	16-16111
Washington	13 Room 4	7/6/16 7:20 AM	7/18/16	37856	LEAD	0.007	0.015	mg/L	16-15883
Lincoln	L13 Room 14	7/6/16 7:22 AM	7/19/16	38783	LEAD	0.002	0.015	mg/L	16-16111
High School	HS-5 Lg. Commons	7/6/16 7:22 AM	7/18/16	38720	LEAD	ND	0.015	mg/L	16-16101
Nellie	N12 Library Hallway Tall Fountain	7/6/16 7:23 AM	7/19/16	38819	LEAD	0.002	0.015	mg/L	16-16116
High School	HS-6 Lg. Commons	7/6/16 7:23 AM	7/18/16	38721	LEAD	ND	0.015	mg/L	16-16101
Valor	V4 Staff Room Sink	7/6/16 7:23 AM	7/18/16	37947	LEAD	ND	0.015	mg/L	16-15908
French Prairie	F 21 Gym	7/6/16 7:23 AM	7/18/16	37902	LEAD	0.002	0.015	mg/L	16-15891
Nellie	N13 Library Hallway Short Fountain	7/6/16 7:24 AM	7/19/16	38820	LEAD	0.002	0.015	mg/L	16-16116
Valor	V4 Staff Room Water Filter	7/6/16 7:24 AM	7/18/16	37946	LEAD	ND	0.015	mg/L	16-15908
Washington	14 Hallway	7/6/16 7:24 AM	7/18/16	37857	LEAD	0.006	0.015	mg/L	16-15883
Lincoln	L14 Room 16	7/6/16 7:25 AM	7/19/16	38784	LEAD	0.003	0.015	mg/L	16-16111
Valor	V4 Room 103	7/6/16 7:26 AM	7/18/16	37951	LEAD	ND	0.015	mg/L	16-15908
High School	HS-7 Lg. Commons	7/6/16 7:27 AM	7/18/16	38722	LEAD	ND	0.015	mg/L	16-16101
High School	HS-8 Lg. Commons	7/6/16 7:27 AM	7/18/16	38723	LEAD	ND	0.015	mg/L	16-16101
Valor	V4 Room 106	7/6/16 7:27 AM	7/18/16	37953	LEAD	ND	0.015	mg/L	16-15908
Washington	15 Room 3	7/6/16 7:27 AM	7/18/16	37858	LEAD	0.005	0.015	mg/L	16-15883
Lincoln	L15 Room 18	7/6/16 7:28 AM	7/19/16	38785	LEAD	0.003	0.015	mg/L	16-16111
Valor	V4 Room 108	7/6/16 7:28 AM	7/18/16	37952	LEAD	ND	0.015	mg/L	16-15908
Valor	V4 Room 109	7/6/16 7:29 AM	7/18/16	37949	LEAD	ND	0.015	mg/L	16-15908
Nellie	N14 Room 9	7/6/16 7:30 AM	7/19/16	38821	LEAD	0.005	0.015	mg/L	16-16116
Lincoln	L16 Hallway	7/6/16 7:30 AM	7/19/16	38786	LEAD	0.040	0.015	mg/L	16-16111
Lincoln	L17 Room 19	7/6/16 7:30 AM	7/19/16	38787	LEAD	0.008	0.015	mg/L	16-16111
Valor	V4 Room 107	7/6/16 7:30 AM	7/18/16	37950	LEAD	ND	0.015	mg/L	16-15908
Washington	16 Staff Room Refer	7/6/16 7:31 AM	7/18/16	37859	LEAD	ND	0.015	mg/L	16-15883
High School	HS-10 Nurse Room	7/6/16 7:32 AM	7/18/16	38725	LEAD	0.005	0.015	mg/L	16-16101
Valor	V5 Room 212	7/6/16 7:32 AM	7/18/16	37954	LEAD	ND	0.015	mg/L	16-15908
French Prairie	F 1 Hall A	7/6/16 7:32 AM	7/18/16	37882	LEAD	0.003	0.015	mg/L	16-15891
Valor	V5 Room 211	7/6/16 7:33 AM	7/18/16	37955	LEAD	ND	0.015	mg/L	16-15908
Washington	17 Staff Room Water Filter	7/6/16 7:33 AM	7/18/16	37860	LEAD	ND	0.015	mg/L	16-15883
Nellie	N15 Room 10	7/6/16 7:34 AM	7/19/16	38822	LEAD	0.004	0.015	mg/L	16-16116
Valor	V5 Room 209	7/6/16 7:34 AM	7/18/16	37956	LEAD	0.035	0.015	mg/L	16-15908
High School	HS-11 Small Commons	7/6/16 7:35 AM	7/18/16	38726	LEAD	ND	0.015	mg/L	16-16101
High School	HS-12 Small Commons	7/6/16 7:35 AM	7/18/16	38727	LEAD	ND	0.015	mg/L	16-16101
Valor	V5 Room 210	7/6/16 7:35 AM	7/18/16	37957	LEAD	ND	0.015	mg/L	16-15908
French Prairie	F 2 Hall A	7/6/16 7:35 AM	7/18/16	37883	LEAD	0.003	0.015	mg/L	16-15891
French Prairie	F 3 Hall A	7/6/16 7:36 AM	7/18/16	37884	LEAD	0.007	0.015	mg/L	16-15891

Washington	18 Kitchen Kettle	7/6/16 7:36 AM	7/18/16	37861	LEAD	0.015	0.015	mg/L	16-15883
Nellie	N16 Room 11	7/6/16 7:37 AM	7/19/16	38823	LEAD	0.004	0.015	mg/L	16-16116
High School	HS-13 Bistro	7/6/16 7:38 AM	7/18/16	38728	LEAD	0.002	0.015	mg/L	16-16101
Valor	V5 Room 208	7/6/16 7:38 AM	7/18/16	37958	LEAD	ND	0.015	mg/L	16-15908
Lincoln	L18 Room 20	7/6/16 7:40 AM	7/19/16	38788	LEAD	0.002	0.015	mg/L	16-16111
Lincoln	L19 Room 17	7/6/16 7:40 AM	7/19/16	38789	LEAD	0.003	0.015	mg/L	16-16111
Lincoln	L20 Room 15	7/6/16 7:40 AM	7/19/16	38790	LEAD	0.001	0.015	mg/L	16-16111
High School	HS-14 Waast Staff Work Rm	7/6/16 7:40 AM	7/18/16	38729	LEAD	0.014	0.015	mg/L	16-16101
French Prairie	F 4 Staff Room	7/6/16 7:40 AM	7/18/16	37885	LEAD	ND	0.015	mg/L	16-15891
Washington	19 Kitchen Prep Sink	7/6/16 7:40 AM	7/18/16	37862	LEAD	0.009	0.015	mg/L	16-15883
Valor	V5 Room 207	7/6/16 7:41 AM	7/18/16	37961	LEAD	ND	0.015	mg/L	16-15908
Nellie	N17 Room 13	7/6/16 7:42 AM	7/19/16	38824	LEAD	0.004	0.015	mg/L	16-16116
High School	HS-15 Waast Staff Lounge	7/6/16 7:42 AM	7/18/16	38730	LEAD	0.012	0.015	mg/L	16-16101
French Prairie	F 5 Staff Room	7/6/16 7:42 AM	7/18/16	37886	LEAD	ND	0.015	mg/L	16-15891
Valor	V5 Upstairs Fountain	7/6/16 7:43 AM	7/18/16	37959	LEAD	ND	0.015	mg/L	16-15908
Washington	20 Kitchen Sink	7/6/16 7:43 AM	7/18/16	37863	LEAD	0.004	0.015	mg/L	16-15883
Valor	V5 Room 206	7/6/16 7:44 AM	7/18/16	37960	LEAD	ND	0.015	mg/L	16-15908
French Prairie	F 6 Commons	7/6/16 7:44 AM	7/18/16	37887	LEAD	0.005	0.015	mg/L	16-15891
Lincoln	L21 Hallway	7/6/16 7:45 AM	7/19/16	38791	LEAD	0.001	0.015	mg/L	16-16111
Lincoln	L22 Hallway	7/6/16 7:45 AM	7/19/16	38792	LEAD	0.001	0.015	mg/L	16-16111
Washington	21 Commons WF	7/6/16 7:45 AM	7/18/16	37864	LEAD	0.005	0.015	mg/L	16-15883
High School	HS-16 Library	7/6/16 7:46 AM	7/18/16	38731	LEAD	0.002	0.015	mg/L	16-16101
Valor	V5 Room 203	7/6/16 7:46 AM	7/18/16	37962	LEAD	ND	0.015	mg/L	16-15908
French Prairie	F 7 Hall B	7/6/16 7:46 AM	7/18/16	37888	LEAD	0.002	0.015	mg/L	16-15891
Valor	V5 Room 204	7/6/16 7:47 AM	7/18/16	37963	LEAD	ND	0.015	mg/L	16-15908
Nellie	N18 Room 12	7/6/16 7:48 AM	7/19/16	38825	LEAD	0.004	0.015	mg/L	16-16116
Lincoln	L23 Staff Lounge	7/6/16 7:48 AM	7/19/16	38793	LEAD	0.003	0.015	mg/L	16-16111
Lincoln	L24 Staff Lounge	7/6/16 7:48 AM	7/19/16	38794	LEAD	ND	0.015	mg/L	16-16111
Valor	V5 Room 201	7/6/16 7:48 AM	7/18/16	37964	LEAD	ND	0.015	mg/L	16-15908
French Prairie	F 8 Hall B	7/6/16 7:48 AM	7/18/16	37889	LEAD	0.002	0.015	mg/L	16-15891
Washington	22 Commons WF	7/6/16 7:50 AM	7/18/16	37865	LEAD	0.010	0.015	mg/L	16-15883
French Prairie	F 9 Boy's Locker Room	7/6/16 7:52 AM	7/18/16	37890	LEAD	0.020	0.015	mg/L	16-15891
Nellie	N19 Room 14	7/6/16 7:53 AM	7/19/16	38826	LEAD	0.004	0.015	mg/L	16-16116
French Prairie	F 10 Hall C	7/6/16 7:54 AM	7/18/16	37891	LEAD	0.002	0.015	mg/L	16-15891
Washington	23 Room 18	7/6/16 7:54 AM	7/18/16	37866	LEAD	0.005	0.015	mg/L	16-15883
Lincoln	L25 Kitchen	7/6/16 7:55 AM	7/19/16	38795	LEAD	0.006	0.015	mg/L	16-16111
French Prairie	F 11 Kitchen	7/6/16 7:56 AM	7/18/16	37892	LEAD	ND	0.015	mg/L	16-15891
Washington	24 Room 19	7/6/16 7:56 AM	7/18/16	37867	LEAD	0.003	0.015	mg/L	16-15883
Nellie	N20 Room 15	7/6/16 7:58 AM	7/19/16	38827	LEAD	0.003	0.015	mg/L	16-16116
Lincoln	L26 Kitchen	7/6/16 7:58 AM	7/19/16	38796	LEAD	0.002	0.015	mg/L	16-16111
High School	HS-17 Room 315	7/6/16 7:59 AM	7/18/16	38732	LEAD	ND	0.015	mg/L	16-16101
Lincoln	L27 Kitchen	7/6/16 8:00 AM	7/19/16	38797	LEAD	0.003	0.015	mg/L	16-16111

Lincoln	L28 Kitchen	7/6/16 8:00 AM	7/19/16	38798	LEAD	0.013	0.015	mg/L	16-16111
Lincoln	L29 Kitchen	7/6/16 8:00 AM	7/19/16	38799	LEAD	0.038	0.015	mg/L	16-16111
French Prairie	F 12 Kitchen	7/6/16 8:00 AM	7/18/16	37893	LEAD	0.002	0.015	mg/L	16-15891
Washington	25 Room 20	7/6/16 8:00 AM	7/18/16	37868	LEAD	0.004	0.015	mg/L	16-15883
Nellie	N21 Cafeteria	7/6/16 8:01 AM	7/19/16	38828	LEAD	0.004	0.015	mg/L	16-16116
High School	HS-9 Room B-11 (116)	7/6/16 8:01 AM	7/18/16	38724	LEAD	0.032	0.015	mg/L	16-16101
Washington	26 Gym WF	7/6/16 8:01 AM	7/18/16	37869	LEAD	0.001	0.015	mg/L	16-15883
French Prairie	F 13 Room 34	7/6/16 8:02 AM	7/18/16	37894	LEAD	ND	0.015	mg/L	16-15891
French Prairie	F 14 Room 34	7/6/16 8:02 AM	7/18/16	37895	LEAD	ND	0.015	mg/L	16-15891
Washington	27 Gym WF	7/6/16 8:02 AM	7/18/16	37870	LEAD	0.002	0.015	mg/L	16-15883
Washington	28 Office	7/6/16 8:03 AM	7/18/16	37871	LEAD	0.009	0.015	mg/L	16-15883
Lincoln	L30 Cafeteria	7/6/16 8:05 AM	7/19/16	38800	LEAD	0.004	0.015	mg/L	16-16111
Nellie	N22 Kitchen Steamer - Back	7/6/16 8:06 AM	7/19/16	38829	LEAD	0.010	0.015	mg/L	16-16116
High School	HS-18 Waca Office Staff Rm	7/6/16 8:06 AM	7/18/16	38733	LEAD	0.002	0.015	mg/L	16-16101
Nellie	N23 Kitchen Steamer - Back	7/6/16 8:07 AM	7/19/16	38830	LEAD	0.002	0.015	mg/L	16-16116
French Prairie	F 15 Hall D	7/6/16 8:10 AM	7/18/16	37896	LEAD	0.001	0.015	mg/L	16-15891
Nellie	N24 Kitchen Triple Sink	7/6/16 8:13 AM	7/19/16	38831	LEAD	0.007	0.015	mg/L	16-16116
High School	HS-20 Lectorium - Front	7/6/16 8:13 AM	7/18/16	38734	LEAD	ND	0.015	mg/L	16-16101
Nellie	N25 Kitchen Triple Sink	7/6/16 8:15 AM	7/19/16	38832	LEAD	0.006	0.015	mg/L	16-16116
Lincoln	L31 Hallway	7/6/16 8:15 AM	7/19/16	38801	LEAD	0.234	0.015	mg/L	16-16111
Lincoln	L32 Gym	7/6/16 8:15 AM	7/19/16	38802	LEAD	0.002	0.015	mg/L	16-16111
French Prairie	F 16 Room 25	7/6/16 8:15 AM	7/18/16	37897	LEAD	0.002	0.015	mg/L	16-15891
French Prairie	F 17 Room 24	7/6/16 8:17 AM	7/18/16	37898	LEAD	0.002	0.015	mg/L	16-15891
High School	HS-21 Athletic Trainer	7/6/16 8:20 AM	7/18/16	38735	LEAD	0.006	0.015	mg/L	16-16101
French Prairie	F 18 Gym	7/6/16 8:20 AM	7/18/16	37899	LEAD	0.003	0.015	mg/L	16-15891
French Prairie	F 19 Gym	7/6/16 8:21 AM	7/18/16	37900	LEAD	0.005	0.015	mg/L	16-15891
French Prairie	F 20 Gym	7/6/16 8:22 AM	7/18/16	37901	LEAD	0.002	0.015	mg/L	16-15891
High School	HS-22 Gym Hall	7/6/16 8:23 AM	7/18/16	38736	LEAD	ND	0.015	mg/L	16-16101
High School	HS-23 Gym Hall	7/6/16 8:24 AM	7/18/16	38737	LEAD	ND	0.015	mg/L	16-16101
Lincoln	L33 Room 42	7/6/16 8:30 AM	7/20/16	38803	LEAD	0.002	0.015	mg/L	16-16111
High School	HS-24 Tennis Court	7/6/16 8:32 AM	7/18/16	38738	LEAD	ND	0.015	mg/L	16-16101
High School	HS-25 CIC - Preschool	7/6/16 8:38 AM	7/18/16	38739	LEAD	ND	0.015	mg/L	16-16101
High School	HS-26 CIC - Kitchen	7/6/16 8:39 AM	7/18/16	38740	LEAD	ND	0.015	mg/L	16-16101
High School	HS-27 CIC - Hall	7/6/16 8:40 AM	7/18/16	38741	LEAD	0.001	0.015	mg/L	16-16101
High School	HS-28 CIC - Infant	7/6/16 8:41 AM	7/18/16	38742	LEAD	ND	0.015	mg/L	16-16101
High School	HS-29 Outside A. Trainer	7/6/16 8:50 AM	7/18/16	38743	LEAD	ND	0.015	mg/L	16-16101
High School	HS-30 Mod 906	7/6/16 9:01 AM	7/18/16	38744	LEAD	ND	0.015	mg/L	16-16101
High School	HS-31 S-W Hall	7/6/16 9:09 AM	7/18/16	38745	LEAD	ND	0.015	mg/L	16-16101
High School	HS-32 S-W Hall	7/6/16 9:09 AM	7/18/16	38746	LEAD	ND	0.015	mg/L	16-16101
High School	HS-33 S-N Hall	7/6/16 9:13 AM	7/18/16	38747	LEAD	ND	0.015	mg/L	16-16101
High School	HS-34 S-N Hall	7/6/16 9:13 AM	7/18/16	38748	LEAD	ND	0.015	mg/L	16-16101
High School	HS-35 Multi-purpose	7/6/16 9:15 AM	7/18/16	38749	LEAD	0.002	0.015	mg/L	16-16101

High School	HS-36 Staff Lounge	7/6/16 9:19 AM	7/18/16	38750	LEAD	ND	0.015	mg/L	16-16101
High School	HS-37 N-S Hall	7/6/16 9:20 AM	7/18/16	38751	LEAD	ND	0.015	mg/L	16-16101
High School	HS-38 N-S Hall	7/6/16 9:20 AM	7/18/16	38752	LEAD	ND	0.015	mg/L	16-16101
High School	HS-39 Counselor	7/6/16 9:22 AM	7/19/16	38753	LEAD	0.001	0.015	mg/L	16-16101
Heritage	K Kitchen RR	8/4/16 6:16 AM	8/26/16	51417	LEAD	ND	0.015	mg/L	16-20838
Heritage	HECR Rm 24	8/4/16 6:17 AM	8/26/16	51399	LEAD	0.001	0.015	mg/L	16-20838
Heritage	K Handwash 1	8/4/16 6:17 AM	8/26/16	51419	LEAD	ND	0.015	mg/L	16-20838
Heritage	K Handwash 2	8/4/16 6:18 AM	8/26/16	51418	LEAD	0.001	0.015	mg/L	16-20838
Heritage	K Dishwasher sink	8/4/16 6:19 AM	8/26/16	51416	LEAD	0.001	0.015	mg/L	16-20838
Heritage	K K Chem disp sink	8/4/16 6:20 AM	8/26/16	51415	LEAD	ND	0.015	mg/L	16-20838
Heritage	K Kitchen Large Kettle	8/4/16 6:21 AM	8/26/16	51434	LEAD	0.003	0.015	mg/L	16-20838
Heritage	Kitchen Kitchen small kettle	8/4/16 6:22 AM	8/26/16	51433	LEAD	0.005	0.015	mg/L	16-20838
Heritage	C Café main	8/4/16 6:23 AM	8/26/16	51429	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HECR Rm 1	8/4/16 6:25 AM	8/26/16	51407	LEAD	0.245	0.015	mg/L	16-20838
Heritage	HE Health Rm Health Rm	8/4/16 6:27 AM	8/26/16	51425	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HECR Rm 2	8/4/16 6:28 AM	8/26/16	51406	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HERR HeE Lobby G1	8/4/16 6:30 AM	8/26/16	51343	LEAD	ND	0.015	mg/L	16-20838
Heritage	HERR HE Lobby G2	8/4/16 6:31 AM	8/26/16	51350	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HERR HE Lobby G3	8/4/16 6:32 AM	8/26/16	51345	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HERR HE Lobby G4	8/4/16 6:33 AM	8/26/16	51364	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HERR HE Lobby B2	8/4/16 6:34 AM	8/26/16	51342	LEAD	ND	0.015	mg/L	16-20838
Heritage	HERR HE Lobby B1	8/4/16 6:34 AM	8/26/16	51344	LEAD	ND	0.015	mg/L	16-20838
Heritage	HERR HE Lobby B3	8/4/16 6:35 AM	8/26/16	51354	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HERR HE Lobby B4	8/4/16 6:36 AM	8/26/16	51362	LEAD	0.002	0.015	mg/L	16-20838
Heritage	HERR HE Staff RR Men	8/4/16 6:37 AM	8/26/16	51351	LEAD	ND	0.015	mg/L	16-20838
Heritage	HERR HE Staff RR Women	8/4/16 6:38 AM	8/26/16	51348	LEAD	ND	0.015	mg/L	16-20838
Heritage	HERR E Pod G1	8/4/16 6:40 AM	8/26/16	51353	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HERR HE E Pod G2	8/4/16 6:41 AM	8/26/16	51352	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HERR HE E Pod B1	8/4/16 6:42 AM	8/26/16	51349	LEAD	ND	0.015	mg/L	16-20838
Heritage	HERR HERR E Pod B2	8/4/16 6:43 AM	8/26/16	51363	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HECR Rm 3	8/4/16 6:44 AM	8/26/16	51414	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HECR Rm 5	8/4/16 6:45 AM	8/26/16	51424	LEAD	ND	0.015	mg/L	16-20838
Heritage	HECR Rm 7	8/4/16 6:46 AM	8/26/16	51420	LEAD	ND	0.015	mg/L	16-20838
Heritage	HE Pod Pod E	8/4/16 6:47 AM	8/26/16	51432	LEAD	0.008	0.015	mg/L	16-20838
Heritage	HECR Rm 9	8/4/16 6:48 AM	8/26/16	51421	LEAD	ND	0.015	mg/L	16-20838
Heritage	HECR Rm 8	8/4/16 6:48 AM	8/26/16	51423	LEAD	0.002	0.015	mg/L	16-20838
Heritage	HECR Rm 6	8/4/16 6:49 AM	8/26/16	51396	LEAD	ND	0.015	mg/L	16-20838
Heritage	HECR Rm 4	8/4/16 6:50 AM	8/26/16	51422	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HE Core He Media Work Rm	8/4/16 6:51 AM	8/26/16	51444	LEAD	ND	0.015	mg/L	16-20838
Heritage	HERR HE life skills RR	8/4/16 6:52 AM	8/26/16	51347	LEAD	ND	0.015	mg/L	16-20838
Heritage	HERR Core Staff 1	8/4/16 6:53 AM	8/26/16	51346	LEAD	ND	0.015	mg/L	16-20838
Heritage	HERR Core Staff RR 2	8/4/16 6:54 AM	8/26/16	51356	LEAD	ND	0.015	mg/L	16-20838

Heritage	HERR F Pod B1	8/4/16 6:55 AM	8/26/16	51358	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HERR F Pod B2	8/4/16 6:56 AM	8/26/16	51355	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HERR F Pod G1	8/4/16 6:57 AM	8/26/16	51361	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HERR F Pod G2	8/4/16 6:58 AM	8/26/16	51357	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HECR Rm 13	8/4/16 6:59 AM	8/26/16	51409	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HECR Rm 11	8/4/16 6:59 AM	8/26/16	51412	LEAD	0.003	0.015	mg/L	16-20838
Heritage	HECR Rm 15	8/4/16 7:00 AM	8/26/16	51395	LEAD	0.006	0.015	mg/L	16-20838
Lincoln Elementary School	F-1 Room #1	8/4/16 7:00 AM	8/22/16	49122	LEAD	0.015	0.015	mg/L	16-20213
Heritage	HE Pod F Pod	8/4/16 7:01 AM	8/26/16	51430	LEAD	0.004	0.015	mg/L	16-20838
Heritage	HECR Rm 17	8/4/16 7:02 AM	8/26/16	51411	LEAD	0.002	0.015	mg/L	16-20838
Heritage	HECR Rm 16	8/4/16 7:03 AM	8/26/16	51405	LEAD	0.005	0.015	mg/L	16-20838
Heritage	HECR Rm 14	8/4/16 7:04 AM	8/30/16	51413	LEAD	0.011	0.015	mg/L	16-20838
Heritage	HECR Rm 12	8/4/16 7:05 AM	8/26/16	51397	LEAD	0.002	0.015	mg/L	16-20838
Heritage	HECR Rm 10	8/4/16 7:06 AM	8/26/16	51410	LEAD	ND	0.015	mg/L	16-20838
Heritage	C HE Core	8/4/16 7:07 AM	8/26/16	51428	LEAD	0.239	0.015	mg/L	16-20838
Heritage	HECR Rm 19	8/4/16 7:09 AM	8/26/16	51408	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HERR G Pod G1	8/4/16 7:10 AM	8/26/16	51360	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HERR G Pod G2	8/4/16 7:11 AM	8/26/16	51359	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HERR G Pod B1	8/4/16 7:12 AM	8/26/16	51373	LEAD	ND	0.015	mg/L	16-20838
Lincoln Elementary School	F-2 Office both sinks	8/4/16 7:12 AM	8/22/16	49123	LEAD	0.021	0.015	mg/L	16-20213
Lincoln Elementary School	F-3 Office both sinks	8/4/16 7:12 AM	8/22/16	49124	LEAD	0.044	0.015	mg/L	16-20213
Heritage	HERR G Pod B2	8/4/16 7:13 AM	8/26/16	51374	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HECR Rm 21	8/4/16 7:14 AM	8/26/16	51403	LEAD	ND	0.015	mg/L	16-20838
Heritage	HECR Rm 23	8/4/16 7:15 AM	8/26/16	51401	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HECR Rm 25	8/4/16 7:16 AM	8/26/16	51404	LEAD	ND	0.015	mg/L	16-20838
Heritage	HE Pod G Pod	8/4/16 7:18 AM	8/26/16	51431	LEAD	ND	0.015	mg/L	16-20838
Heritage	HECR Rm 22	8/4/16 7:19 AM	8/26/16	51402	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HECR Rm 20	8/4/16 7:20 AM	8/26/16	51398	LEAD	ND	0.015	mg/L	16-20838
Heritage	HECR Rm 18	8/4/16 7:21 AM	8/26/16	51400	LEAD	ND	0.015	mg/L	16-20838
WHS	W-1 Loading dock	8/4/16 7:21 AM	8/25/16	51011	LEAD	ND	0.015	mg/L	16-20821
WHS	W-2 Loading dock	8/4/16 7:22 AM	8/25/16	51012	LEAD	0.001	0.015	mg/L	16-20821
Lincoln Elementary School	F-4 Room #6	8/4/16 7:22 AM	8/22/16	49125	LEAD	0.010	0.015	mg/L	16-20213
Lincoln Elementary School	F-5 Room #6	8/4/16 7:22 AM	8/22/16	49126	LEAD	0.197	0.015	mg/L	16-20213
WHS	W-3 Kitchen	8/4/16 7:25 AM	8/25/16	51013	LEAD	0.004	0.015	mg/L	16-20821
WHS	W-4 Kitchen	8/4/16 7:26 AM	8/25/16	51014	LEAD	0.005	0.015	mg/L	16-20821
WHS	W-5 Kitchen KP	8/4/16 7:27 AM	8/25/16	51015	LEAD	ND	0.015	mg/L	16-20821
VCR	L G Shower 1	8/4/16 7:28 AM	8/26/16	51479	LEAD	0.007	0.015	mg/L	16-20851
WHS	W-6 Kitchen	8/4/16 7:28 AM	8/25/16	51016	LEAD	0.004	0.015	mg/L	16-20821
VCR	L G Shower 2	8/4/16 7:29 AM	8/26/16	51478	LEAD	0.021	0.015	mg/L	16-20851
WHS	W-7 Kitchen	8/4/16 7:29 AM	8/25/16	51017	LEAD	0.013	0.015	mg/L	16-20821
VCR	L G Shower 3	8/4/16 7:30 AM	8/30/16	51477	LEAD	0.274	0.015	mg/L	16-20851
WHS	W-8 Kitchen	8/4/16 7:30 AM	8/25/16	51018	LEAD	0.011	0.015	mg/L	16-20821

Lincoln Elementary School	F-6 Room#8	8/4/16 7:30 AM	8/22/16	49127	LEAD	0.056	0.015	mg/L	16-20213
WES	16 wes	8/4/16 7:30 AM	8/22/16	48448	LEAD	0.003	0.015	mg/L	16-19954
VCR	L G Shower 4	8/4/16 7:31 AM	8/26/16	51476	LEAD	0.024	0.015	mg/L	16-20851
WHS	W-9 Kitchen	8/4/16 7:31 AM	8/25/16	51019	LEAD	0.052	0.015	mg/L	16-20821
VCR	L G RR 1	8/4/16 7:32 AM	8/26/16	51473	LEAD	0.002	0.015	mg/L	16-20851
VCR	L G RR 3	8/4/16 7:33 AM	8/26/16	51472	LEAD	0.004	0.015	mg/L	16-20851
VCR	L G RR 2	8/4/16 7:33 AM	8/26/16	51474	LEAD	0.002	0.015	mg/L	16-20851
VCR	L G Coach Shower	8/4/16 7:34 AM	8/26/16	51470	LEAD	ND	0.015	mg/L	16-20851
WES	70 wes	8/4/16 7:34 AM	8/22/16	48449	LEAD	0.003	0.015	mg/L	16-19954
VCR	L G coach sink	8/4/16 7:35 AM	8/26/16	51471	LEAD	ND	0.015	mg/L	16-20851
FPMS	F1 Custodian office	8/4/16 7:35 AM	8/22/16	49174	LEAD	ND	0.015	mg/L	16-20214
Lincoln Elementary School	F7 Room #10	8/4/16 7:35 AM	8/22/16	49128	LEAD	0.013	0.015	mg/L	16-20213
VCR	L B Coach Shower	8/4/16 7:36 AM	8/26/16	51481	LEAD	0.003	0.015	mg/L	16-20851
WHS	W-10 Custodian Closet	8/4/16 7:36 AM	8/25/16	51020	LEAD	0.004	0.015	mg/L	16-20821
WES	31 wes	8/4/16 7:36 AM	8/22/16	48450	LEAD	0.003	0.015	mg/L	16-19954
VCR	L B Coach sink	8/4/16 7:37 AM	8/26/16	51483	LEAD	ND	0.015	mg/L	16-20851
WHS	W-11 Shower	8/4/16 7:37 AM	8/25/16	51021	LEAD	0.021	0.015	mg/L	16-20821
VCR	L B RR 1	8/4/16 7:38 AM	8/26/16	51482	LEAD	0.002	0.015	mg/L	16-20851
WHS	W-12 Sink	8/4/16 7:38 AM	8/25/16	51022	LEAD	0.002	0.015	mg/L	16-20821
VCR	L B RR 2	8/4/16 7:39 AM	8/26/16	51480	LEAD	0.001	0.015	mg/L	16-20851
VCR	L B RR 3	8/4/16 7:39 AM	8/26/16	51484	LEAD	0.001	0.015	mg/L	16-20851
WHS	W-13 Female Restroom	8/4/16 7:39 AM	8/25/16	51023	LEAD	0.005	0.015	mg/L	16-20821
Lincoln Elementary School	F8 Room #14	8/4/16 7:39 AM	8/22/16	49129	LEAD	0.034	0.015	mg/L	16-20213
Lincoln Elementary School	F9 Room #14	8/4/16 7:39 AM	8/22/16	49130	LEAD	0.279	0.015	mg/L	16-20213
WES	30 wes	8/4/16 7:39 AM	8/22/16	48451	LEAD	0.004	0.015	mg/L	16-19954
VCR	L B Shower 1	8/4/16 7:40 AM	8/26/16	51467	LEAD	0.096	0.015	mg/L	16-20851
WHS	W-14 Female Restroom	8/4/16 7:40 AM	8/25/16	51024	LEAD	0.005	0.015	mg/L	16-20821
VCR	L B Shower 2	8/4/16 7:41 AM	8/26/16	51468	LEAD	0.030	0.015	mg/L	16-20851
WHS	W-15 Female Restroom	8/4/16 7:41 AM	8/25/16	51025	LEAD	0.006	0.015	mg/L	16-20821
VCR	L B Shower 3	8/4/16 7:42 AM	8/30/16	51475	LEAD	0.590	0.015	mg/L	16-20851
WHS	W-16 Male Restroom	8/4/16 7:42 AM	8/25/16	51026	LEAD	0.004	0.015	mg/L	16-20821
VCR	L B Shower 4	8/4/16 7:43 AM	8/26/16	51469	LEAD	0.017	0.015	mg/L	16-20851
WHS	W-17 Male Restroom	8/4/16 7:43 AM	8/25/16	51027	LEAD	0.002	0.015	mg/L	16-20821
WES	29 wes	8/4/16 7:43 AM	8/22/16	48452	LEAD	0.009	0.015	mg/L	16-19954
WHS	W-18 Male Restroom	8/4/16 7:44 AM	8/25/16	51028	LEAD	0.002	0.015	mg/L	16-20821
VCR	VCR Band	8/4/16 7:45 AM	8/26/16	51545	LEAD	ND	0.015	mg/L	16-20851
FPMS	F2 Commons	8/4/16 7:45 AM	8/22/16	49175	LEAD	0.002	0.015	mg/L	16-20214
VCR	VC Band Hall	8/4/16 7:46 AM	8/26/16	51487	LEAD	ND	0.015	mg/L	16-20851
VCR	VRR Lobby G1	8/4/16 7:50 AM	8/26/16	51504	LEAD	0.001	0.015	mg/L	16-20851
WHS	W-19 Sci Lab RM 101	8/4/16 7:50 AM	8/25/16	51029	LEAD	0.007	0.015	mg/L	16-20821
FPMS	F3 Dish room	8/4/16 7:50 AM	8/22/16	49176	LEAD	0.002	0.015	mg/L	16-20214
FPMS	F4 Dish room	8/4/16 7:50 AM	8/22/16	49177	LEAD	0.003	0.015	mg/L	16-20214

VCR	VRR Lobby G2	8/4/16 7:51 AM	8/26/16	51495	LEAD	ND	0.015	mg/L	16-20851
WHS	W-20 Sci Lab RM 101	8/4/16 7:51 AM	8/25/16	51030	LEAD	0.008	0.015	mg/L	16-20821
WHS	W-21 Sci Lab RM 101	8/4/16 7:51 AM	8/25/16	51031	LEAD	0.002	0.015	mg/L	16-20821
VCR	VRR Lobby B1	8/4/16 7:52 AM	8/26/16	51505	LEAD	ND	0.015	mg/L	16-20851
WHS	W-22 Sci Lab RM 101	8/4/16 7:52 AM	8/25/16	51032	LEAD	0.026	0.015	mg/L	16-20821
FPMS	F5 Kitchen	8/4/16 7:52 AM	8/22/16	49178	LEAD	0.001	0.015	mg/L	16-20214
VCR	VRR Lobby B2	8/4/16 7:53 AM	8/26/16	51506	LEAD	ND	0.015	mg/L	16-20851
WHS	W-23 Sci Lab RM 101	8/4/16 7:53 AM	8/25/16	51033	LEAD	0.042	0.015	mg/L	16-20821
FPMS	F6 Kitchen	8/4/16 7:53 AM	8/22/16	49179	LEAD	0.002	0.015	mg/L	16-20214
VCR	V Office Health Rm	8/4/16 7:54 AM	8/26/16	51486	LEAD	ND	0.015	mg/L	16-20851
VCR	VCR A6	8/4/16 7:54 AM	8/26/16	51548	LEAD	0.001	0.015	mg/L	16-20851
WHS	W-24 Sci Lab RM 101	8/4/16 7:54 AM	8/25/16	51034	LEAD	ND	0.015	mg/L	16-20821
VCR	VCR A6 Office	8/4/16 7:55 AM	8/26/16	51549	LEAD	ND	0.015	mg/L	16-20851
WHS	W-25 Sci Lab RM 101	8/4/16 7:55 AM	8/25/16	51035	LEAD	0.014	0.015	mg/L	16-20821
FPMS	F7 FP Office	8/4/16 7:55 AM	8/22/16	49180	LEAD	0.006	0.015	mg/L	16-20214
WHS	W-26 Sci Lab RM 101	8/4/16 7:56 AM	8/25/16	51036	LEAD	0.004	0.015	mg/L	16-20821
FPMS	F8 Staff room	8/4/16 7:56 AM	8/22/16	49181	LEAD	ND	0.015	mg/L	16-20214
WHS	W-27 Sci Lab RM 101	8/4/16 7:57 AM	8/25/16	51037	LEAD	0.002	0.015	mg/L	16-20821
FPMS	F9 Staff room	8/4/16 7:57 AM	8/22/16	49182	LEAD	ND	0.015	mg/L	16-20214
WHS	W-28 Sci Lab RM 101	8/4/16 7:58 AM	8/25/16	51038	LEAD	0.014	0.015	mg/L	16-20821
WHS	W-29 Sci Lab RM 101	8/4/16 7:58 AM	8/25/16	51039	LEAD	0.003	0.015	mg/L	16-20821
FPMS	F10 Boile Rm	8/4/16 8:00 AM	8/22/16	49183	LEAD	0.022	0.015	mg/L	16-20214
VCR	VRR Workroom staff 1	8/4/16 8:02 AM	8/26/16	51500	LEAD	ND	0.015	mg/L	16-20851
VCR	VRR Work Rm Staff 2	8/4/16 8:03 AM	8/26/16	51496	LEAD	0.004	0.015	mg/L	16-20851
WHS	W-30 Sci Lab RM 102	8/4/16 8:04 AM	8/25/16	51040	LEAD	0.013	0.015	mg/L	16-20821
FPMS	F41 DO Kitchen	8/4/16 8:05 AM	8/22/16	49214	LEAD	0.005	0.015	mg/L	16-20214
WHS	W-31 Sci Lab RM 102	8/4/16 8:06 AM	8/25/16	51041	LEAD	0.015	0.015	mg/L	16-20821
WHS	W-32 Sci Lab RM 102	8/4/16 8:07 AM	8/25/16	51042	LEAD	0.018	0.015	mg/L	16-20821
WHS	W-33 Sci Lab RM 102	8/4/16 8:07 AM	8/25/16	51043	LEAD	0.009	0.015	mg/L	16-20821
FPMS	F42 DO Restroom 1	8/4/16 8:07 AM	8/22/16	49215	LEAD	0.013	0.015	mg/L	16-20214
WHS	W-34 Sci Lab RM 102	8/4/16 8:08 AM	8/25/16	51044	LEAD	0.010	0.015	mg/L	16-20821
FPMS	F43 DO Restroom 2	8/4/16 8:08 AM	8/22/16	49216	LEAD	0.007	0.015	mg/L	16-20214
WHS	W-35 Sci Lab RM 102	8/4/16 8:09 AM	8/25/16	51045	LEAD	0.001	0.015	mg/L	16-20821
Nellie	N26 S Outside D/Fountain	8/4/16 8:09 AM	8/25/16	50575	LEAD	0.005	0.015	mg/L	16-20664
WHS	W-36 Sci Lab RM 102	8/4/16 8:10 AM	8/25/16	51046	LEAD	0.003	0.015	mg/L	16-20821
Nellie	N27 S Outside Spicket	8/4/16 8:10 AM	8/25/16	50576	LEAD	0.002	0.015	mg/L	16-20664
WHS	W-37 Sci Lab RM 102	8/4/16 8:11 AM	8/25/16	51047	LEAD	0.003	0.015	mg/L	16-20821
WHS	W-38 Sci Lab RM 102	8/4/16 8:12 AM	8/25/16	51048	LEAD	0.001	0.015	mg/L	16-20821
WHS	W-39 Sci Lab RM 102	8/4/16 8:13 AM	8/25/16	51049	LEAD	0.003	0.015	mg/L	16-20821
WHS	W-40 Sci Lab RM 102	8/4/16 8:14 AM	8/25/16	51050	LEAD	ND	0.015	mg/L	16-20821
High School - AIS	AIS 1 R818	8/4/16 8:15 AM	8/26/16	51248	LEAD	ND	0.015	mg/L	16-20830
High School - AIS	AIS 2 R818	8/4/16 8:16 AM	8/26/16	51249	LEAD	ND	0.015	mg/L	16-20830

Nellie	N28 Kitchen Sprayer	8/4/16 8:16 AM	8/25/16	50577	LEAD	0.022	0.015	mg/L	16-20664
High School - AIS	AIS 3 R818	8/4/16 8:17 AM	8/26/16	51250	LEAD	0.002	0.015	mg/L	16-20830
High School - AIS	AIS 4 R818	8/4/16 8:17 AM	8/26/16	51251	LEAD	0.001	0.015	mg/L	16-20830
Nellie	N29 Handwash Sink	8/4/16 8:17 AM	8/25/16	50578	LEAD	0.013	0.015	mg/L	16-20664
Nellie	N30 Kitchen Floor Sink	8/4/16 8:18 AM	8/25/16	50579	LEAD	0.002	0.015	mg/L	16-20664
High School - AIS	AIS 5 R818	8/4/16 8:19 AM	8/26/16	51252	LEAD	ND	0.015	mg/L	16-20830
WHS	W-41 Sci Lab RM 103	8/4/16 8:19 AM	8/25/16	51051	LEAD	0.012	0.015	mg/L	16-20821
WHS	W-42 Sci Lab RM 103	8/4/16 8:19 AM	8/25/16	51052	LEAD	0.002	0.015	mg/L	16-20821
WHS	W-43 Sci Lab RM 103	8/4/16 8:20 AM	8/25/16	51053	LEAD	0.002	0.015	mg/L	16-20821
High School - AIS	AIS 6 R816	8/4/16 8:21 AM	8/26/16	51253	LEAD	ND	0.015	mg/L	16-20830
WHS	W-44 Sci Lab RM 103	8/4/16 8:21 AM	8/25/16	51054	LEAD	0.002	0.015	mg/L	16-20821
High School - AIS	AIS 7 R814	8/4/16 8:22 AM	8/26/16	51254	LEAD	ND	0.015	mg/L	16-20830
WHS	W-45 Sci Lab RM 103	8/4/16 8:22 AM	8/25/16	51055	LEAD	0.002	0.015	mg/L	16-20821
WHS	W-46 Sci Lab RM 103	8/4/16 8:23 AM	8/25/16	51056	LEAD	0.042	0.015	mg/L	16-20821
High School - AIS	AIS 8 Janitor Closet 1	8/4/16 8:24 AM	8/26/16	51255	LEAD	ND	0.015	mg/L	16-20830
Nellie	N31 Room 17 Water Faucet	8/4/16 8:24 AM	8/25/16	50580	LEAD	0.009	0.015	mg/L	16-20664
High School - AIS	AIS 9 Girls bath 1	8/4/16 8:26 AM	8/26/16	51256	LEAD	ND	0.015	mg/L	16-20830
WHS	W-47 WEBSS Office	8/4/16 8:26 AM	8/25/16	51057	LEAD	0.002	0.015	mg/L	16-20821
Nellie	N32 Staff Room w/Faucet	8/4/16 8:27 AM	8/25/16	50581	LEAD	0.006	0.015	mg/L	16-20664
WES	28 wes	8/4/16 8:27 AM	8/22/16	48453	LEAD	0.012	0.015	mg/L	16-19954
High School - AIS	AIS 10 Girls bath 1	8/4/16 8:28 AM	8/26/16	51257	LEAD	ND	0.015	mg/L	16-20830
WHS	W-48 Sci Lab RM 104	8/4/16 8:28 AM	8/25/16	51058	LEAD	0.003	0.015	mg/L	16-20821
High School - AIS	AIS 11 Girls bath 1	8/4/16 8:29 AM	8/26/16	51258	LEAD	ND	0.015	mg/L	16-20830
WHS	W-49 Sci Lab RM 104	8/4/16 8:29 AM	8/25/16	51059	LEAD	0.008	0.015	mg/L	16-20821
WES	69 wes	8/4/16 8:29 AM	8/22/16	48454	LEAD	0.005	0.015	mg/L	16-19954
WHS	W-50 Sci Lab RM 104	8/4/16 8:30 AM	8/25/16	51060	LEAD	0.039	0.015	mg/L	16-20821
Nellie	N33 Office Nurse Station Faucet	8/4/16 8:30 AM	8/25/16	50582	LEAD	0.004	0.015	mg/L	16-20664
Lincoln Elementary School	F10 Room #16	8/4/16 8:30 AM	8/22/16	49131	LEAD	0.056	0.015	mg/L	16-20213
WHS	W-51 Sci Lab RM 104	8/4/16 8:31 AM	8/25/16	51061	LEAD	0.003	0.015	mg/L	16-20821
High School - AIS	AIS 12 R801	8/4/16 8:32 AM	8/26/16	51259	LEAD	ND	0.015	mg/L	16-20830
WHS	W-52 Sci Lab RM 104	8/4/16 8:32 AM	8/25/16	51062	LEAD	0.262	0.015	mg/L	16-20821
WES	32 wes	8/4/16 8:32 AM	8/22/16	48455	LEAD	0.006	0.015	mg/L	16-19954
High School - AIS	AIS 13 R803	8/4/16 8:33 AM	8/26/16	51260	LEAD	ND	0.015	mg/L	16-20830
WHS	W-53 Sci Lab RM 105	8/4/16 8:34 AM	8/25/16	51063	LEAD	0.005	0.015	mg/L	16-20821
WES	33 wes	8/4/16 8:34 AM	8/22/16	48456	LEAD	0.013	0.015	mg/L	16-19954
WHS	W-54 Sci Lab RM 105	8/4/16 8:35 AM	8/25/16	51064	LEAD	0.017	0.015	mg/L	16-20821
High School - AIS	AIS 14 Boys bath 1	8/4/16 8:36 AM	8/26/16	51261	LEAD	ND	0.015	mg/L	16-20830
High School - AIS	AIS 15 Boys bath 1	8/4/16 8:36 AM	8/26/16	51262	LEAD	ND	0.015	mg/L	16-20830
High School - AIS	AIS 16 Boys bath 1	8/4/16 8:36 AM	8/26/16	51263	LEAD	ND	0.015	mg/L	16-20830
Lincoln Elementary School	F11 Room #18	8/4/16 8:36 AM	8/22/16	49132	LEAD	0.032	0.015	mg/L	16-20213
WHS	W-55 Sci Lab RM 105	8/4/16 8:37 AM	8/25/16	51065	LEAD	0.002	0.015	mg/L	16-20821
Nellie	N34 Kinder Custodial Closet	8/4/16 8:37 AM	8/25/16	50583	LEAD	0.006	0.015	mg/L	16-20664

FPMS	F44 Hall A Staff RR	8/4/16 8:37 AM	8/22/16	49217	LEAD	0.006	0.015	mg/L	16-20214
FPMS	F75 Hall A	8/4/16 8:39 AM	8/22/16	49248	LEAD	0.007	0.015	mg/L	16-20214
Lincoln Elementary School	F12 Room #19	8/4/16 8:39 AM	8/22/16	49133	LEAD	0.173	0.015	mg/L	16-20213
Lincoln Elementary School	F13 Room #19	8/4/16 8:39 AM	8/22/16	49134	LEAD	0.031	0.015	mg/L	16-20213
Nellie	N35 Handicap Restroom Sink	8/4/16 8:40 AM	8/25/16	50584	LEAD	ND	0.015	mg/L	16-20664
High School - AIS	AIS 17 Janitor Closet 2	8/4/16 8:41 AM	8/26/16	51264	LEAD	ND	0.015	mg/L	16-20830
Nellie	N36 Handicap Restroom Shower	8/4/16 8:41 AM	8/25/16	50585	LEAD	0.003	0.015	mg/L	16-20664
FPMS	F46 Hall A Boy RR	8/4/16 8:41 AM	8/22/16	49219	LEAD	0.004	0.015	mg/L	16-20214
FPMS	F47 Hall A Boy RR	8/4/16 8:41 AM	8/22/16	49220	LEAD	0.003	0.015	mg/L	16-20214
FPMS	F48 Hall A Boy RR	8/4/16 8:41 AM	8/22/16	49221	LEAD	0.005	0.015	mg/L	16-20214
WHS	W-56 Nurse Office	8/4/16 8:42 AM	8/25/16	51066	LEAD	0.004	0.015	mg/L	16-20821
WES	34 wes	8/4/16 8:42 AM	8/22/16	48457	LEAD	0.022	0.015	mg/L	16-19954
High School - AIS	AIS 18 R805	8/4/16 8:43 AM	8/26/16	51265	LEAD	ND	0.015	mg/L	16-20830
WHS	W-57 Nurse Office	8/4/16 8:43 AM	8/25/16	51067	LEAD	0.025	0.015	mg/L	16-20821
FPMS	F49 Hall A Custodial Closet	8/4/16 8:43 AM	8/22/16	49222	LEAD	0.004	0.015	mg/L	16-20214
Lincoln Elementary School	F14 Room #20	8/4/16 8:43 AM	8/22/16	49135	LEAD	0.029	0.015	mg/L	16-20213
VCR	VRR Life skills	8/4/16 8:44 AM	8/26/16	51494	LEAD	ND	0.015	mg/L	16-20851
High School - AIS	AIS 19 R807	8/4/16 8:44 AM	8/26/16	51266	LEAD	ND	0.015	mg/L	16-20830
Nellie	N37 Room 19 w/Faucet	8/4/16 8:44 AM	8/25/16	50586	LEAD	0.003	0.015	mg/L	16-20664
FPMS	F50 Hall Girl RR	8/4/16 8:44 AM	8/22/16	49223	LEAD	0.005	0.015	mg/L	16-20214
VCR	VCR 101	8/4/16 8:45 AM	8/26/16	51541	LEAD	ND	0.015	mg/L	16-20851
Nellie	N38 Room 18 w/Faucet	8/4/16 8:45 AM	8/24/16	50587	LEAD	0.014	0.015	mg/L	16-20664
WES	35 wes	8/4/16 8:45 AM	8/22/16	48438	LEAD	0.004	0.015	mg/L	16-19954
High School - AIS	AIS 20 R809	8/4/16 8:46 AM	8/26/16	51267	LEAD	ND	0.015	mg/L	16-20830
WHS	W-58 Bistro	8/4/16 8:46 AM	8/25/16	51068	LEAD	ND	0.015	mg/L	16-20821
FPMS	F71 Hall A Girls RR	8/4/16 8:46 AM	8/22/16	49244	LEAD	0.005	0.015	mg/L	16-20214
FPMS	F72 Hall A Girls RR	8/4/16 8:46 AM	8/22/16	49245	LEAD	0.008	0.015	mg/L	16-20214
Lincoln Elementary School	F15 Room #17	8/4/16 8:47 AM	8/22/16	49136	LEAD	0.012	0.015	mg/L	16-20213
WES	36 wes	8/4/16 8:47 AM	8/22/16	48439	LEAD	0.005	0.015	mg/L	16-19954
High School - AIS	AIS 21 Staffroom	8/4/16 8:48 AM	8/26/16	51268	LEAD	ND	0.015	mg/L	16-20830
VCR	VC Valor Downstairs	8/4/16 8:49 AM	8/26/16	51488	LEAD	ND	0.015	mg/L	16-20851
High School - AIS	AIS 22 Staff Bath	8/4/16 8:49 AM	8/26/16	51269	LEAD	ND	0.015	mg/L	16-20830
WHS	W-59 Male RR	8/4/16 8:50 AM	8/25/16	51069	LEAD	0.001	0.015	mg/L	16-20821
WHS	W-60 Male RR	8/4/16 8:50 AM	8/25/16	51070	LEAD	0.001	0.015	mg/L	16-20821
WES	40 wes	8/4/16 8:50 AM	8/22/16	48440	LEAD	0.008	0.015	mg/L	16-19954
VCR	VRR downstairs G1	8/4/16 8:51 AM	8/26/16	51497	LEAD	0.001	0.015	mg/L	16-20851
High School - AIS	AIS 23 Janitor Room 3	8/4/16 8:51 AM	8/26/16	51270	LEAD	ND	0.015	mg/L	16-20830
WHS	W-61 Male RR	8/4/16 8:51 AM	8/25/16	51071	LEAD	0.002	0.015	mg/L	16-20821
Nellie	N39 Outside Staff Room Spicket	8/4/16 8:51 AM	8/24/16	50588	LEAD	0.002	0.015	mg/L	16-20664
WES	41 wes	8/4/16 8:51 AM	8/22/16	48441	LEAD	0.003	0.015	mg/L	16-19954
VCR	VRR downstairs G2	8/4/16 8:52 AM	8/26/16	51501	LEAD	0.001	0.015	mg/L	16-20851
WHS	W-62 Male RR	8/4/16 8:52 AM	8/25/16	51072	LEAD	0.002	0.015	mg/L	16-20821

Nellie	N40 Outside Room 325 Spicket	8/4/16 8:52 AM	8/24/16	50589	LEAD	0.003	0.015	mg/L	16-20664
FPMS	F73 Room 6	8/4/16 8:52 AM	8/22/16	49246	LEAD	0.005	0.015	mg/L	16-20214
Lincoln Elementary School	F16 Room #15	8/4/16 8:52 AM	8/22/16	49137	LEAD	0.012	0.015	mg/L	16-20213
VCR	VRR Downstairs B1	8/4/16 8:53 AM	8/26/16	51499	LEAD	0.001	0.015	mg/L	16-20851
High School - AIS	AIS 26 Girls bath 2	8/4/16 8:53 AM	8/26/16	51273	LEAD	0.002	0.015	mg/L	16-20830
WHS	W-63 Female RR	8/4/16 8:53 AM	8/25/16	51073	LEAD	0.001	0.015	mg/L	16-20821
VCR	VRR Downstairs B2	8/4/16 8:54 AM	8/26/16	51503	LEAD	0.001	0.015	mg/L	16-20851
High School - AIS	AIS 25 Girls bath 2	8/4/16 8:54 AM	8/26/16	51272	LEAD	ND	0.015	mg/L	16-20830
WHS	W-64 Female RR	8/4/16 8:54 AM	8/25/16	51074	LEAD	0.001	0.015	mg/L	16-20821
WHS	W-65 Female RR	8/4/16 8:54 AM	8/25/16	51075	LEAD	ND	0.015	mg/L	16-20821
WES	70 wes	8/4/16 8:54 AM	8/22/16	48442	LEAD	0.006	0.015	mg/L	16-19954
VCR	VCR 103	8/4/16 8:55 AM	8/26/16	51543	LEAD	0.003	0.015	mg/L	16-20851
High School - AIS	AIS 24 Girls bath 2	8/4/16 8:55 AM	8/26/16	51271	LEAD	ND	0.015	mg/L	16-20830
WHS	W-66 Female RR	8/4/16 8:55 AM	8/25/16	51076	LEAD	ND	0.015	mg/L	16-20821
Nellie	N41 Room 3 w/Faucet	8/4/16 8:55 AM	8/24/16	50590	LEAD	0.009	0.015	mg/L	16-20664
FPMS	F45 Hall A	8/4/16 8:55 AM	8/22/16	49218	LEAD	0.003	0.015	mg/L	16-20214
FPMS	F74 Hall A	8/4/16 8:55 AM	8/22/16	49247	LEAD	0.003	0.015	mg/L	16-20214
VCR	VCR 105 S2	8/4/16 8:56 AM	8/26/16	51537	LEAD	0.001	0.015	mg/L	16-20851
VCR	VCR 105 S1	8/4/16 8:56 AM	8/26/16	51539	LEAD	ND	0.015	mg/L	16-20851
WES	37 wes	8/4/16 8:56 AM	8/22/16	48443	LEAD	0.004	0.015	mg/L	16-19954
VCR	VCR 105 S3	8/4/16 8:57 AM	8/26/16	51540	LEAD	0.002	0.015	mg/L	16-20851
Nellie	N42 Room 2 w/Faucet	8/4/16 8:57 AM	8/24/16	50591	LEAD	0.003	0.015	mg/L	16-20664
VCR	VCR 105 S4	8/4/16 8:58 AM	8/26/16	51538	LEAD	0.001	0.015	mg/L	16-20851
VCR	VCR 105 S5	8/4/16 8:59 AM	8/26/16	51546	LEAD	0.001	0.015	mg/L	16-20851
WHS	W-67 Custodian RM 411	8/4/16 8:59 AM	8/25/16	51077	LEAD	ND	0.015	mg/L	16-20821
WES	38 wes	8/4/16 8:59 AM	8/22/16	48444	LEAD	0.005	0.015	mg/L	16-19954
VCR	VRR Downstairs staff	8/4/16 9:00 AM	8/26/16	51498	LEAD	ND	0.015	mg/L	16-20851
Lincoln Elementary School	F17 Front Hallway boys both	8/4/16 9:00 AM	8/22/16	49138	LEAD	0.009	0.015	mg/L	16-20213
Lincoln Elementary School	F18 Front Hallway boys both	8/4/16 9:00 AM	8/22/16	49139	LEAD	0.005	0.015	mg/L	16-20213
Lincoln Elementary School	F19 Front Hallway boys both	8/4/16 9:00 AM	8/22/16	49140	LEAD	0.009	0.015	mg/L	16-20213
VCR	VCR 107 S1	8/4/16 9:01 AM	8/26/16	51552	LEAD	0.002	0.015	mg/L	16-20851
Nellie	N43 Room 5 w/Faucet	8/4/16 9:01 AM	8/24/16	50592	LEAD	0.008	0.015	mg/L	16-20664
VCR	VCR 107 S2	8/4/16 9:02 AM	8/26/16	51551	LEAD	0.002	0.015	mg/L	16-20851
WHS	W-68 Office Female RR	8/4/16 9:02 AM	8/25/16	51078	LEAD	0.002	0.015	mg/L	16-20821
Nellie	N44 Room 6 w/Faucet	8/4/16 9:02 AM	8/24/16	50593	LEAD	0.010	0.015	mg/L	16-20664
WES	39 wes	8/4/16 9:02 AM	8/22/16	48445	LEAD	0.005	0.015	mg/L	16-19954
VCR	VCR 109	8/4/16 9:03 AM	8/26/16	51550	LEAD	0.002	0.015	mg/L	16-20851
WHS	W-69 Office Female RR	8/4/16 9:03 AM	8/25/16	51079	LEAD	0.001	0.015	mg/L	16-20821
VCR	VCR 108	8/4/16 9:04 AM	8/26/16	51547	LEAD	0.002	0.015	mg/L	16-20851
WHS	W-70 Office Male RR	8/4/16 9:04 AM	8/25/16	51080	LEAD	0.001	0.015	mg/L	16-20821
Lincoln Elementary School	F20 Cost. Closet	8/4/16 9:04 AM	8/22/16	49141	LEAD	0.007	0.015	mg/L	16-20213
VCR	VCR 106	8/4/16 9:05 AM	8/26/16	51542	LEAD	0.002	0.015	mg/L	16-20851

Nellie	N45 Room 7 Faucet	8/4/16 9:05 AM	8/24/16	50594	LEAD	0.010	0.015	mg/L	16-20664
VCR	VCR 104 S1	8/4/16 9:06 AM	8/26/16	51513	LEAD	0.004	0.015	mg/L	16-20851
Nellie	N46 Room 7-A Faucet	8/4/16 9:06 AM	8/24/16	50595	LEAD	0.004	0.015	mg/L	16-20664
VCR	VCR 104 S6	8/4/16 9:08 AM	8/26/16	51512	LEAD	0.001	0.015	mg/L	16-20851
VCR	VCR 104 S5	8/4/16 9:08 AM	8/26/16	51524	LEAD	0.018	0.015	mg/L	16-20851
Lincoln Elementary School	F21 Front Hallway Grils both	8/4/16 9:08 AM	8/22/16	49142	LEAD	0.003	0.015	mg/L	16-20213
Lincoln Elementary School	F22 Front Hallway Grils both	8/4/16 9:08 AM	8/22/16	49143	LEAD	0.006	0.015	mg/L	16-20213
Lincoln Elementary School	F23 Front Hallway Grils both	8/4/16 9:08 AM	8/22/16	49144	LEAD	0.002	0.015	mg/L	16-20213
VCR	VCR 104 S7	8/4/16 9:09 AM	8/26/16	51521	LEAD	0.001	0.015	mg/L	16-20851
VCR	VCR 104 S8	8/4/16 9:10 AM	8/26/16	51520	LEAD	ND	0.015	mg/L	16-20851
WHS	W-71 Staff Art Male RR	8/4/16 9:10 AM	8/25/16	51081	LEAD	0.001	0.015	mg/L	16-20821
Nellie	N47 Library Hall Custodial Closet	8/4/16 9:10 AM	8/24/16	50596	LEAD	0.004	0.015	mg/L	16-20664
VCR	VC V upstairs	8/4/16 9:11 AM	8/26/16	51489	LEAD	0.003	0.015	mg/L	16-20851
High School - AIS	AIS 27 R814	8/4/16 9:11 AM	8/26/16	51274	LEAD	ND	0.015	mg/L	16-20830
Nellie	N48 Library back room Faucet	8/4/16 9:11 AM	8/24/16	50597	LEAD	0.016	0.015	mg/L	16-20664
WES	42 wes	8/4/16 9:11 AM	8/22/16	48446	LEAD	0.074	0.015	mg/L	16-19954
High School - AIS	AIS 28 R811	8/4/16 9:12 AM	8/26/16	51275	LEAD	ND	0.015	mg/L	16-20830
WHS	W-72 Art Male RR	8/4/16 9:12 AM	8/25/16	51082	LEAD	0.003	0.015	mg/L	16-20821
WHS	W-73 Art Male RR	8/4/16 9:12 AM	8/25/16	51083	LEAD	0.003	0.015	mg/L	16-20821
VCR	VRR Upstairs G1	8/4/16 9:13 AM	8/26/16	51508	LEAD	0.001	0.015	mg/L	16-20851
VCR	VCR 211	8/4/16 9:13 AM	8/26/16	51531	LEAD	0.002	0.015	mg/L	16-20851
High School - AIS	AIS 29 R811	8/4/16 9:13 AM	8/26/16	51276	LEAD	ND	0.015	mg/L	16-20830
WHS	W-74 Art Male RR	8/4/16 9:13 AM	8/25/16	51084	LEAD	0.004	0.015	mg/L	16-20821
WES	43 wes	8/4/16 9:13 AM	8/22/16	48447	LEAD	0.016	0.015	mg/L	16-19954
VCR	VRR Upstairs G2	8/4/16 9:14 AM	8/26/16	51507	LEAD	0.001	0.015	mg/L	16-20851
High School - AIS	AIS 30 R811	8/4/16 9:14 AM	8/26/16	51277	LEAD	ND	0.015	mg/L	16-20830
WHS	W-75 Art Male RR	8/4/16 9:14 AM	8/25/16	51085	LEAD	0.004	0.015	mg/L	16-20821
VCR	VRR Upstairs B1	8/4/16 9:15 AM	8/26/16	51509	LEAD	ND	0.015	mg/L	16-20851
WHS	W-76 Staff Art Female RR	8/4/16 9:15 AM	8/25/16	51086	LEAD	0.004	0.015	mg/L	16-20821
Nellie	N49 Room 9 w/Faucet	8/4/16 9:15 AM	8/24/16	50598	LEAD	0.016	0.015	mg/L	16-20664
VCR	VRR Upstairs B2	8/4/16 9:16 AM	8/26/16	51502	LEAD	0.001	0.015	mg/L	16-20851
High School - AIS	AIS 31 R811	8/4/16 9:16 AM	8/26/16	51278	LEAD	ND	0.015	mg/L	16-20830
High School - AIS	AIS 32 R812	8/4/16 9:16 AM	8/26/16	51279	LEAD	ND	0.015	mg/L	16-20830
WES	44 wes	8/4/16 9:16 AM	8/22/16	48458	LEAD	0.014	0.015	mg/L	16-19954
VCR	VCR 208	8/4/16 9:17 AM	8/26/16	51517	LEAD	0.002	0.015	mg/L	16-20851
VCR	VCR 206	8/4/16 9:17 AM	8/26/16	51522	LEAD	ND	0.015	mg/L	16-20851
WHS	W-77 Art Female RR	8/4/16 9:17 AM	8/25/16	51087	LEAD	0.006	0.015	mg/L	16-20821
Nellie	N50 Room 10 Faucet	8/4/16 9:17 AM	8/24/16	50599	LEAD	0.005	0.015	mg/L	16-20664
VCR	VCR 210	8/4/16 9:18 AM	8/26/16	51527	LEAD	ND	0.015	mg/L	16-20851
WHS	W-78 Art Female RR	8/4/16 9:18 AM	8/25/16	51088	LEAD	0.002	0.015	mg/L	16-20821
WHS	W-79 Art Female RR	8/4/16 9:18 AM	8/25/16	51089	LEAD	0.005	0.015	mg/L	16-20821
Lincoln Elementary School	F24 Back hallway Girls both	8/4/16 9:18 AM	8/22/16	49145	LEAD	0.03	0.015	mg/L	16-20213

Lincoln Elementary School	F25 Back hallway Girls both	8/4/16 9:18 AM	8/22/16	49146	LEAD	0.003	0.015	mg/L	16-20213
Lincoln Elementary School	F26 Back hallway Girls both	8/4/16 9:18 AM	8/22/16	49147	LEAD	0.003	0.015	mg/L	16-20213
VCR	VRR Upstairs Staff	8/4/16 9:19 AM	8/26/16	51510	LEAD	ND	0.015	mg/L	16-20851
WHS	W-80 Art Female RR	8/4/16 9:19 AM	8/25/16	51090	LEAD	0.002	0.015	mg/L	16-20821
VCR	V Core Upstairs sink	8/4/16 9:20 AM	8/26/16	51485	LEAD	0.002	0.015	mg/L	16-20851
High School - AIS	AIS 33 R812	8/4/16 9:20 AM	8/26/16	51280	LEAD	ND	0.015	mg/L	16-20830
High School - AIS	AIS 34 R812	8/4/16 9:20 AM	8/26/16	51281	LEAD	ND	0.015	mg/L	16-20830
Nellie	N51 Room 11 Faucet	8/4/16 9:20 AM	8/24/16	50600	LEAD	0.004	0.015	mg/L	16-20664
High School - AIS	AIS 35 R812	8/4/16 9:21 AM	8/26/16	51282	LEAD	ND	0.015	mg/L	16-20830
Nellie	N52 Room 13 Faucet	8/4/16 9:21 AM	8/24/16	50601	LEAD	0.032	0.015	mg/L	16-20664
WES	45 wes	8/4/16 9:21 AM	8/22/16	48459	LEAD	0.007	0.015	mg/L	16-19954
VCR	VCR 212	8/4/16 9:22 AM	8/26/16	51535	LEAD	0.003	0.015	mg/L	16-20851
High School - AIS	AIS 36 R812	8/4/16 9:22 AM	8/26/16	51283	LEAD	ND	0.015	mg/L	16-20830
WHS	W-81 Art Custodian Closet	8/4/16 9:22 AM	8/25/16	51091	LEAD	ND	0.015	mg/L	16-20821
Nellie	N53 Room 12 Faucet	8/4/16 9:22 AM	8/24/16	50602	LEAD	0.015	0.015	mg/L	16-20664
Lincoln Elementary School	F27 Cost. Closet retime	8/4/16 9:22 AM	8/22/16	49148	LEAD	0.008	0.015	mg/L	16-20213
Lincoln Elementary School	F28 Cost. Closet retime	8/4/16 9:22 AM	8/22/16	49149	LEAD	0.008	0.015	mg/L	16-20213
FPMS	F76 Room 4	8/4/16 9:23 AM	8/22/16	49249	LEAD	0.002	0.015	mg/L	16-20214
VCR	VCR 209	8/4/16 9:24 AM	8/26/16	51514	LEAD	0.069	0.015	mg/L	16-20851
High School - AIS	AIS 37 Boys bath 2	8/4/16 9:24 AM	8/26/16	51284	LEAD	0.002	0.015	mg/L	16-20830
WES	46 wes	8/4/16 9:24 AM	8/22/16	48460	LEAD	0.021	0.015	mg/L	16-19954
VCR	VCR 207	8/4/16 9:25 AM	8/26/16	51516	LEAD	0.002	0.015	mg/L	16-20851
High School - AIS	AIS 38 Boys bath 2	8/4/16 9:25 AM	8/26/16	51285	LEAD	0.001	0.015	mg/L	16-20830
WHS	W-82 Art RM 510	8/4/16 9:25 AM	8/25/16	51092	LEAD	ND	0.015	mg/L	16-20821
WHS	W-83 Art RM 510	8/4/16 9:25 AM	8/25/16	51093	LEAD	ND	0.015	mg/L	16-20821
FPMS	F77 Room 4	8/4/16 9:25 AM	8/22/16	49250	LEAD	0.002	0.015	mg/L	16-20214
VCR	VCR 205 S1	8/4/16 9:26 AM	8/26/16	51533	LEAD	0.010	0.015	mg/L	16-20851
High School - AIS	AIS 39 Boys bath 2	8/4/16 9:26 AM	8/26/16	51286	LEAD	0.002	0.015	mg/L	16-20830
VCR	VCR 205 S2	8/4/16 9:27 AM	8/26/16	51534	LEAD	0.001	0.015	mg/L	16-20851
High School - AIS	AIS 40 Break Room	8/4/16 9:27 AM	8/26/16	51287	LEAD	ND	0.015	mg/L	16-20830
VCR	VCR 205 S3	8/4/16 9:28 AM	8/26/16	51536	LEAD	ND	0.015	mg/L	16-20851
High School - AIS	AIS 41 R810	8/4/16 9:28 AM	8/26/16	51288	LEAD	ND	0.015	mg/L	16-20830
WHS	W-84 Art RM 513	8/4/16 9:28 AM	8/25/16	51094	LEAD	ND	0.015	mg/L	16-20821
WHS	W-85 Art RM 513	8/4/16 9:28 AM	8/25/16	51095	LEAD	ND	0.015	mg/L	16-20821
WES	47 wes	8/4/16 9:28 AM	8/22/16	48461	LEAD	0.007	0.015	mg/L	16-19954
VCR	VCR 205 S4	8/4/16 9:29 AM	8/26/16	51532	LEAD	0.003	0.015	mg/L	16-20851
High School - AIS	AIS 42 Multipurpose	8/4/16 9:29 AM	8/26/16	51289	LEAD	0.001	0.015	mg/L	16-20830
WHS	W-86 Art RM 513	8/4/16 9:29 AM	8/25/16	51096	LEAD	ND	0.015	mg/L	16-20821
VCR	VCR 205 S5	8/4/16 9:30 AM	8/26/16	51529	LEAD	0.002	0.015	mg/L	16-20851
WHS	W-87 Art RM 515	8/4/16 9:30 AM	8/25/16	51097	LEAD	ND	0.015	mg/L	16-20821
WES	48 wes	8/4/16 9:30 AM	8/22/16	48462	LEAD	0.009	0.015	mg/L	16-19954
VCR	VCR 205 S6	8/4/16 9:31 AM	8/26/16	51526	LEAD	0.001	0.015	mg/L	16-20851

WHS	W-88 Stage	8/4/16 9:31 AM	8/25/16	51098	LEAD	0.002	0.015	mg/L	16-20821
VCR	VCR 205 S7	8/4/16 9:32 AM	8/26/16	51525	LEAD	0.003	0.015	mg/L	16-20851
VCR	VCR 205 S8	8/4/16 9:33 AM	8/26/16	51515	LEAD	0.001	0.015	mg/L	16-20851
High School - AIS	AIS 43 Girls bath 3	8/4/16 9:33 AM	8/26/16	51290	LEAD	ND	0.015	mg/L	16-20830
WES	49 wes	8/4/16 9:33 AM	8/22/16	48463	LEAD	0.085	0.015	mg/L	16-19954
High School - AIS	AIS 44 Girls bath 3	8/4/16 9:34 AM	8/26/16	51291	LEAD	ND	0.015	mg/L	16-20830
High School - AIS	AIS 45 Girls bath 3	8/4/16 9:34 AM	8/26/16	51292	LEAD	ND	0.015	mg/L	16-20830
Nellie	N54 Room 14 Faucet	8/4/16 9:35 AM	8/24/16	50603	LEAD	0.007	0.015	mg/L	16-20664
Lincoln Elementary School	F29 Back hallway Boys both	8/4/16 9:35 AM	8/22/16	49150	LEAD	0.022	0.015	mg/L	16-20213
Lincoln Elementary School	F30 Back hallway Boys both	8/4/16 9:35 AM	8/22/16	49151	LEAD	0.003	0.015	mg/L	16-20213
VCR	VCR 204	8/4/16 9:36 AM	8/26/16	51530	LEAD	ND	0.015	mg/L	16-20851
High School - AIS	AIS 46 R804	8/4/16 9:36 AM	8/26/16	51293	LEAD	ND	0.015	mg/L	16-20830
Nellie	N55 Room 15 Faucet	8/4/16 9:36 AM	8/24/16	50604	LEAD	0.011	0.015	mg/L	16-20664
WES	50 wes	8/4/16 9:36 AM	8/22/16	48464	LEAD	0.045	0.015	mg/L	16-19954
VCR	VCR 203	8/4/16 9:37 AM	8/26/16	51528	LEAD	0.002	0.015	mg/L	16-20851
VCR	VCR 201	8/4/16 9:38 AM	8/26/16	51511	LEAD	0.011	0.015	mg/L	16-20851
High School - AIS	AIS 47 R802	8/4/16 9:38 AM	8/26/16	51294	LEAD	ND	0.015	mg/L	16-20830
Nellie	N56 East Courtyard	8/4/16 9:38 AM	8/24/16	50605	LEAD	0.003	0.015	mg/L	16-20664
High School - AIS	AIS 49 Boys bath 3	8/4/16 9:40 AM	8/26/16	51296	LEAD	ND	0.015	mg/L	16-20830
WHS	W-89 WEBSS Workroom LNG	8/4/16 9:40 AM	8/25/16	51099	LEAD	0.002	0.015	mg/L	16-20821
Lincoln Elementary School	F31 Room 29	8/4/16 9:40 AM	8/22/16	49152	LEAD	0.025	0.015	mg/L	16-20213
WES	51 wes	8/4/16 9:40 AM	8/22/16	48465	LEAD	0.002	0.015	mg/L	16-19954
High School - AIS	AIS 48 Boys bath 3	8/4/16 9:41 AM	8/26/16	51295	LEAD	ND	0.015	mg/L	16-20830
Nellie	N57 West Courtyard	8/4/16 9:41 AM	8/24/16	50606	LEAD	0.008	0.015	mg/L	16-20664
High School - AIS	AIS 50 Staff Bath	8/4/16 9:42 AM	8/26/16	51297	LEAD	ND	0.015	mg/L	16-20830
WES	52 wes	8/4/16 9:42 AM	8/22/16	48466	LEAD	0.003	0.015	mg/L	16-19954
High School - AIS	AIS 51 R813	8/4/16 9:43 AM	8/26/16	51298	LEAD	ND	0.015	mg/L	16-20830
WHS	W-90 WEBSS Workroom RR	8/4/16 9:43 AM	8/25/16	51100	LEAD	0.002	0.015	mg/L	16-20821
Nellie	N58 Custodial Office	8/4/16 9:43 AM	8/24/16	50607	LEAD	0.001	0.015	mg/L	16-20664
WES	53 wes	8/4/16 9:43 AM	8/22/16	48467	LEAD	0.004	0.015	mg/L	16-19954
WHS	W-91 WEBSS Workroom RR	8/4/16 9:44 AM	8/25/16	51101	LEAD	0.003	0.015	mg/L	16-20821
Heritage	C Annex W	8/4/16 9:45 AM	8/26/16	51426	LEAD	ND	0.015	mg/L	16-20838
High School - AIS	AIS 52 R815	8/4/16 9:45 AM	8/26/16	51299	LEAD	ND	0.015	mg/L	16-20830
Heritage	HARR WB1	8/4/16 9:46 AM	8/26/16	51383	LEAD	ND	0.015	mg/L	16-20838
VCR	VCR Library Office	8/4/16 9:47 AM	8/26/16	51544	LEAD	0.002	0.015	mg/L	16-20851
Heritage	HARR WB2	8/4/16 9:47 AM	8/26/16	51381	LEAD	0.001	0.015	mg/L	16-20838
High School - AIS	AIS 53 R817	8/4/16 9:47 AM	8/26/16	51300	LEAD	ND	0.015	mg/L	16-20830
WES	54 wes	8/4/16 9:47 AM	8/22/16	48428	LEAD	0.004	0.015	mg/L	16-19954
Heritage	HARR WG1	8/4/16 9:48 AM	8/26/16	51370	LEAD	ND	0.015	mg/L	16-20838
Heritage	HARR WB3	8/4/16 9:48 AM	8/26/16	51382	LEAD	0.001	0.015	mg/L	16-20838
Heritage	HARR WG2	8/4/16 9:49 AM	8/26/16	51384	LEAD	ND	0.015	mg/L	16-20838
WES	71 wes	8/4/16 9:49 AM	8/22/16	48429	LEAD	0.003	0.015	mg/L	16-19954

Heritage	HARR WG3	8/4/16 9:50 AM	8/26/16	51368	LEAD	ND	0.015	mg/L	16-20838
Heritage	C Annex E	8/4/16 9:51 AM	8/26/16	51427	LEAD	ND	0.015	mg/L	16-20838
FPMS	F78 Room 16	8/4/16 9:51 AM	8/22/16	49251	LEAD	0.006	0.015	mg/L	16-20214
Heritage	HARR EG1	8/4/16 9:52 AM	8/26/16	51369	LEAD	ND	0.015	mg/L	16-20838
WES	55 wes	8/4/16 9:52 AM	8/22/16	48430	LEAD	0.002	0.015	mg/L	16-19954
Heritage	HARR EG3	8/4/16 9:53 AM	8/26/16	51366	LEAD	ND	0.015	mg/L	16-20838
Heritage	HARR EG2	8/4/16 9:53 AM	8/26/16	51367	LEAD	ND	0.015	mg/L	16-20838
Lincoln Elementary School	F32 Room 32	8/4/16 9:53 AM	8/22/16	49153	LEAD	0.036	0.015	mg/L	16-20213
Heritage	HARR EB1	8/4/16 9:54 AM	8/26/16	51365	LEAD	ND	0.015	mg/L	16-20838
FPMS	F79 Hall B girl R/R	8/4/16 9:54 AM	8/22/16	49252	LEAD	0.004	0.015	mg/L	16-20214
FPMS	F80 Hall B girl R/R	8/4/16 9:54 AM	8/22/16	49253	LEAD	0.005	0.015	mg/L	16-20214
WES	56 wes	8/4/16 9:54 AM	8/22/16	48431	LEAD	0.002	0.015	mg/L	16-19954
Heritage	HARR EB2	8/4/16 9:55 AM	8/26/16	51379	LEAD	ND	0.015	mg/L	16-20838
FPMS	F81 Hall B girl R/R	8/4/16 9:55 AM	8/22/16	49254	LEAD	0.005	0.015	mg/L	16-20214
WES	57 wes	8/4/16 9:55 AM	8/22/16	48432	LEAD	0.002	0.015	mg/L	16-19954
VCR	VCR 104 S2	8/4/16 9:56 AM	8/26/16	51519	LEAD	0.001	0.015	mg/L	16-20851
Heritage	HARR Staff 1	8/4/16 9:56 AM	8/26/16	51371	LEAD	ND	0.015	mg/L	16-20838
Heritage	HARR EB3	8/4/16 9:56 AM	8/26/16	51380	LEAD	ND	0.015	mg/L	16-20838
VCR	VCR 104 S3	8/4/16 9:57 AM	8/26/16	51518	LEAD	0.002	0.015	mg/L	16-20851
VCR	VCR 104 S4	8/4/16 9:57 AM	8/26/16	51523	LEAD	0.016	0.015	mg/L	16-20851
Heritage	HARR Staff 2	8/4/16 9:57 AM	8/26/16	51372	LEAD	ND	0.015	mg/L	16-20838
WES	58 wes	8/4/16 9:58 AM	8/22/16	48433	LEAD	0.010	0.015	mg/L	16-19954
FPMS	F82 Hall B boy R/R	8/4/16 9:59 AM	8/22/16	49255	LEAD	0.003	0.015	mg/L	16-20214
FPMS	F83 Hall B boy R/R	8/4/16 9:59 AM	8/22/16	49256	LEAD	0.002	0.015	mg/L	16-20214
FPMS	F84 Hall B boy R/R	8/4/16 9:59 AM	8/22/16	49257	LEAD	0.002	0.015	mg/L	16-20214
FPMS	F90 Gym	8/4/16 10:00 AM	8/22/16	49263	LEAD	0.002	0.015	mg/L	16-20214
WES	78 wes	8/4/16 10:00 AM	8/22/16	48414	LEAD	0.005	0.015	mg/L	16-19954
WES	79 wes	8/4/16 10:00 AM	8/22/16	48415	LEAD	0.008	0.015	mg/L	16-19954
WES	59 wes	8/4/16 10:01 AM	8/22/16	48434	LEAD	0.122	0.015	mg/L	16-19954
FPMS	F85 Hall B	8/4/16 10:04 AM	8/22/16	49258	LEAD	0.003	0.015	mg/L	16-20214
WES	76 wes	8/4/16 10:04 AM	8/22/16	48412	LEAD	0.026	0.015	mg/L	16-19954
Lincoln Elementary School	F33 Kitchen	8/4/16 10:05 AM	8/22/16	49154	LEAD	0.003	0.015	mg/L	16-20213
Lincoln Elementary School	F34 Kitchen	8/4/16 10:05 AM	8/22/16	49155	LEAD	0.003	0.015	mg/L	16-20213
Lincoln Elementary School	F35 Kitchen	8/4/16 10:05 AM	8/22/16	49156	LEAD	0.016	0.015	mg/L	16-20213
Lincoln Elementary School	F36 Kitchen	8/4/16 10:05 AM	8/22/16	49157	LEAD	0.005	0.015	mg/L	16-20213
WES	60 wes	8/4/16 10:05 AM	8/22/16	48435	LEAD	0.004	0.015	mg/L	16-19954
FPMS	F86 Hall B	8/4/16 10:06 AM	8/22/16	49259	LEAD	0.003	0.015	mg/L	16-20214
FPMS	F87 Custodic closet hall B	8/4/16 10:07 AM	8/22/16	49260	LEAD	0.004	0.015	mg/L	16-20214
WES	77 wes	8/4/16 10:08 AM	8/22/16	48413	LEAD	0.099	0.015	mg/L	16-19954
FPMS	F88 Gym	8/4/16 10:09 AM	8/22/16	49261	LEAD	0.005	0.015	mg/L	16-20214
FPMS	F89 Gym	8/4/16 10:09 AM	8/22/16	49262	LEAD	0.004	0.015	mg/L	16-20214
FPMS	F61 Gym	8/4/16 10:10 AM	8/22/16	49234	LEAD	0.002	0.015	mg/L	16-20214

Lincoln Elementary School	F37 Outside kitchen	8/4/16 10:10 AM	8/22/16	49158	LEAD	0.006	0.015	mg/L	16-20213
Heritage	HACR Rm 34	8/4/16 10:15 AM	8/26/16	51393	LEAD	0.002	0.015	mg/L	16-20838
Lincoln Elementary School	F38 Laundry	8/4/16 10:15 AM	8/22/16	49159	LEAD	ND	0.015	mg/L	16-20213
Heritage	HACR Rm 35	8/4/16 10:16 AM	8/26/16	51387	LEAD	0.002	0.015	mg/L	16-20838
Heritage	HACR Rm 36	8/4/16 10:17 AM	8/26/16	51377	LEAD	0.002	0.015	mg/L	16-20838
Heritage	HACR Rm 37	8/4/16 10:18 AM	8/26/16	51391	LEAD	0.002	0.015	mg/L	16-20838
WHS	W-92 Male RR	8/4/16 10:18 AM	8/25/16	51102	LEAD	0.006	0.015	mg/L	16-20821
FPMS	F62 Coach RR Girls	8/4/16 10:18 AM	8/22/16	49235	LEAD	0.014	0.015	mg/L	16-20214
Heritage	HACR Rm 38	8/4/16 10:19 AM	8/26/16	51375	LEAD	0.002	0.015	mg/L	16-20838
WHS	W-93 Male RR	8/4/16 10:19 AM	8/25/16	51103	LEAD	0.006	0.015	mg/L	16-20821
Heritage	HACR Rm 39	8/4/16 10:20 AM	8/26/16	51376	LEAD	0.002	0.015	mg/L	16-20838
WHS	W-94 Male RR	8/4/16 10:20 AM	8/25/16	51104	LEAD	0.006	0.015	mg/L	16-20821
FPMS	F15 Hall C	8/4/16 10:20 AM	8/22/16	49188	LEAD	0.002	0.015	mg/L	16-20214
FPMS	F63 Girl Locker RM	8/4/16 10:20 AM	8/22/16	49236	LEAD	0.001	0.015	mg/L	16-20214
FPMS	F64 Girl Locker RM	8/4/16 10:20 AM	8/22/16	49237	LEAD	0.003	0.015	mg/L	16-20214
Lincoln Elementary School	F39 Garden	8/4/16 10:20 AM	8/22/16	49160	LEAD	ND	0.015	mg/L	16-20213
Heritage	HACR Rm 41	8/4/16 10:21 AM	8/26/16	51386	LEAD	0.004	0.015	mg/L	16-20838
WHS	W-95 Female RR	8/4/16 10:21 AM	8/25/16	51105	LEAD	0.003	0.015	mg/L	16-20821
WHS	W-96 Female RR	8/4/16 10:21 AM	8/25/16	51106	LEAD	0.003	0.015	mg/L	16-20821
Heritage	HACR Rm 42	8/4/16 10:22 AM	8/26/16	51390	LEAD	0.002	0.015	mg/L	16-20838
WHS	W-97 Female RR	8/4/16 10:22 AM	8/25/16	51107	LEAD	0.011	0.015	mg/L	16-20821
Heritage	HACR Rm 44	8/4/16 10:23 AM	8/26/16	51385	LEAD	0.002	0.015	mg/L	16-20838
Heritage	HACR Rm 43	8/4/16 10:24 AM	8/26/16	51392	LEAD	0.002	0.015	mg/L	16-20838
Heritage	HACR Rm 45	8/4/16 10:25 AM	8/26/16	51394	LEAD	0.002	0.015	mg/L	16-20838
Heritage	HACR Rm 46	8/4/16 10:26 AM	8/26/16	51389	LEAD	0.002	0.015	mg/L	16-20838
WHS	W-98 Gym Custodian 729	8/4/16 10:26 AM	8/25/16	51108	LEAD	0.001	0.015	mg/L	16-20821
Heritage	HACR Rm 47	8/4/16 10:27 AM	8/26/16	51378	LEAD	0.002	0.015	mg/L	16-20838
Heritage	HACR Rm 48	8/4/16 10:28 AM	8/26/16	51388	LEAD	0.003	0.015	mg/L	16-20838
High School - AIS	AIS EXT 54 East ext hose BIB	8/4/16 10:28 AM	8/26/16	51301	LEAD	ND	0.015	mg/L	16-20830
High School - AIS	AIS EXT 55 West ext hose BIB	8/4/16 10:29 AM	8/26/16	51302	LEAD	ND	0.015	mg/L	16-20830
WHS	W-99 Gym Ice Machine 728	8/4/16 10:30 AM	8/25/16	51109	LEAD	0.002	0.015	mg/L	16-20821
FPMS	F65 Girl Shower RM	8/4/16 10:30 AM	8/22/16	49238	LEAD	0.026	0.015	mg/L	16-20214
FPMS	F66 Girl Shower RM	8/4/16 10:30 AM	8/22/16	49239	LEAD	0.042	0.015	mg/L	16-20214
FPMS	F67 Girl Shower RM	8/4/16 10:30 AM	8/22/16	49240	LEAD	0.011	0.015	mg/L	16-20214
WES	61 wes	8/4/16 10:31 AM	8/22/16	48436	LEAD	0.003	0.015	mg/L	16-19954
FPMS	F68 Girl Shower RM	8/4/16 10:32 AM	8/22/16	49241	LEAD	0.067	0.015	mg/L	16-20214
FPMS	F69 Girl Shower RM	8/4/16 10:32 AM	8/22/16	49242	LEAD	0.066	0.015	mg/L	16-20214
FPMS	F70 Girl Shower RM	8/4/16 10:32 AM	8/22/16	49243	LEAD	0.052	0.015	mg/L	16-20214
WHS	W-100 Staff Sink 701	8/4/16 10:33 AM	8/25/16	51110	LEAD	0.006	0.015	mg/L	16-20821
High School - AIS	AIS EXT 56 North ext hose BIB	8/4/16 10:34 AM	8/26/16	51303	LEAD	0.001	0.015	mg/L	16-20830
FPMS	F51 Girl Shower RM	8/4/16 10:34 AM	8/22/16	49224	LEAD	0.013	0.015	mg/L	16-20214
FPMS	F52 Girl Shower RM	8/4/16 10:34 AM	8/22/16	49225	LEAD	0.015	0.015	mg/L	16-20214

FPMS	F53 Girl Shower RM	8/4/16 10:34 AM	8/22/16	49226	LEAD	0.022	0.015	mg/L	16-20214
WHS	W-101 Staff Shower 701	8/4/16 10:35 AM	8/25/16	51111	LEAD	0.005	0.015	mg/L	16-20821
FPMS	F92 girl shower locker	8/4/16 10:35 AM	8/22/16	49265	LEAD	0.035	0.015	mg/L	16-20214
WES	62 wes	8/4/16 10:35 AM	8/22/16	48437	LEAD	0.013	0.015	mg/L	16-19954
High School - AIS	AIS EXT 57 South ext hose BIB	8/4/16 10:36 AM	8/26/16	51304	LEAD	ND	0.015	mg/L	16-20830
WHS	W-103 Girls LKRM Sink	8/4/16 10:36 AM	8/25/16	51113	LEAD	0.006	0.015	mg/L	16-20821
WHS	W-102 Girls LKRM Sink	8/4/16 10:37 AM	8/25/16	51112	LEAD	0.002	0.015	mg/L	16-20821
Heritage	E HE Annex Front	8/4/16 10:38 AM	8/26/16	51438	LEAD	0.001	0.015	mg/L	16-20838
WES	63 wes	8/4/16 10:38 AM	8/22/16	48418	LEAD	0.003	0.015	mg/L	16-19954
Heritage	E Kpod E	8/4/16 10:39 AM	8/26/16	51439	LEAD	0.001	0.015	mg/L	16-20838
Heritage	E HE Annex Rear	8/4/16 10:40 AM	8/26/16	51440	LEAD	ND	0.015	mg/L	16-20838
Lincoln Elementary School	F40 Gym boys bath	8/4/16 10:40 AM	8/22/16	49161	LEAD	0.003	0.015	mg/L	16-20213
Lincoln Elementary School	F41 Gym boys bath	8/4/16 10:40 AM	8/22/16	49162	LEAD	0.025	0.015	mg/L	16-20213
Lincoln Elementary School	F42 Gym boys bath	8/4/16 10:40 AM	8/22/16	49163	LEAD	0.120	0.015	mg/L	16-20213
WES	64 wes	8/4/16 10:40 AM	8/22/16	48419	LEAD	0.008	0.015	mg/L	16-19954
Heritage	E 1st grade	8/4/16 10:43 AM	8/26/16	51441	LEAD	0.004	0.015	mg/L	16-20838
WHS	W-104 Girls SHR 1-1	8/4/16 10:44 AM	8/25/16	51114	LEAD	0.014	0.015	mg/L	16-20821
WES	65 wes	8/4/16 10:44 AM	8/22/16	48420	LEAD	0.006	0.015	mg/L	16-19954
Heritage	E 2nd grade	8/4/16 10:45 AM	8/26/16	51436	LEAD	0.006	0.015	mg/L	16-20838
High School - MOD	mod 1 907	8/4/16 10:45 AM	8/24/16	50624	LEAD	ND	0.015	mg/L	16-20666
FPMS	F54 Boy Coach Shower RM	8/4/16 10:45 AM	8/22/16	49227	LEAD	0.016	0.015	mg/L	16-20214
FPMS	F55 Boy Coach RR	8/4/16 10:45 AM	8/22/16	49228	LEAD	0.119	0.015	mg/L	16-20214
WES	66 wes	8/4/16 10:45 AM	8/22/16	48421	LEAD	0.007	0.015	mg/L	16-19954
Heritage	E K Pod W	8/4/16 10:46 AM	8/26/16	51442	LEAD	0.010	0.015	mg/L	16-20838
WHS	W-105 Girls SHR 1-2	8/4/16 10:46 AM	8/25/16	51115	LEAD	0.011	0.015	mg/L	16-20821
High School - MOD	mod 2 907	8/4/16 10:46 AM	8/24/16	50625	LEAD	ND	0.015	mg/L	16-20666
High School - MOD	mod 3 907	8/4/16 10:46 AM	8/24/16	50626	LEAD	ND	0.015	mg/L	16-20666
WHS	W-106 Girls SHR 1-3	8/4/16 10:47 AM	8/25/16	51116	LEAD	0.007	0.015	mg/L	16-20821
Heritage	E HE Office	8/4/16 10:48 AM	8/26/16	51443	LEAD	0.004	0.015	mg/L	16-20838
WHS	W-107 Girls SHR 1-4	8/4/16 10:48 AM	8/25/16	51117	LEAD	0.005	0.015	mg/L	16-20821
High School - MOD	mod 4 907	8/4/16 10:48 AM	8/24/16	50627	LEAD	ND	0.015	mg/L	16-20666
WES	72 wes	8/4/16 10:48 AM	8/22/16	48422	LEAD	0.002	0.015	mg/L	16-19954
WHS	W-108 Girls SHR 1-5	8/4/16 10:49 AM	8/25/16	51118	LEAD	0.014	0.015	mg/L	16-20821
Heritage	E Generator	8/4/16 10:50 AM	8/26/16	51437	LEAD	0.008	0.015	mg/L	16-20838
WHS	W-109 Girls SHR 2-1	8/4/16 10:50 AM	8/25/16	51119	LEAD	0.011	0.015	mg/L	16-20821
WES	67 wes	8/4/16 10:50 AM	8/22/16	48423	LEAD	0.004	0.015	mg/L	16-19954
WHS	W-110 Girls SHR 2-2	8/4/16 10:51 AM	8/25/16	51120	LEAD	0.012	0.015	mg/L	16-20821
Heritage	E Loading Dock	8/4/16 10:52 AM	8/26/16	51435	LEAD	0.006	0.015	mg/L	16-20838
WES	68 wes	8/4/16 10:52 AM	8/22/16	48424	LEAD	0.004	0.015	mg/L	16-19954
WHS	W-111 Girls SHR 2-3	8/4/16 10:53 AM	8/25/16	51121	LEAD	0.011	0.015	mg/L	16-20821
WHS	W-112 Girls SHR 2-5	8/4/16 10:54 AM	8/25/16	51122	LEAD	0.010	0.015	mg/L	16-20821
FPMS	F56 Boy Shower RM	8/4/16 10:54 AM	8/22/16	49229	LEAD	0.012	0.015	mg/L	16-20214

FPMS	F57 Boy Shower RM	8/4/16 10:54 AM	8/22/16	49230	LEAD	0.031	0.015	mg/L	16-20214
FPMS	F58 Boy Shower RM	8/4/16 10:54 AM	8/22/16	49231	LEAD	0.336	0.015	mg/L	16-20214
High School - MOD	mod 7 906	8/4/16 10:55 AM	8/24/16	50630	LEAD	ND	0.015	mg/L	16-20666
Lincoln Elementary School	F43 Gym girls bath	8/4/16 10:55 AM	8/22/16	49164	LEAD	0.013	0.015	mg/L	16-20213
Lincoln Elementary School	F44 Gym girls bath	8/4/16 10:55 AM	8/22/16	49165	LEAD	0.002	0.015	mg/L	16-20213
Lincoln Elementary School	F45 Gym girls bath	8/4/16 10:55 AM	8/22/16	49166	LEAD	0.010	0.015	mg/L	16-20213
Lincoln Elementary School	F46 Gym girls bath	8/4/16 10:55 AM	8/22/16	49167	LEAD	0.001	0.015	mg/L	16-20213
Lincoln Elementary School	F47 Gym girls bath	8/4/16 10:55 AM	8/22/16	49168	LEAD	0.193	0.015	mg/L	16-20213
WHS	W-114 Girls SHR 3-1	8/4/16 10:56 AM	8/25/16	51124	LEAD	0.014	0.015	mg/L	16-20821
High School - MOD	mod 5 906	8/4/16 10:56 AM	8/24/16	50628	LEAD	ND	0.015	mg/L	16-20666
WHS	W-113 Girls SHR 3-4	8/4/16 10:57 AM	8/25/16	51123	LEAD	ND	0.015	mg/L	16-20821
High School - MOD	mod 6 906	8/4/16 10:57 AM	8/24/16	50629	LEAD	ND	0.015	mg/L	16-20666
FPMS	F31 Boy Shower Rm	8/4/16 10:57 AM	8/22/16	49204	LEAD	0.054	0.015	mg/L	16-20214
FPMS	F32 Boy Shower Rm	8/4/16 10:57 AM	8/22/16	49205	LEAD	0.082	0.015	mg/L	16-20214
FPMS	F59 Boy Shower RM	8/4/16 10:57 AM	8/22/16	49232	LEAD	0.221	0.015	mg/L	16-20214
FPMS	F60 Boy Shower RM	8/4/16 10:57 AM	8/22/16	49233	LEAD	0.155	0.015	mg/L	16-20214
WES	69 wes	8/4/16 10:57 AM	8/22/16	48425	LEAD	0.005	0.015	mg/L	16-19954
WHS	W-115 Girls SHR 3-2	8/4/16 10:58 AM	8/25/16	51125	LEAD	0.018	0.015	mg/L	16-20821
WHS	W-116 Girls SHR 3-3	8/4/16 10:59 AM	8/25/16	51126	LEAD	0.020	0.015	mg/L	16-20821
WHS	W-117 Girls SHR 3-5	8/4/16 10:59 AM	8/25/16	51127	LEAD	0.018	0.015	mg/L	16-20821
High School - MOD	mod 8 904	8/4/16 11:00 AM	8/24/16	50631	LEAD	ND	0.015	mg/L	16-20666
High School - MOD	mod 9 904	8/4/16 11:01 AM	8/24/16	50632	LEAD	ND	0.015	mg/L	16-20666
FPMS	F33 Boy Shower Rm	8/4/16 11:02 AM	8/22/16	49206	LEAD	0.047	0.015	mg/L	16-20214
FPMS	F34 Boy Shower Rm	8/4/16 11:02 AM	8/22/16	49207	LEAD	0.167	0.015	mg/L	16-20214
FPMS	F36 Boy Shower Rm	8/4/16 11:02 AM	8/22/16	49209	LEAD	0.098	0.015	mg/L	16-20214
WHS	W-118 REFF CHG RM	8/4/16 11:03 AM	8/25/16	51128	LEAD	0.017	0.015	mg/L	16-20821
WHS	W-119 REFF CHG RM	8/4/16 11:03 AM	8/25/16	51129	LEAD	0.004	0.015	mg/L	16-20821
FPMS	F35 Boy Shower Rm	8/4/16 11:04 AM	8/22/16	49208	LEAD	0.036	0.015	mg/L	16-20214
High School - MOD	mod 10 902	8/4/16 11:06 AM	8/24/16	50633	LEAD	ND	0.015	mg/L	16-20666
FPMS	F37 Boy Locker -r	8/4/16 11:06 AM	8/22/16	49210	LEAD	0.021	0.015	mg/L	16-20214
FPMS	F38 Boy Locker -r	8/4/16 11:06 AM	8/22/16	49211	LEAD	0.030	0.015	mg/L	16-20214
High School - MOD	mod 11 902	8/4/16 11:07 AM	8/24/16	50634	LEAD	ND	0.015	mg/L	16-20666
High School - MOD	mod 12 902	8/4/16 11:08 AM	8/24/16	50635	LEAD	ND	0.015	mg/L	16-20666
WHS	W-120 Staff SHR	8/4/16 11:09 AM	8/25/16	51130	LEAD	0.009	0.015	mg/L	16-20821
High School - MOD	mod 13 902	8/4/16 11:09 AM	8/24/16	50636	LEAD	ND	0.015	mg/L	16-20666
WHS	W-121 Staff Sink	8/4/16 11:10 AM	8/25/16	51131	LEAD	0.004	0.015	mg/L	16-20821
High School - MOD	mod 14 902	8/4/16 11:10 AM	8/24/16	50637	LEAD	ND	0.015	mg/L	16-20666
FPMS	F40 Hall C-M rest Rm	8/4/16 11:10 AM	8/22/16	49213	LEAD	ND	0.015	mg/L	16-20214
Lincoln Elementary School	F48 Room 42	8/4/16 11:10 AM	8/22/16	49169	LEAD	0.008	0.015	mg/L	16-20213
High School - MOD	mod 15 902	8/4/16 11:11 AM	8/24/16	50638	LEAD	ND	0.015	mg/L	16-20666
WES	18 wes	8/4/16 11:11 AM	8/22/16	48426	LEAD	0.011	0.015	mg/L	16-19954
WHS	W-122 Boys LKR Sink	8/4/16 11:12 AM	8/25/16	51132	LEAD	0.004	0.015	mg/L	16-20821

WES	20 wes	8/4/16 11:12 AM	8/22/16	48408	LEAD	0.006	0.015	mg/L	16-19954
WES	19 wes	8/4/16 11:12 AM	8/22/16	48427	LEAD	0.005	0.015	mg/L	16-19954
WHS	W-123 Boys LKR Sink	8/4/16 11:13 AM	8/25/16	51133	LEAD	0.006	0.015	mg/L	16-20821
FPMS	F39 Hall C-w-rest Rm	8/4/16 11:14 AM	8/22/16	49212	LEAD	ND	0.015	mg/L	16-20214
FPMS	F11 Room 28	8/4/16 11:15 AM	8/22/16	49184	LEAD	0.021	0.015	mg/L	16-20214
FPMS	F12 Room 28	8/4/16 11:15 AM	8/22/16	49185	LEAD	0.004	0.015	mg/L	16-20214
Lincoln Elementary School	F49 Kimle boys bath sink	8/4/16 11:15 AM	8/22/16	49170	LEAD	0.002	0.015	mg/L	16-20213
FPMS	F13 Room 28	8/4/16 11:16 AM	8/22/16	49186	LEAD	0.002	0.015	mg/L	16-20214
FPMS	F14 Room 28	8/4/16 11:16 AM	8/22/16	49187	LEAD	0.016	0.015	mg/L	16-20214
High School - MOD	mod 16 mod bathroom boys	8/4/16 11:18 AM	8/24/16	50639	LEAD	ND	0.015	mg/L	16-20666
High School - MOD	mod 17 mod bathroom boys	8/4/16 11:18 AM	8/24/16	50640	LEAD	ND	0.015	mg/L	16-20666
WHS	W-124 Boys LKR 1-1	8/4/16 11:19 AM	8/25/16	51134	LEAD	0.475	0.015	mg/L	16-20821
High School - MOD	mod 18 mod bathroom boys	8/4/16 11:19 AM	8/24/16	50641	LEAD	ND	0.015	mg/L	16-20666
High School - MOD	mod 19 mod bath boys	8/4/16 11:19 AM	8/24/16	50642	LEAD	ND	0.015	mg/L	16-20666
WHS	W-125 Boys LKR 1-2	8/4/16 11:20 AM	8/25/16	51135	LEAD	0.015	0.015	mg/L	16-20821
High School - MOD	mod 20 mod bath boys	8/4/16 11:20 AM	8/24/16	50643	LEAD	ND	0.015	mg/L	16-20666
High School - MOD	mod 21 mod bath boys	8/4/16 11:20 AM	8/24/16	50644	LEAD	0.001	0.015	mg/L	16-20666
Lincoln Elementary School	F50 Life Skills both	8/4/16 11:20 AM	8/22/16	49171	LEAD	0.007	0.015	mg/L	16-20213
WHS	W-126 Boys LKR 1-3	8/4/16 11:21 AM	8/25/16	51136	LEAD	0.029	0.015	mg/L	16-20821
WHS	W-127 Boys LKR 1-4	8/4/16 11:21 AM	8/25/16	51137	LEAD	0.009	0.015	mg/L	16-20821
High School - MOD	mod 22 mod bath boys	8/4/16 11:21 AM	8/24/16	50645	LEAD	ND	0.015	mg/L	16-20666
High School - MOD	mod 23 mod bath boys	8/4/16 11:21 AM	8/24/16	50646	LEAD	ND	0.015	mg/L	16-20666
WHS	W-128 Boys LKR 1-5	8/4/16 11:22 AM	8/25/16	51138	LEAD	0.028	0.015	mg/L	16-20821
WHS	W-129 Boys LKR 2-1	8/4/16 11:24 AM	8/25/16	51139	LEAD	0.043	0.015	mg/L	16-20821
High School - MOD	mod 24 mod bath boys	8/4/16 11:24 AM	8/24/16	50647	LEAD	ND	0.015	mg/L	16-20666
High School - MOD	mod 25 mod bath boys	8/4/16 11:24 AM	8/24/16	50648	LEAD	ND	0.015	mg/L	16-20666
FPMS	F16 Rm 31	8/4/16 11:24 AM	8/22/16	49189	LEAD	0.037	0.015	mg/L	16-20214
WHS	W-130 Boys LKR 2-2	8/4/16 11:25 AM	8/25/16	51140	LEAD	0.051	0.015	mg/L	16-20821
High School - MOD	mod 26 mod bath boys	8/4/16 11:25 AM	8/24/16	50649	LEAD	ND	0.015	mg/L	16-20666
FPMS	F17 Rm 35	8/4/16 11:25 AM	8/22/16	49190	LEAD	0.006	0.015	mg/L	16-20214
WHS	W-131 Boys LKR 2-3	8/4/16 11:26 AM	8/25/16	51141	LEAD	0.030	0.015	mg/L	16-20821
High School - MOD	mod 27 mod bath boys	8/4/16 11:26 AM	8/24/16	50650	LEAD	ND	0.015	mg/L	16-20666
High School - MOD	mod 28 mod bath boys	8/4/16 11:26 AM	8/24/16	50651	LEAD	ND	0.015	mg/L	16-20666
FPMS	F18 Hall D	8/4/16 11:26 AM	8/22/16	49191	LEAD	0.001	0.015	mg/L	16-20214
WHS	W-132 Boys LKR 2-4	8/4/16 11:27 AM	8/25/16	51142	LEAD	0.020	0.015	mg/L	16-20821
WHS	W-133 Boys LKR 2-5	8/4/16 11:27 AM	8/25/16	51143	LEAD	0.092	0.015	mg/L	16-20821
High School - MOD	mod 29 mod bath boys	8/4/16 11:27 AM	8/24/16	50652	LEAD	ND	0.015	mg/L	16-20666
High School - MOD	mod 30 mod bath boys	8/4/16 11:28 AM	8/24/16	50653	LEAD	ND	0.015	mg/L	16-20666
High School - MOD	mod 31 mod bath boys	8/4/16 11:28 AM	8/24/16	50654	LEAD	ND	0.015	mg/L	16-20666
High School - MOD	mod 32 mod bath boys	8/4/16 11:28 AM	8/24/16	50655	LEAD	ND	0.015	mg/L	16-20666
WHS	W-134 Boys LKR 3-1	8/4/16 11:29 AM	8/25/16	51144	LEAD	0.028	0.015	mg/L	16-20821
High School - MOD	mod 33 mod bath boys	8/4/16 11:29 AM	8/24/16	50656	LEAD	ND	0.015	mg/L	16-20666

WHS	W-135 Boys LKR 3-2	8/4/16 11:30 AM	8/25/16	51145	LEAD	0.033	0.015	mg/L	16-20821
WHS	W-136 Boys LKR 3-3	8/4/16 11:30 AM	8/25/16	51146	LEAD	0.030	0.015	mg/L	16-20821
FPMS	F20 Rm 25	8/4/16 11:30 AM	8/22/16	49193	LEAD	0.003	0.015	mg/L	16-20214
Lincoln Elementary School	F51 P.lot Front school	8/4/16 11:30 AM	8/22/16	49172	LEAD	0.006	0.015	mg/L	16-20213
Lincoln Elementary School	F52 P.lot Front school	8/4/16 11:30 AM	8/22/16	49173	LEAD	0.005	0.015	mg/L	16-20213
WHS	W-137 Boys LKR 3-4	8/4/16 11:31 AM	8/25/16	51147	LEAD	0.017	0.015	mg/L	16-20821
High School - MOD	mod 34 mod bath girls	8/4/16 11:34 AM	8/24/16	50657	LEAD	0.03	0.015	mg/L	16-20666
High School - MOD	mod 35 mod bath girls	8/4/16 11:35 AM	8/24/16	50658	LEAD	0.003	0.015	mg/L	16-20666
High School - MOD	mod 36 mod bath girls	8/4/16 11:35 AM	8/24/16	50659	LEAD	0.003	0.015	mg/L	16-20666
WHS	W-138 Mens Team Sink	8/4/16 11:36 AM	8/25/16	51148	LEAD	ND	0.015	mg/L	16-20821
High School - MOD	mod 37 mod bath girls	8/4/16 11:36 AM	8/24/16	50660	LEAD	0.003	0.015	mg/L	16-20666
WHS	W-139 Mens Team Sink	8/4/16 11:37 AM	8/25/16	51149	LEAD	ND	0.015	mg/L	16-20821
High School - MOD	mod 38 mod bath girls	8/4/16 11:37 AM	8/24/16	50661	LEAD	0.002	0.015	mg/L	16-20666
High School - MOD	mod 39 mod bath girls	8/4/16 11:37 AM	8/24/16	50662	LEAD	0.003	0.015	mg/L	16-20666
WHS	W-140 Mens Team Sink	8/4/16 11:38 AM	8/25/16	51150	LEAD	ND	0.015	mg/L	16-20821
WHS	W-141 Mens Team Sink	8/4/16 11:38 AM	8/25/16	51151	LEAD	0.001	0.015	mg/L	16-20821
High School - MOD	mod 40 mod bath girls	8/4/16 11:38 AM	8/24/16	50663	LEAD	0.002	0.015	mg/L	16-20666
High School - MOD	mod 41 mod bath girls	8/4/16 11:38 AM	8/24/16	50664	LEAD	0.001	0.015	mg/L	16-20666
FPMS	F19 Rm 24	8/4/16 11:38 AM	8/22/16	49192	LEAD	0.002	0.015	mg/L	16-20214
High School - MOD	mod 42 mod bath girls	8/4/16 11:39 AM	8/24/16	50665	LEAD	0.001	0.015	mg/L	16-20666
WHS	W-142 Mens Team Staff Sink	8/4/16 11:40 AM	8/25/16	51152	LEAD	ND	0.015	mg/L	16-20821
High School - MOD	mod 43 mod bath girls	8/4/16 11:40 AM	8/24/16	50666	LEAD	0.002	0.015	mg/L	16-20666
WHS	W-143 Mens Team Staff Shower	8/4/16 11:41 AM	8/25/16	51153	LEAD	ND	0.015	mg/L	16-20821
High School - MOD	mod 44 mod bath girls	8/4/16 11:41 AM	8/24/16	50667	LEAD	ND	0.015	mg/L	16-20666
WHS	W-144 Mens Team SHR	8/4/16 11:45 AM	8/25/16	51154	LEAD	0.001	0.015	mg/L	16-20821
WHS	W-145 Mens Team SHR	8/4/16 11:46 AM	8/25/16	51155	LEAD	ND	0.015	mg/L	16-20821
WHS	W-146 Mens Team SHR	8/4/16 11:46 AM	8/25/16	51156	LEAD	ND	0.015	mg/L	16-20821
WHS	W-147 Mens Team SHR	8/4/16 11:47 AM	8/25/16	51157	LEAD	0.001	0.015	mg/L	16-20821
WHS	W-148 Mens Team SHR	8/4/16 11:48 AM	8/25/16	51158	LEAD	ND	0.015	mg/L	16-20821
WHS	W-149 Mens Team SHR	8/4/16 11:50 AM	8/25/16	51159	LEAD	ND	0.015	mg/L	16-20821
FPMS	F21 Rm 9	8/4/16 11:50 AM	8/22/16	49194	LEAD	0.018	0.015	mg/L	16-20214
WHS	W-150 Mens Team SHR	8/4/16 11:51 AM	8/25/16	51160	LEAD	0.002	0.015	mg/L	16-20821
WHS	W-151 Mens Team SHR	8/4/16 11:51 AM	8/25/16	51161	LEAD	ND	0.015	mg/L	16-20821
WHS	W-152 Mens Team SHR	8/4/16 11:52 AM	8/25/16	51162	LEAD	ND	0.015	mg/L	16-20821
FPMS	F22 Rm 12	8/4/16 11:55 AM	8/22/16	49195	LEAD	0.011	0.015	mg/L	16-20214
WHS	W-153 Weight RM Mens RR	8/4/16 11:56 AM	8/25/16	51163	LEAD	0.002	0.015	mg/L	16-20821
FPMS	F23 Rm 12	8/4/16 11:56 AM	8/22/16	49196	LEAD	0.009	0.015	mg/L	16-20214
WHS	W-154 Weight RM Mens RR	8/4/16 11:57 AM	8/25/16	51164	LEAD	0.002	0.015	mg/L	16-20821
WHS	W-155 Weight RM Mens RR	8/4/16 11:57 AM	8/25/16	51165	LEAD	0.002	0.015	mg/L	16-20821
WHS	W-156 Weight RM Mens RR	8/4/16 11:58 AM	8/25/16	51166	LEAD	0.002	0.015	mg/L	16-20821
WHS	W-157 Weight RM Female RR	8/4/16 11:59 AM	8/25/16	51167	LEAD	0.007	0.015	mg/L	16-20821
WHS	W-158 Weight RM Female RR	8/4/16 12:00 PM	8/25/16	51168	LEAD	ND	0.015	mg/L	16-20821

WHS	W-159 Weight RM Female RR	8/4/16 12:01 PM	8/25/16	51169	LEAD	ND	0.015	mg/L	16-20821
WHS	W-160 Weight RM Female RR	8/4/16 12:01 PM	8/25/16	51170	LEAD	ND	0.015	mg/L	16-20821
WES	73 wes	8/4/16 12:30 PM	8/22/16	48409	LEAD	0.013	0.015	mg/L	16-19954
WES	81 wes	8/4/16 12:32 PM	8/22/16	48417	LEAD	0.004	0.015	mg/L	16-19954
WES	74 wes	8/4/16 12:34 PM	8/22/16	48410	LEAD	0.011	0.015	mg/L	16-19954
WES	80 wes	8/4/16 12:37 PM	8/22/16	48416	LEAD	0.005	0.015	mg/L	16-19954
WHS	W-161 Female Team Staff SHR	8/4/16 12:40 PM	8/25/16	51171	LEAD	0.001	0.015	mg/L	16-20821
WHS	W-162 Female Team Staff Sink	8/4/16 12:41 PM	8/25/16	51172	LEAD	0.008	0.015	mg/L	16-20821
WES	75 wes	8/4/16 12:41 PM	8/22/16	48411	LEAD	0.005	0.015	mg/L	16-19954
WHS	W-163 Female Team Sink	8/4/16 12:42 PM	8/25/16	51173	LEAD	0.017	0.015	mg/L	16-20821
WHS	W-164 Female Team Sink	8/4/16 12:43 PM	8/25/16	51174	LEAD	0.015	0.015	mg/L	16-20821
WHS	W-165 Female Team Sink	8/4/16 12:44 PM	8/25/16	51175	LEAD	0.014	0.015	mg/L	16-20821
WHS	W-166 Female Team Sink	8/4/16 12:44 PM	8/25/16	51176	LEAD	0.013	0.015	mg/L	16-20821
WHS	W-167 Female Team SHR	8/4/16 12:47 PM	8/25/16	51177	LEAD	0.004	0.015	mg/L	16-20821
WHS	W-168 Female Team SHR	8/4/16 12:48 PM	8/25/16	51178	LEAD	0.003	0.015	mg/L	16-20821
WHS	W-169 Female Team SHR	8/4/16 12:49 PM	8/25/16	51179	LEAD	0.003	0.015	mg/L	16-20821
WHS	W-170 Female Team SHR	8/4/16 12:50 PM	8/25/16	51180	LEAD	0.005	0.015	mg/L	16-20821
WHS	W-171 Female Team SHR	8/4/16 12:51 PM	8/25/16	51181	LEAD	0.002	0.015	mg/L	16-20821
WHS	W-172 Female Team SHR	8/4/16 12:51 PM	8/25/16	51182	LEAD	0.002	0.015	mg/L	16-20821
WHS	W-173 Female Team SHR	8/4/16 12:52 PM	8/25/16	51183	LEAD	0.001	0.015	mg/L	16-20821
WHS	W-174 Female Team SHR	8/4/16 12:53 PM	8/25/16	51184	LEAD	0.001	0.015	mg/L	16-20821
WHS	W-175 Female Team SHR	8/4/16 12:53 PM	8/25/16	51185	LEAD	0.002	0.015	mg/L	16-20821
WHS	W-176 WHS Sink Athletic Train	8/4/16 12:57 PM	8/25/16	51186	LEAD	0.004	0.015	mg/L	16-20821
FPMS	F24 Rm 34	8/4/16 12:58 PM	8/22/16	49197	LEAD	ND	0.015	mg/L	16-20214
FPMS	F25 Rm 34	8/4/16 12:58 PM	8/22/16	49198	LEAD	ND	0.015	mg/L	16-20214
High School - CLC	CLC 1 CLC bath 1	8/4/16 1:01 PM	8/26/16	51226	LEAD	ND	0.015	mg/L	16-20827
WHS	W-177 WHS Ice Machine Athletic Train	8/4/16 1:01 PM	8/25/16	51187	LEAD	0.016	0.015	mg/L	16-20821
High School - CLC	CLC 2 CLC bath 2	8/4/16 1:02 PM	8/26/16	51227	LEAD	0.002	0.015	mg/L	16-20827
High School - CLC	CLC 3 CLC laundry	8/4/16 1:03 PM	8/26/16	51228	LEAD	ND	0.015	mg/L	16-20827
High School - CLC	CLC 4 CLC kitchen	8/4/16 1:04 PM	8/26/16	51229	LEAD	0.001	0.015	mg/L	16-20827
High School - CLC	CLC 5 CLC preschool	8/4/16 1:06 PM	8/26/16	51230	LEAD	ND	0.015	mg/L	16-20827
High School - CLC	CLC 6 CLC preschool bath	8/4/16 1:06 PM	8/26/16	51231	LEAD	ND	0.015	mg/L	16-20827
WHS	W-178 Outdoor	8/4/16 1:07 PM	8/25/16	51188	LEAD	0.002	0.015	mg/L	16-20821
High School - CLC	CLC 7 CLC infant-toddler	8/4/16 1:08 PM	8/26/16	51232	LEAD	0.001	0.015	mg/L	16-20827
FPMS	F26 Hall D Boy R-R	8/4/16 1:08 PM	8/22/16	49199	LEAD	0.001	0.015	mg/L	16-20214
High School - CLC	CLC 8 CLC infant-toddler bath	8/4/16 1:09 PM	8/26/16	51233	LEAD	ND	0.015	mg/L	16-20827
FPMS	F27 Hall D Girl R-R	8/4/16 1:09 PM	8/22/16	49200	LEAD	0.002	0.015	mg/L	16-20214
WHS	W-179 Outdoor	8/4/16 1:10 PM	8/25/16	51189	LEAD	0.028	0.015	mg/L	16-20821
High School - CLC	CLC EXT 9 CLC west hose BIB	8/4/16 1:12 PM	8/26/16	51234	LEAD	ND	0.015	mg/L	16-20827
High School - CLC	CLC EXT 10 CLC east hose Bib	8/4/16 1:12 PM	8/26/16	51235	LEAD	ND	0.015	mg/L	16-20827
WHS	W-180 Outdoor	8/4/16 1:13 PM	8/25/16	51190	LEAD	0.002	0.015	mg/L	16-20821
Nellie	N59 Office "A" Restroom	8/4/16 1:15 PM	8/24/16	50608	LEAD	0.003	0.015	mg/L	16-20664

FPMS	F28 Hall D Custodin Closet	8/4/16 1:15 PM	8/22/16	49201	LEAD	ND	0.015	mg/L	16-20214
WHS	W-181 Outdoor	8/4/16 1:16 PM	8/25/16	51191	LEAD	ND	0.015	mg/L	16-20821
Nellie	N60 Office "B" Restroom	8/4/16 1:16 PM	8/24/16	50609	LEAD	0.002	0.015	mg/L	16-20664
FPMS	F29 Rm 36	8/4/16 1:18 PM	8/22/16	49202	LEAD	0.001	0.015	mg/L	16-20214
WHS	W-182 Outdoor	8/4/16 1:19 PM	8/25/16	51192	LEAD	ND	0.015	mg/L	16-20821
FPMS	F30 Rm 36	8/4/16 1:19 PM	8/22/16	49203	LEAD	0.002	0.015	mg/L	16-20214
WHS	W-183 Outdoor	8/4/16 1:20 PM	8/25/16	51193	LEAD	0.004	0.015	mg/L	16-20821
Nellie	N61 Kinder Boy's Restroom	8/4/16 1:20 PM	8/24/16	50610	LEAD	0.001	0.015	mg/L	16-20664
Nellie	N62 Kinder Boy's Restroom	8/4/16 1:20 PM	8/24/16	50611	LEAD	ND	0.015	mg/L	16-20664
FPMS	F91 Rm 48	8/4/16 1:20 PM	8/22/16	49264	LEAD	ND	0.015	mg/L	16-20214
Nellie	N63 Kinder Boy's Restroom	8/4/16 1:21 PM	8/24/16	50612	LEAD	0.001	0.015	mg/L	16-20664
WHS	W-184 Outdoor	8/4/16 1:22 PM	8/25/16	51194	LEAD	0.002	0.015	mg/L	16-20821
WHS	W-185 Outdoor	8/4/16 1:24 PM	8/25/16	51195	LEAD	0.015	0.015	mg/L	16-20821
WHS	W-186 Outdoor	8/4/16 1:25 PM	8/25/16	51196	LEAD	0.008	0.015	mg/L	16-20821
Nellie	N64 Kinder Girl's Restroom	8/4/16 1:27 PM	8/24/16	50613	LEAD	ND	0.015	mg/L	16-20664
Nellie	N65 Kinder Girl's Restroom	8/4/16 1:27 PM	8/24/16	50614	LEAD	ND	0.015	mg/L	16-20664
WHS	W-187 Outdoor	8/4/16 1:28 PM	8/25/16	51197	LEAD	0.002	0.015	mg/L	16-20821
Nellie	N66 Kinder Girl's Restroom	8/4/16 1:28 PM	8/24/16	50615	LEAD	ND	0.015	mg/L	16-20664
WHS	W-188 Outdoor	8/4/16 1:30 PM	8/25/16	51198	LEAD	0.001	0.015	mg/L	16-20821
WHS	W-189 Outdoor	8/4/16 1:32 PM	8/25/16	51199	LEAD	ND	0.015	mg/L	16-20821
VCR	VE Science Closet S2	8/4/16 1:34 PM	8/26/16	51493	LEAD	0.001	0.015	mg/L	16-20851
WHS	W-190 Concession Sink	8/4/16 1:38 PM	8/25/16	51200	LEAD	ND	0.015	mg/L	16-20821
Nellie	N67 Library Boy's Restroom	8/4/16 1:38 PM	8/24/16	50616	LEAD	0.003	0.015	mg/L	16-20664
Nellie	N68 Library Boy's Restroom	8/4/16 1:38 PM	8/24/16	50617	LEAD	0.004	0.015	mg/L	16-20664
Nellie	N69 Library Boy's Restroom	8/4/16 1:39 PM	8/24/16	50618	LEAD	0.003	0.015	mg/L	16-20664
VCR	VE Laundry	8/4/16 1:40 PM	8/26/16	51490	LEAD	0.005	0.015	mg/L	16-20851
VCR	VE V Office	8/4/16 1:41 PM	8/26/16	51491	LEAD	0.007	0.015	mg/L	16-20851
High School - MOD	Agg 1 outside east agg build	8/4/16 1:42 PM	8/24/16	50668	LEAD	ND	0.015	mg/L	16-20666
VCR	VE V band hall	8/4/16 1:43 PM	8/26/16	51492	LEAD	0.002	0.015	mg/L	16-20851
High School - MOD	Green 1 inside west green house	8/4/16 1:44 PM	8/24/16	50669	LEAD	ND	0.015	mg/L	16-20666
Nellie	N70 Library Girl's Restroom	8/4/16 1:44 PM	8/24/16	50619	LEAD	0.002	0.015	mg/L	16-20664
Nellie	N71 Library Girl's Restroom	8/4/16 1:44 PM	8/24/16	50620	LEAD	0.003	0.015	mg/L	16-20664
Nellie	N72 Library Girl's Restroom	8/4/16 1:45 PM	8/24/16	50621	LEAD	0.003	0.015	mg/L	16-20664
WHS	W-191 Outdoor	8/4/16 1:46 PM	8/25/16	51201	LEAD	ND	0.015	mg/L	16-20821
Nellie	N73 Kitchen Restroom	8/4/16 1:47 PM	8/24/16	50622	LEAD	0.002	0.015	mg/L	16-20664
WHS	W-192 Girls Sport RR	8/4/16 1:48 PM	8/25/16	51202	LEAD	0.001	0.015	mg/L	16-20821
WHS	W-193 Girls Sport RR	8/4/16 1:48 PM	8/25/16	51203	LEAD	ND	0.015	mg/L	16-20821
High School - MOD	Green 2 inside east green house	8/4/16 1:48 PM	8/24/16	50670	LEAD	ND	0.015	mg/L	16-20666
WHS	W-194 Boys Sport RR	8/4/16 1:49 PM	8/25/16	51204	LEAD	ND	0.015	mg/L	16-20821
High School - MOD	Green 3 outside east green house	8/4/16 1:49 PM	8/24/16	50671	LEAD	ND	0.015	mg/L	16-20666
WHS	W-195 Boys Sport RR	8/4/16 1:50 PM	8/25/16	51205	LEAD	ND	0.015	mg/L	16-20821
WHS	W-196 Ath Training Cntr	8/4/16 1:53 PM	8/25/16	51206	LEAD	ND	0.015	mg/L	16-20821

High School - Softball & T	Soft Ball 1 West Soft ball field	8/4/16 1:55 PM	8/25/16	51213	LEAD	ND	0.015	mg/L	16-20822
WHS	W-197 Ath Training Cntr Ice Machine	8/4/16 1:55 PM	8/25/16	51207	LEAD	ND	0.015	mg/L	16-20821
WHS	W-198 Ath Training Cntr Sink	8/4/16 1:55 PM	8/25/16	51208	LEAD	ND	0.015	mg/L	16-20821
WHS	W-199 Ath Training Cntr Sink	8/4/16 1:58 PM	8/25/16	51209	LEAD	ND	0.015	mg/L	16-20821
WHS	W-200 Outdoor	8/4/16 1:59 PM	8/25/16	51210	LEAD	ND	0.015	mg/L	16-20821
WHS	W-201 Concession STD	8/4/16 2:00 PM	8/25/16	51211	LEAD	ND	0.015	mg/L	16-20821
High School - Softball & T	Soft Ball 2 South Soft ball Field	8/4/16 2:01 PM	8/25/16	51214	LEAD	0.001	0.015	mg/L	16-20822
WHS	W-202 Concession STD	8/4/16 2:01 PM	8/25/16	51212	LEAD	ND	0.015	mg/L	16-20821
High School - Softball & T	Bleachers 1 South Foot ball Field Bleachers	8/4/16 2:17 PM	8/25/16	51215	LEAD	ND	0.015	mg/L	16-20822
High School - Softball & T	T-1 Tennis court stroage	8/4/16 2:23 PM	8/26/16	51216	LEAD	0.002	0.015	mg/L	16-20822
High School - Softball & T	T-2 Tennis court faucet	8/4/16 2:24 PM	8/26/16	51217	LEAD	ND	0.015	mg/L	16-20822
High School - Softball & T	T-3 Tennis court fountain	8/4/16 2:25 PM	8/26/16	51218	LEAD	0.015	0.015	mg/L	16-20822
High School - Softball & T	T-4 Boys bath Tennis Court	8/4/16 2:26 PM	8/26/16	51219	LEAD	0.002	0.015	mg/L	16-20822
High School - Softball & T	T-5 Girls bath tennis court	8/4/16 2:27 PM	8/26/16	51220	LEAD	ND	0.015	mg/L	16-20822
Maint	M 1 Shop	8/5/16 6:19 AM	8/30/16	51306	LEAD	ND	0.015	mg/L	16-20832
Maint	M 2 Shop	8/5/16 6:21 AM	8/30/16	51307	LEAD	0.001	0.015	mg/L	16-20832
Maint	M 3 Fountain Shop	8/5/16 6:23 AM	8/30/16	51308	LEAD	0.001	0.015	mg/L	16-20832
Maint	M 4 Shop	8/5/16 6:25 AM	8/30/16	51309	LEAD	ND	0.015	mg/L	16-20832
Maint	M 5 Shower Shop	8/5/16 6:27 AM	8/30/16	51310	LEAD	0.002	0.015	mg/L	16-20832
Maint	M 6 Show B-R	8/5/16 6:28 AM	8/30/16	51311	LEAD	ND	0.015	mg/L	16-20832
Maint	M 7 Utility sink breakoom	8/5/16 6:30 AM	8/30/16	51312	LEAD	0.001	0.015	mg/L	16-20832
Maint	M 8 Kitchen sink breakroom	8/5/16 6:31 AM	8/30/16	51313	LEAD	0.001	0.015	mg/L	16-20832
Maint	M 9 S hose BIB	8/5/16 6:38 AM	8/30/16	51314	LEAD	0.010	0.015	mg/L	16-20832
Maint	M 10 N hose BIB	8/5/16 6:40 AM	8/30/16	51315	LEAD	0.006	0.015	mg/L	16-20832
Success	SU-9 Kitchen	8/5/16 7:22 AM	8/26/16	51246	LEAD	ND	0.015	mg/L	16-20829
Success	SU-8 Down Girls Bath	8/5/16 7:23 AM	8/26/16	51245	LEAD	ND	0.015	mg/L	16-20829
Success	Su-6 Down Boys Bath	8/5/16 7:24 AM	8/26/16	51243	LEAD	ND	0.015	mg/L	16-20829
Success	SU-7 Custodian 1	8/5/16 7:25 AM	8/26/16	51244	LEAD	0.001	0.015	mg/L	16-20829
Success	SU-1 Up Girls bath	8/5/16 7:27 AM	8/26/16	51238	LEAD	ND	0.015	mg/L	16-20829
Success	SU-2 Class 201	8/5/16 7:28 AM	8/26/16	51239	LEAD	ND	0.015	mg/L	16-20829
Success	SU-3 Up Boys Bath	8/5/16 7:29 AM	8/26/16	51240	LEAD	ND	0.015	mg/L	16-20829
Success	SU-4 Upstair Fountain	8/5/16 7:31 AM	8/26/16	51241	LEAD	0.001	0.015	mg/L	16-20829
Success	SU-5 Classroom	8/5/16 7:32 AM	8/26/16	51242	LEAD	ND	0.015	mg/L	16-20829
Success	SU-10 Hose Bibb	8/5/16 7:35 AM	8/26/16	51247	LEAD	ND	0.015	mg/L	16-20829
Bridges	B-7 Staff Br	8/5/16 7:45 AM	8/26/16	51322	LEAD	ND	0.015	mg/L	16-20833
Bridges	B-6 Kitchen	8/5/16 7:46 AM	8/26/16	51321	LEAD	ND	0.015	mg/L	16-20833
Bridges	B-5 Custodian	8/5/16 7:47 AM	8/26/16	51320	LEAD	ND	0.015	mg/L	16-20833
Bridges	B-2 Down #2 Br	8/5/16 7:48 AM	8/26/16	51317	LEAD	ND	0.015	mg/L	16-20833
Bridges	B-4 Up Br	8/5/16 7:48 AM	8/26/16	51319	LEAD	ND	0.015	mg/L	16-20833
Bridges	B-3 Down Fountain	8/5/16 7:49 AM	8/26/16	51318	LEAD	ND	0.015	mg/L	16-20833
Bridges	B-1 Down #1 Br	8/5/16 7:50 AM	8/26/16	51316	LEAD	ND	0.015	mg/L	16-20833
O-Welcome	O-1 Fountain	8/5/16 8:00 AM	8/22/16	49266	LEAD	ND	0.015	mg/L	16-20215

O-Welcome	O-2 Front Br	8/5/16 8:01 AM	8/22/16	49267	LEAD	0.004	0.015	mg/L	16-20215
O-Welcome	O-3 Kitchen	8/5/16 8:02 AM	8/22/16	49268	LEAD	0.001	0.015	mg/L	16-20215
O-Welcome	O-4 Back Br	8/5/16 8:02 AM	8/22/16	49269	LEAD	0.003	0.015	mg/L	16-20215
O-Welcome	O-5 East Hose BB	8/5/16 8:05 AM	8/22/16	49270	LEAD	0.001	0.015	mg/L	16-20215
O-Welcome	O-6 North Hose BB	8/5/16 8:06 AM	8/22/16	49271	LEAD	0.005	0.015	mg/L	16-20215
CIP	C-1 Kitchen 1	8/5/16 8:35 AM	8/22/16	48381	LEAD	0.002	0.015	mg/L	16-19952
CIP	c-2 Kitchen 2	8/5/16 8:36 AM	8/22/16	48382	LEAD	ND	0.015	mg/L	16-19952
CIP	C-3 Kitchen 3	8/5/16 8:36 AM	8/22/16	48383	LEAD	ND	0.015	mg/L	16-19952
CIP	C-4 Custodian	8/5/16 8:38 AM	8/22/16	48384	LEAD	ND	0.015	mg/L	16-19952
CIP	C-6 Fountain S-Hall	8/5/16 8:38 AM	8/22/16	48386	LEAD	ND	0.015	mg/L	16-19952
CIP	C-5 Fountain Hall	8/5/16 8:39 AM	8/22/16	48385	LEAD	ND	0.015	mg/L	16-19952
CIP	C-7 Class 1 east	8/5/16 8:41 AM	8/22/16	48387	LEAD	ND	0.015	mg/L	16-19952
CIP	C-8 Class 1 North	8/5/16 8:42 AM	8/22/16	48388	LEAD	ND	0.015	mg/L	16-19952
CIP	C-9 Br Middle	8/5/16 8:43 AM	8/22/16	48389	LEAD	ND	0.015	mg/L	16-19952
CIP	C-11 Class middle 1	8/5/16 8:44 AM	8/22/16	48391	LEAD	ND	0.015	mg/L	16-19952
CIP	C-12 Class middle 2	8/5/16 8:45 AM	8/22/16	48392	LEAD	ND	0.015	mg/L	16-19952
CIP	C-13 Bath 1	8/5/16 8:45 AM	8/22/16	48393	LEAD	ND	0.015	mg/L	16-19952
CIP	C-10 Br middle 2	8/5/16 8:46 AM	8/22/16	48390	LEAD	ND	0.015	mg/L	16-19952
CIP	C-14 Bath 2	8/5/16 8:46 AM	8/22/16	48394	LEAD	ND	0.015	mg/L	16-19952
CIP	C-15 Class 3 west	8/5/16 8:47 AM	8/22/16	48395	LEAD	ND	0.015	mg/L	16-19952
CIP	C-16 Class 3 East	8/5/16 8:48 AM	8/23/16	48396	LEAD	ND	0.015	mg/L	16-19952
DO	D-1 Kitchen	8/5/16 10:00 AM	8/26/16	51323	LEAD	ND	0.015	mg/L	16-20834
DO	D-2 Bath Down left	8/5/16 10:04 AM	8/26/16	51324	LEAD	ND	0.015	mg/L	16-20834
DO	D-3 bath down right	8/5/16 10:05 AM	8/26/16	51325	LEAD	ND	0.015	mg/L	16-20834
DO	D-4 Fountain short	8/5/16 10:06 AM	8/26/16	51326	LEAD	ND	0.015	mg/L	16-20834
DO	D-5 Fountain tall	8/5/16 10:06 AM	8/26/16	51327	LEAD	ND	0.015	mg/L	16-20834
DO	D-6 mens bath down left	8/5/16 10:07 AM	8/26/16	51328	LEAD	0.001	0.015	mg/L	16-20834
DO	D-7 mens bath down right	8/5/16 10:07 AM	8/26/16	51329	LEAD	ND	0.015	mg/L	16-20834
DO	D-8 mens bath up	8/5/16 10:08 AM	8/26/16	51330	LEAD	ND	0.015	mg/L	16-20834
DO	D-9 woman bath up	8/5/16 10:09 AM	8/26/16	51331	LEAD	ND	0.015	mg/L	16-20834
DO	D-10 east hose BIB	8/5/16 10:14 AM	8/26/16	51332	LEAD	0.004	0.015	mg/L	16-20834
DO	D-11 N W Hose BIB	8/5/16 10:15 AM	8/26/16	51333	LEAD	0.006	0.015	mg/L	16-20834
DO	D-12 S W Hose BIB	8/5/16 10:16 AM	8/26/16	51334	LEAD	0.109	0.015	mg/L	16-20834
LES	A1 Kitchen	8/31/16 5:50 AM	9/12/16	52713	LEAD	0.002	0.015	mg/L	16-21391
LES	A2 Kitchen	8/31/16 5:50 AM	9/12/16	52714	LEAD	0.001	0.015	mg/L	16-21391
Nellie Retest	N28 N28 - Kitchen Sprayer	9/2/16 12:06 AM	9/14/16	53408	LEAD	0.005	0.015	mg/L	16-21705
High School	T2K High School Kitchen Sink	9/13/16 7:00 AM	9/15/16	55353	LEAD	0.002	0.015	mg/L	16-22614
High School	T2N High School Nurse Sink	9/13/16 7:15 AM	9/15/16	55354	LEAD	0.003	0.015	mg/L	16-22614
High School	T2116 High School Rm 116 Sink	9/13/16 7:20 AM	9/15/16	55355	LEAD	0.018	0.015	mg/L	16-22614
Lincoln	L-1 Girls Gym Bath Left	10/18/16 6:06 AM	10/21/16	63790	LEAD	0.002	0.015	mg/L	16-26027
Lincoln	L-2 Boys Gym Bath Left	10/18/16 6:08 AM	10/21/16	63791	LEAD	0.009	0.015	mg/L	16-26027
Lincoln	L-3 Boys Gym Bath Right	10/18/16 6:10 AM	10/21/16	63792	LEAD	0.002	0.015	mg/L	16-26027

Lincoln	L-4 Rm 6	10/18/16 6:12 AM	10/21/16	63793	LEAD	0.003	0.015	mg/L	16-26027
Lincoln	L-5 Rm 8	10/18/16 6:14 AM	10/21/16	63794	LEAD	0.002	0.015	mg/L	16-26027
Lincoln	L-6 Rm 14	10/18/16 6:15 AM	10/21/16	63795	LEAD	0.004	0.015	mg/L	16-26027
Lincoln	L-7 Rm 16	10/18/16 6:17 AM	10/21/16	63796	LEAD	0.004	0.015	mg/L	16-26027
Lincoln	L-8 Rm 18 Faucet	10/18/16 6:18 AM	10/21/16	63797	LEAD	0.002	0.015	mg/L	16-26027
Lincoln	L-9 Rm 18 Bubbler	10/18/16 6:18 AM	10/21/16	63798	LEAD	0.004	0.015	mg/L	16-26027
Lincoln	L-10 Rm 19 Raucet Left	10/18/16 6:20 AM	10/21/16	63799	LEAD	0.041	0.015	mg/L	16-26027
Lincoln	L-11 Rm 19 Bubbler	10/18/16 6:20 AM	10/21/16	63800	LEAD	0.007	0.015	mg/L	16-26027
Lincoln	L-12 Rm 19 High Faucet Right	10/18/16 6:20 AM	10/21/16	63801	LEAD	0.003	0.015	mg/L	16-26027
Lincoln	L-13 Rm 20 Faucet	10/18/16 6:22 AM	10/21/16	63802	LEAD	0.003	0.015	mg/L	16-26027
Lincoln	L-14 Rm 20 Bubbler	10/18/16 6:22 AM	10/21/16	63803	LEAD	0.003	0.015	mg/L	16-26027
Lincoln	L-15 North Hall Bubbler	10/18/16 6:25 AM	10/21/16	63804	LEAD	0.007	0.015	mg/L	16-26027
Lincoln	L-16 Rm 29	10/18/16 6:26 AM	10/21/16	63805	LEAD	0.003	0.015	mg/L	16-26027
Lincoln	L-17 Back Hallway Boys Right Bath	10/18/16 6:26 AM	10/21/16	63806	LEAD	0.003	0.015	mg/L	16-26027
Lincoln	L-18 Rm 32	10/18/16 6:27 AM	10/21/16	63807	LEAD	0.002	0.015	mg/L	16-26027
Lincoln	L-19 Rm 2 Faucet	10/18/16 6:29 AM	10/21/16	63808	LEAD	0.006	0.015	mg/L	16-26027
Lincoln	L-20 Rm 2 Bubbler	10/18/16 6:29 AM	10/21/16	63809	LEAD	0.002	0.015	mg/L	16-26027
Lincoln	L-21 Main Office Faucet	10/18/16 6:31 AM	10/21/16	63810	LEAD	0.002	0.015	mg/L	16-26027
Lincoln	L-22 Library Office Faucet	10/18/16 6:31 AM	10/21/16	63811	LEAD	0.005	0.015	mg/L	16-26027
Lincoln	L-23 Gym Girls Bath Right	10/18/16 6:32 AM	10/21/16	63812	LEAD	0.001	0.015	mg/L	16-26027
French Prairie	F-1 Girls Locker Rm Shower	10/18/16 6:38 AM	10/20/16	63763	LEAD	0.022	0.015	mg/L	16-26026
French Prairie	F-2 Girls Locker Rm Shower	10/18/16 6:39 AM	10/20/16	63764	LEAD	0.040	0.015	mg/L	16-26026
French Prairie	F-3 Girls Locker Rm Shower	10/18/16 6:39 AM	10/20/16	63765	LEAD	0.020	0.015	mg/L	16-26026
French Prairie	F-4 Girls Locker Rm Shower	10/18/16 6:39 AM	10/20/16	63766	LEAD	0.014	0.015	mg/L	16-26026
French Prairie	F-5 Girls Locker Rm Shower	10/18/16 6:40 AM	10/20/16	63767	LEAD	0.017	0.015	mg/L	16-26026
French Prairie	F-6 Girls Locker Rm Shower	10/18/16 6:40 AM	10/20/16	63768	LEAD	0.073	0.015	mg/L	16-26026
French Prairie	F-7 Girls Locker Rm Shower	10/18/16 6:40 AM	10/20/16	63769	LEAD	0.036	0.015	mg/L	16-26026
French Prairie	F-8 Girls Locker Rm Shower	10/18/16 6:41 AM	10/20/16	63770	LEAD	0.016	0.015	mg/L	16-26026
French Prairie	F-9 Girls Locker Rm Shower	10/18/16 6:41 AM	10/20/16	63771	LEAD	0.030	0.015	mg/L	16-26026
French Prairie	F-10 Girls Locker Rm Shower	10/18/16 6:42 AM	10/20/16	63772	LEAD	0.014	0.015	mg/L	16-26026
French Prairie	F-11 Girls Locker Rm Shower	10/18/16 6:44 AM	10/20/16	63773	LEAD	0.003	0.015	mg/L	16-26026
French Prairie	F-12 Boys Locker Rm Shower	10/18/16 6:47 AM	10/20/16	63774	LEAD	0.014	0.015	mg/L	16-26026
French Prairie	F-13 Boys Locker Rm Shower	10/18/16 6:48 AM	10/21/16	63775	LEAD	0.015	0.015	mg/L	16-26026
French Prairie	F-14 Boys Locker Rm Shower	10/18/16 6:48 AM	10/21/16	63776	LEAD	0.009	0.015	mg/L	16-26026
French Prairie	F-15 Boys Locker Rm Shower	10/18/16 6:49 AM	10/21/16	63777	LEAD	0.013	0.015	mg/L	16-26026
French Prairie	F-16 Boys Locker Rm Shower	10/18/16 6:49 AM	10/21/16	63778	LEAD	0.014	0.015	mg/L	16-26026
French Prairie	F-17 Boys Locker Rm Shower	10/18/16 6:50 AM	10/21/16	63779	LEAD	0.020	0.015	mg/L	16-26026
French Prairie	F-18 Boys Locker Rm Shower	10/18/16 6:50 AM	10/21/16	63780	LEAD	0.022	0.015	mg/L	16-26026
French Prairie	F-19 Boys Locker Rm Shower	10/18/16 6:50 AM	10/21/16	63781	LEAD	0.016	0.015	mg/L	16-26026
French Prairie	F-20 Boys Locker Rm Shower	10/18/16 6:52 AM	10/21/16	63782	LEAD	0.013	0.015	mg/L	16-26026
French Prairie	F-21 Boys Locker Rm Shower	10/18/16 6:52 AM	10/21/16	63783	LEAD	0.018	0.015	mg/L	16-26026
French Prairie	F-22 Boys Locker Rm Shower	10/18/16 6:52 AM	10/21/16	63784	LEAD	0.040	0.015	mg/L	16-26026























































