

Any fixture that tested over the action level of 1.3 mg/L, was disabled, repairs made and retested

Project	Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Analyte	Result	EPA Action Level	Units	Project number
Heritage	H1 Kitchen W Sink	7/6/16 6:10 AM	8/10/16	37586	COPPER	0.232	1.3	mg/L	16-15757
Heritage	H2 Kitchen E Sink	7/6/16 6:12 AM	8/10/16	37587	COPPER	0.206	1.3	mg/L	16-15757
Heritage	H3 HE Gym W Fountain	7/6/16 6:13 AM	8/10/16	37588	COPPER	0.206	1.3	mg/L	16-15757
Heritage	H3 HE Gym E Fountain	7/6/16 6:14 AM	8/10/16	37589	COPPER	0.206	1.3	mg/L	16-15757
Heritage	H4 Cafe fountain	7/6/16 6:17 AM	8/10/16	37590	COPPER	0.173	1.3	mg/L	16-15757
Heritage	H4 Music Rm 1 Fountain	7/6/16 6:15 AM	8/10/16	37591	COPPER	0.296	1.3	mg/L	16-15757
Heritage	H5 Staff Rm Sink	7/6/16 6:22 AM	8/10/16	37592	COPPER	0.183	1.3	mg/L	16-15757
Heritage	H5 Staff Rm Water Filter	7/6/16 6:23 AM	8/11/16	37593	COPPER	ND	1.3	mg/L	16-15757
Heritage	H6 Rm 9	7/6/16 6:32 AM	8/10/16	37594	COPPER	0.240	1.3	mg/L	16-15757
Heritage	H6 Rm 6	7/6/16 6:33 AM	8/10/16	37595	COPPER	0.261	1.3	mg/L	16-15757
Heritage	H6 Rm 8	7/6/16 6:32 AM	8/10/16	37596	COPPER	0.251	1.3	mg/L	16-15757
Heritage	H6 Rm 4	7/6/16 6:24 AM	8/10/16	37597	COPPER	0.322	1.3	mg/L	16-15757
Heritage	H6 Pod Fountain	7/6/16 6:25 AM	8/10/16	37598	COPPER	0.213	1.3	mg/L	16-15757
Heritage	H6 Rm 7	7/6/16 6:31 AM	8/10/16	37599	COPPER	0.221	1.3	mg/L	16-15757
Heritage	H6 Rm 3	7/6/16 6:27 AM	8/10/16	37600	COPPER	0.221	1.3	mg/L	16-15757
Heritage	H6 Rm 5	7/6/16 6:28 AM	8/10/16	37601	COPPER	0.271	1.3	mg/L	16-15757
Heritage	H6 Rm 2	7/6/16 6:26 AM	8/10/16	37602	COPPER	0.261	1.3	mg/L	16-15757
Heritage	H7 Rm 17	7/6/16 6:43 AM	8/10/16	37603	COPPER	0.280	1.3	mg/L	16-15757
Heritage	H7 Rm 13	7/6/16 6:39 AM	8/10/16	37604	COPPER	0.266	1.3	mg/L	16-15757
Heritage	H7 Rm 10	7/6/16 6:35 AM	8/10/16	37605	COPPER	0.263	1.3	mg/L	16-15757
Heritage	H7 Rm 14	7/6/16 6:45 AM	8/10/16	37606	COPPER	0.277	1.3	mg/L	16-15757
Heritage	H7 Rm 11	7/6/16 6:36 AM	8/10/16	37607	COPPER	0.236	1.3	mg/L	16-15757
Heritage	H7 Rm 12	7/6/16 6:38 AM	8/10/16	37608	COPPER	0.293	1.3	mg/L	16-15757
Heritage	H7 Rm 16	7/6/16 6:44 AM	8/10/16	37609	COPPER	0.282	1.3	mg/L	16-15757
Heritage	H7 Rm 15	7/6/16 6:41 AM	8/10/16	37610	COPPER	0.267	1.3	mg/L	16-15757
Heritage	H8 Rm 21	7/6/16 6:51 AM	8/10/16	37611	COPPER	0.284	1.3	mg/L	16-15757
Heritage	H8 Rm 19	7/6/16 6:46 AM	8/10/16	37612	COPPER	0.264	1.3	mg/L	16-15757
Heritage	H8 Pod Fountain	7/6/16 6:50 AM	8/10/16	37613	COPPER	0.235	1.3	mg/L	16-15757
Heritage	H8 Rm 25	7/6/16 6:54 AM	8/10/16	37614	COPPER	0.261	1.3	mg/L	16-15757
Heritage	H8 Rm 24	7/6/16 6:57 AM	8/10/16	37615	COPPER	0.265	1.3	mg/L	16-15757
Heritage	H8 Rm 20	7/6/16 6:49 AM	8/10/16	37616	COPPER	0.238	1.3	mg/L	16-15757
Heritage	H8 Rm 18	7/6/16 6:48 AM	8/10/16	37617	COPPER	0.232	1.3	mg/L	16-15757
Heritage	H8 Rm 22	7/6/16 6:52 AM	8/10/16	37618	COPPER	0.248	1.3	mg/L	16-15757
Heritage	H8 Rm 23	7/6/16 6:56 AM	8/10/16	37619	COPPER	0.277	1.3	mg/L	16-15757
Heritage	A A1 Fountain	7/6/16 6:57 AM	8/10/16	37620	COPPER	0.036	1.3	mg/L	16-15757
Heritage	A A2 Fountain	7/6/16 6:58 AM	8/10/16	37621	COPPER	0.033	1.3	mg/L	16-15757
Heritage	A A3 Fountain	7/6/16 6:59 AM	8/10/16	37622	COPPER	0.077	1.3	mg/L	16-15757
Heritage	A A4 Fountain	7/6/16 7:00 AM	8/10/16	37623	COPPER	0.076	1.3	mg/L	16-15757
Heritage	A A5 Sink Staff	7/6/16 7:01 AM	8/10/16	37624	COPPER	0.099	1.3	mg/L	16-15757

Heritage	A A5 Water Filter	7/6/16 7:02 AM	8/11/16	37625	COPPER	ND	1.3	mg/L	16-15757
Washington	1 Room 16	7/6/16 6:40 AM	8/10/16	37844	COPPER	0.008	1.3	mg/L	16-15883
Washington	2 Room 17	7/6/16 6:41 AM	8/10/16	37845	COPPER	0.012	1.3	mg/L	16-15883
Washington	3 Outside Fountain	7/6/16 6:45 AM	8/10/16	37846	COPPER	0.011	1.3	mg/L	16-15883
Washington	4 Outside Fountain	7/6/16 6:46 AM	8/10/16	37847	COPPER	0.009	1.3	mg/L	16-15883
Washington	5 Room 15	7/6/16 6:50 AM	8/10/16	37848	COPPER	0.008	1.3	mg/L	16-15883
Washington	6 Room 13	7/6/16 6:52 AM	8/10/16	37849	COPPER	0.009	1.3	mg/L	16-15883
Washington	7 Room 14	7/6/16 6:54 AM	8/10/16	37850	COPPER	0.015	1.3	mg/L	16-15883
Washington	8 Music Room 21	7/6/16 6:57 AM	8/10/16	37851	COPPER	0.042	1.3	mg/L	16-15883
Washington	9 Room 11	7/6/16 7:03 AM	8/10/16	37852	COPPER	0.007	1.3	mg/L	16-15883
Washington	10 Room 12	7/6/16 7:05 AM	8/10/16	37853	COPPER	0.009	1.3	mg/L	16-15883
Washington	11 Hallway	7/6/16 7:12 AM	8/10/16	37854	COPPER	0.013	1.3	mg/L	16-15883
Washington	12 Hallway	7/6/16 7:16 AM	8/10/16	37855	COPPER	0.005	1.3	mg/L	16-15883
Washington	13 Room 4	7/6/16 7:20 AM	8/10/16	37856	COPPER	0.021	1.3	mg/L	16-15883
Washington	14 Hallway	7/6/16 7:24 AM	8/10/16	37857	COPPER	0.010	1.3	mg/L	16-15883
Washington	15 Room 3	7/6/16 7:27 AM	8/10/16	37858	COPPER	0.014	1.3	mg/L	16-15883
Washington	16 Staff Room Refer	7/6/16 7:31 AM	8/10/16	37859	COPPER	0.004	1.3	mg/L	16-15883
Washington	17 Staff Room Water Filter	7/6/16 7:33 AM	8/10/16	37860	COPPER	ND	1.3	mg/L	16-15883
Washington	18 Kitchen Kettle	7/6/16 7:36 AM	8/10/16	37861	COPPER	0.122	1.3	mg/L	16-15883
Washington	19 Kitchen Prep Sink	7/6/16 7:40 AM	8/10/16	37862	COPPER	0.041	1.3	mg/L	16-15883
Washington	20 Kitchen Sink	7/6/16 7:43 AM	8/10/16	37863	COPPER	0.007	1.3	mg/L	16-15883
Washington	21 Commons WF	7/6/16 7:45 AM	8/10/16	37864	COPPER	0.015	1.3	mg/L	16-15883
Washington	22 Commons WF	7/6/16 7:50 AM	8/10/16	37865	COPPER	0.007	1.3	mg/L	16-15883
Washington	23 Room 18	7/6/16 7:54 AM	8/10/16	37866	COPPER	0.006	1.3	mg/L	16-15883
Washington	24 Room 19	7/6/16 7:56 AM	8/10/16	37867	COPPER	0.005	1.3	mg/L	16-15883
Washington	25 Room 20	7/6/16 8:00 AM	8/10/16	37868	COPPER	0.010	1.3	mg/L	16-15883
Washington	26 Gym WF	7/6/16 8:01 AM	8/10/16	37869	COPPER	0.158	1.3	mg/L	16-15883
Washington	27 Gym WF	7/6/16 8:02 AM	8/10/16	37870	COPPER	0.152	1.3	mg/L	16-15883
Washington	28 Office	7/6/16 8:03 AM	8/10/16	37871	COPPER	0.032	1.3	mg/L	16-15883
French Prairie	F 1 Hall A	7/6/16 7:32 AM	8/10/16	37882	COPPER	0.117	1.3	mg/L	16-15891
French Prairie	F 2 Hall A	7/6/16 7:35 AM	8/10/16	37883	COPPER	0.104	1.3	mg/L	16-15891
French Prairie	F 3 Hall A	7/6/16 7:36 AM	8/10/16	37884	COPPER	0.031	1.3	mg/L	16-15891
French Prairie	F 4 Staff Room	7/6/16 7:40 AM	8/10/16	37885	COPPER	0.179	1.3	mg/L	16-15891
French Prairie	F 5 Staff Room	7/6/16 7:42 AM	8/10/16	37886	COPPER	0.001	1.3	mg/L	16-15891
French Prairie	F 6 Commons	7/6/16 7:44 AM	8/10/16	37887	COPPER	0.235	1.3	mg/L	16-15891
French Prairie	F 7 Hall B	7/6/16 7:46 AM	8/10/16	37888	COPPER	0.099	1.3	mg/L	16-15891
French Prairie	F 8 Hall B	7/6/16 7:48 AM	8/10/16	37889	COPPER	0.088	1.3	mg/L	16-15891
French Prairie	F 9 Boy's Locker Room	7/6/16 7:52 AM	8/10/16	37890	COPPER	0.016	1.3	mg/L	16-15891
French Prairie	F 10 Hall C	7/6/16 7:54 AM	8/10/16	37891	COPPER	0.252	1.3	mg/L	16-15891
French Prairie	F 11 Kitchen	7/6/16 7:56 AM	8/10/16	37892	COPPER	0.173	1.3	mg/L	16-15891
French Prairie	F 12 Kitchen	7/6/16 8:00 AM	8/10/16	37893	COPPER	0.216	1.3	mg/L	16-15891
French Prairie	F 13 Room 34	7/6/16 8:02 AM	8/10/16	37894	COPPER	0.205	1.3	mg/L	16-15891

French Prairie	F 14 Room 34	7/6/16 8:02 AM	8/10/16	37895	COPPER	0.238	1.3	mg/L	16-15891
French Prairie	F 15 Hall D	7/6/16 8:10 AM	8/10/16	37896	COPPER	0.213	1.3	mg/L	16-15891
French Prairie	F 16 Room 25	7/6/16 8:15 AM	8/10/16	37897	COPPER	0.093	1.3	mg/L	16-15891
French Prairie	F 17 Room 24	7/6/16 8:17 AM	8/10/16	37898	COPPER	0.162	1.3	mg/L	16-15891
French Prairie	F 18 Gym	7/6/16 8:20 AM	8/10/16	37899	COPPER	0.015	1.3	mg/L	16-15891
French Prairie	F 19 Gym	7/6/16 8:21 AM	8/10/16	37900	COPPER	0.007	1.3	mg/L	16-15891
French Prairie	F 20 Gym	7/6/16 8:22 AM	8/10/16	37901	COPPER	0.033	1.3	mg/L	16-15891
French Prairie	F 21 Gym	7/6/16 7:23 AM	8/10/16	37902	COPPER	0.025	1.3	mg/L	16-15891
Valor	L Girl's Locker Room	7/6/16 7:04 AM	8/10/16	37936	COPPER	0.210	1.3	mg/L	16-15908
Valor	L Boy's Locker Room	7/6/16 7:05 AM	8/10/16	37937	COPPER	0.210	1.3	mg/L	16-15908
Valor	V1 VA Gym S Fountain	7/6/16 7:09 AM	8/10/16	37938	COPPER	0.230	1.3	mg/L	16-15908
Valor	V1 VA Gym N Fountain	7/6/16 7:10 AM	8/10/16	37939	COPPER	0.219	1.3	mg/L	16-15908
Valor	V2 VA Cafe W Fountain	7/6/16 7:12 AM	8/10/16	37940	COPPER	0.201	1.3	mg/L	16-15908
Valor	V2 VA Cafe Middle Fountain	7/6/16 7:13 AM	8/10/16	37941	COPPER	0.214	1.3	mg/L	16-15908
Valor	V2 VA Cafe E Fountain	7/6/16 7:11 AM	8/10/16	37942	COPPER	0.224	1.3	mg/L	16-15908
Valor	V3 VA Band/Music	7/6/16 7:14 AM	8/10/16	37943	COPPER	0.289	1.3	mg/L	16-15908
Valor	V4 A6	7/6/16 7:17 AM	8/11/16	37944	COPPER	0.256	1.3	mg/L	16-15908
Valor	V4 Office Filter Water	7/6/16 7:18 AM	8/11/16	37945	COPPER	ND	1.3	mg/L	16-15908
Valor	V4 Staff Room Water Filter	7/6/16 7:24 AM	8/11/16	37946	COPPER	ND	1.3	mg/L	16-15908
Valor	V4 Staff Room Sink	7/6/16 7:23 AM	8/11/16	37947	COPPER	0.162	1.3	mg/L	16-15908
Valor	V4 Room 101	7/6/16 7:19 AM	8/11/16	37948	COPPER	0.299	1.3	mg/L	16-15908
Valor	V4 Room 109	7/6/16 7:29 AM	8/11/16	37949	COPPER	0.279	1.3	mg/L	16-15908
Valor	V4 Room 107	7/6/16 7:30 AM	8/11/16	37950	COPPER	0.283	1.3	mg/L	16-15908
Valor	V4 Room 103	7/6/16 7:26 AM	8/11/16	37951	COPPER	0.285	1.3	mg/L	16-15908
Valor	V4 Room 108	7/6/16 7:28 AM	8/11/16	37952	COPPER	0.284	1.3	mg/L	16-15908
Valor	V4 Room 106	7/6/16 7:27 AM	8/11/16	37953	COPPER	0.281	1.3	mg/L	16-15908
Valor	V5 Room 212	7/6/16 7:32 AM	8/10/16	37954	COPPER	0.245	1.3	mg/L	16-15908
Valor	V5 Room 211	7/6/16 7:33 AM	8/10/16	37955	COPPER	0.256	1.3	mg/L	16-15908
Valor	V5 Room 209	7/6/16 7:34 AM	8/10/16	37956	COPPER	0.530	1.3	mg/L	16-15908
Valor	V5 Room 210	7/6/16 7:35 AM	8/10/16	37957	COPPER	0.268	1.3	mg/L	16-15908
Valor	V5 Room 208	7/6/16 7:38 AM	8/10/16	37958	COPPER	0.252	1.3	mg/L	16-15908
Valor	V5 Upstairs Fountain	7/6/16 7:43 AM	8/10/16	37959	COPPER	0.233	1.3	mg/L	16-15908
Valor	V5 Room 206	7/6/16 7:44 AM	8/10/16	37960	COPPER	0.270	1.3	mg/L	16-15908
Valor	V5 Room 207	7/6/16 7:41 AM	8/10/16	37961	COPPER	0.238	1.3	mg/L	16-15908
Valor	V5 Room 203	7/6/16 7:46 AM	8/10/16	37962	COPPER	0.245	1.3	mg/L	16-15908
Valor	V5 Room 204	7/6/16 7:47 AM	8/10/16	37963	COPPER	0.293	1.3	mg/L	16-15908
Valor	V5 Room 201	7/6/16 7:48 AM	8/10/16	37964	COPPER	0.320	1.3	mg/L	16-15908
High School	HS-1 Kitchen H.S.	7/6/16 6:35 AM	8/10/16	38716	COPPER	0.056	1.3	mg/L	16-16101
High School	HS-2 Webbs Hall	7/6/16 7:15 AM	8/10/16	38717	COPPER	0.007	1.3	mg/L	16-16101
High School	HS-3 Webbs Hall	7/6/16 7:16 AM	8/10/16	38718	COPPER	0.004	1.3	mg/L	16-16101
High School	HS-4 Webbs Office	7/6/16 7:19 AM	8/10/16	38719	COPPER	0.043	1.3	mg/L	16-16101
High School	HS-5 Lg. Commons	7/6/16 7:22 AM	8/10/16	38720	COPPER	0.122	1.3	mg/L	16-16101

High School	HS-6 Lg. Commons	7/6/16 7:23 AM	8/10/16	38721	COPPER	0.121	1.3	mg/L	16-16101
High School	HS-7 Lg. Commons	7/6/16 7:27 AM	8/10/16	38722	COPPER	0.098	1.3	mg/L	16-16101
High School	HS-8 Lg. Commons	7/6/16 7:27 AM	8/10/16	38723	COPPER	0.094	1.3	mg/L	16-16101
High School	HS-9 Room B-11 (116)	7/6/16 8:01 AM	8/10/16	38724	COPPER	0.254	1.3	mg/L	16-16101
High School	HS-10 Nurse Room	7/6/16 7:32 AM	8/10/16	38725	COPPER	0.009	1.3	mg/L	16-16101
High School	HS-11 Small Commons	7/6/16 7:35 AM	8/10/16	38726	COPPER	0.202	1.3	mg/L	16-16101
High School	HS-12 Small Commons	7/6/16 7:35 AM	8/10/16	38727	COPPER	0.202	1.3	mg/L	16-16101
High School	HS-13 Bistro	7/6/16 7:38 AM	8/10/16	38728	COPPER	0.166	1.3	mg/L	16-16101
High School	HS-14 Waast Staff Work Rm	7/6/16 7:40 AM	8/10/16	38729	COPPER	0.191	1.3	mg/L	16-16101
High School	HS-15 Waast Staff Lounge	7/6/16 7:42 AM	8/10/16	38730	COPPER	0.282	1.3	mg/L	16-16101
High School	HS-16 Library	7/6/16 7:46 AM	8/10/16	38731	COPPER	0.193	1.3	mg/L	16-16101
High School	HS-17 Room 315	7/6/16 7:59 AM	8/10/16	38732	COPPER	0.206	1.3	mg/L	16-16101
High School	HS-18 Waca Office Staff Rm	7/6/16 8:06 AM	8/10/16	38733	COPPER	0.192	1.3	mg/L	16-16101
High School	HS-20 Lectorium - Front	7/6/16 8:13 AM	8/10/16	38734	COPPER	0.212	1.3	mg/L	16-16101
High School	HS-21 Athletic Trainer	7/6/16 8:20 AM	8/10/16	38735	COPPER	0.033	1.3	mg/L	16-16101
High School	HS-22 Gym Hall	7/6/16 8:23 AM	8/10/16	38736	COPPER	0.197	1.3	mg/L	16-16101
High School	HS-23 Gym Hall	7/6/16 8:24 AM	8/10/16	38737	COPPER	0.196	1.3	mg/L	16-16101
High School	HS-24 Tennis Court	7/6/16 8:32 AM	8/10/16	38738	COPPER	0.058	1.3	mg/L	16-16101
High School	HS-25 CIC - Preschool	7/6/16 8:38 AM	8/10/16	38739	COPPER	0.209	1.3	mg/L	16-16101
High School	HS-26 CIC - Kitchen	7/6/16 8:39 AM	8/10/16	38740	COPPER	0.211	1.3	mg/L	16-16101
High School	HS-27 CIC - Hall	7/6/16 8:40 AM	8/10/16	38741	COPPER	0.248	1.3	mg/L	16-16101
High School	HS-28 CIC - Infant	7/6/16 8:41 AM	8/10/16	38742	COPPER	0.159	1.3	mg/L	16-16101
High School	HS-29 Outside A. Trainer	7/6/16 8:50 AM	8/10/16	38743	COPPER	0.087	1.3	mg/L	16-16101
High School	HS-30 Mod 906	7/6/16 9:01 AM	8/10/16	38744	COPPER	0.077	1.3	mg/L	16-16101
High School	HS-31 S-W Hall	7/6/16 9:09 AM	8/11/16	38745	COPPER	0.156	1.3	mg/L	16-16101
High School	HS-32 S-W Hall	7/6/16 9:09 AM	8/11/16	38746	COPPER	0.143	1.3	mg/L	16-16101
High School	HS-33 S-N Hall	7/6/16 9:13 AM	8/11/16	38747	COPPER	0.126	1.3	mg/L	16-16101
High School	HS-34 S-N Hall	7/6/16 9:13 AM	8/11/16	38748	COPPER	0.113	1.3	mg/L	16-16101
High School	HS-35 Multi-purpose	7/6/16 9:15 AM	8/11/16	38749	COPPER	0.103	1.3	mg/L	16-16101
High School	HS-36 Staff Lounge	7/6/16 9:19 AM	8/11/16	38750	COPPER	0.161	1.3	mg/L	16-16101
High School	HS-37 N-S Hall	7/6/16 9:20 AM	8/11/16	38751	COPPER	0.200	1.3	mg/L	16-16101
High School	HS-38 N-S Hall	7/6/16 9:20 AM	8/11/16	38752	COPPER	0.200	1.3	mg/L	16-16101
High School	HS-39 Counselor	7/6/16 9:22 AM	8/11/16	38753	COPPER	0.217	1.3	mg/L	16-16101
Lincoln	L1 Room 1	7/6/16 7:00 AM	8/11/16	38774	COPPER	0.268	1.3	mg/L	16-16111
Lincoln	L2 Room 2	7/6/16 7:00 AM	8/11/16	38775	COPPER	0.154	1.3	mg/L	16-16111
Lincoln	L3 Hallway	7/6/16 7:00 AM	8/11/16	38776	COPPER	0.013	1.3	mg/L	16-16111
Lincoln	L4 Office	7/6/16 7:00 AM	8/11/16	38777	COPPER	0.070	1.3	mg/L	16-16111
Lincoln	L5 Office	7/6/16 7:00 AM	8/11/16	38778	COPPER	ND	1.3	mg/L	16-16111
Lincoln	L6 Room 6	7/6/16 7:00 AM	8/11/16	38779	COPPER	0.192	1.3	mg/L	16-16111
Lincoln	L10 Room 10	7/6/16 7:00 AM	8/11/16	38780	COPPER	0.124	1.3	mg/L	16-16111
Lincoln	L11 Hallway	7/6/16 7:20 AM	8/11/16	38781	COPPER	0.238	1.3	mg/L	16-16111
Lincoln	L12 Hallway	7/6/16 7:20 AM	8/11/16	38782	COPPER	0.254	1.3	mg/L	16-16111

Lincoln	L13 Room 14	7/6/16 7:22 AM	8/11/16	38783	COPPER	0.146	1.3	mg/L	16-16111
Lincoln	L14 Room 16	7/6/16 7:25 AM	8/11/16	38784	COPPER	0.056	1.3	mg/L	16-16111
Lincoln	L15 Room 18	7/6/16 7:28 AM	8/11/16	38785	COPPER	0.167	1.3	mg/L	16-16111
Lincoln	L16 Hallway	7/6/16 7:30 AM	8/11/16	38786	COPPER	0.089	1.3	mg/L	16-16111
Lincoln	L17 Room 19	7/6/16 7:30 AM	8/11/16	38787	COPPER	0.239	1.3	mg/L	16-16111
Lincoln	L18 Room 20	7/6/16 7:40 AM	8/11/16	38788	COPPER	0.198	1.3	mg/L	16-16111
Lincoln	L19 Room 17	7/6/16 7:40 AM	8/11/16	38789	COPPER	0.199	1.3	mg/L	16-16111
Lincoln	L20 Room 15	7/6/16 7:40 AM	8/11/16	38790	COPPER	0.205	1.3	mg/L	16-16111
Lincoln	L21 Hallway	7/6/16 7:45 AM	8/11/16	38791	COPPER	0.250	1.3	mg/L	16-16111
Lincoln	L22 Hallway	7/6/16 7:45 AM	8/11/16	38792	COPPER	0.274	1.3	mg/L	16-16111
Lincoln	L23 Staff Lounge	7/6/16 7:48 AM	8/11/16	38793	COPPER	0.063	1.3	mg/L	16-16111
Lincoln	L24 Staff Lounge	7/6/16 7:48 AM	8/11/16	38794	COPPER	ND	1.3	mg/L	16-16111
Lincoln	L25 Kitchen	7/6/16 7:55 AM	8/11/16	38795	COPPER	0.132	1.3	mg/L	16-16111
Lincoln	L26 Kitchen	7/6/16 7:58 AM	8/11/16	38796	COPPER	0.134	1.3	mg/L	16-16111
Lincoln	L27 Kitchen	7/6/16 8:00 AM	8/11/16	38797	COPPER	0.143	1.3	mg/L	16-16111
Lincoln	L28 Kitchen	7/6/16 8:00 AM	8/11/16	38798	COPPER	0.181	1.3	mg/L	16-16111
Lincoln	L29 Kitchen	7/6/16 8:00 AM	8/11/16	38799	COPPER	0.187	1.3	mg/L	16-16111
Lincoln	L30 Cafeteria	7/6/16 8:05 AM	8/11/16	38800	COPPER	0.013	1.3	mg/L	16-16111
Lincoln	L31 Hallway	7/6/16 8:15 AM	8/12/16	38801	COPPER	4.126	1.3	mg/L	16-16111
Lincoln	L32 Gym	7/6/16 8:15 AM	8/11/16	38802	COPPER	0.040	1.3	mg/L	16-16111
Lincoln	L33 Room 42	7/6/16 8:30 AM	8/11/16	38803	COPPER	0.278	1.3	mg/L	16-16111
Nellie	N1 Room 17	7/6/16 6:30 AM	8/11/16	38808	COPPER	0.011	1.3	mg/L	16-16116
Nellie	N2 Staff Room	7/6/16 6:36 AM	8/11/16	38809	COPPER	ND	1.3	mg/L	16-16116
Nellie	N3 Room 18	7/6/16 6:42 AM	8/11/16	38810	COPPER	0.022	1.3	mg/L	16-16116
Nellie	N4 Room 19	7/6/16 6:48 AM	8/11/16	38811	COPPER	0.020	1.3	mg/L	16-16116
Nellie	N5 Kinder Hallway Tall Fountain	7/6/16 6:54 AM	8/11/16	38812	COPPER	0.169	1.3	mg/L	16-16116
Nellie	N6 Kinder Hallway Short Fountain	7/6/16 6:56 AM	8/11/16	38813	COPPER	0.153	1.3	mg/L	16-16116
Nellie	N7 Room 2	7/6/16 7:00 AM	8/11/16	38814	COPPER	0.013	1.3	mg/L	16-16116
Nellie	N8 Room 3	7/6/16 7:04 AM	8/11/16	38815	COPPER	0.008	1.3	mg/L	16-16116
Nellie	N9 Room 5	7/6/16 7:08 AM	8/11/16	38816	COPPER	0.007	1.3	mg/L	16-16116
Nellie	N10 Room 6	7/6/16 7:12 AM	8/11/16	38817	COPPER	0.018	1.3	mg/L	16-16116
Nellie	N11 Room 7	7/6/16 7:16 AM	8/11/16	38818	COPPER	0.018	1.3	mg/L	16-16116
Nellie	N12 Library Hallway Tall Fountain	7/6/16 7:23 AM	8/11/16	38819	COPPER	0.125	1.3	mg/L	16-16116
Nellie	N13 Library Hallway Short Fountain	7/6/16 7:24 AM	8/11/16	38820	COPPER	0.114	1.3	mg/L	16-16116
Nellie	N14 Room 9	7/6/16 7:30 AM	8/11/16	38821	COPPER	0.020	1.3	mg/L	16-16116
Nellie	N15 Room 10	7/6/16 7:34 AM	8/11/16	38822	COPPER	0.026	1.3	mg/L	16-16116
Nellie	N16 Room 11	7/6/16 7:37 AM	8/11/16	38823	COPPER	0.049	1.3	mg/L	16-16116
Nellie	N17 Room 13	7/6/16 7:42 AM	8/11/16	38824	COPPER	0.040	1.3	mg/L	16-16116
Nellie	N18 Room 12	7/6/16 7:48 AM	8/11/16	38825	COPPER	0.023	1.3	mg/L	16-16116
Nellie	N19 Room 14	7/6/16 7:53 AM	8/11/16	38826	COPPER	0.039	1.3	mg/L	16-16116
Nellie	N20 Room 15	7/6/16 7:58 AM	8/11/16	38827	COPPER	0.015	1.3	mg/L	16-16116
Nellie	N21 Cafeteria	7/6/16 8:01 AM	8/11/16	38828	COPPER	0.126	1.3	mg/L	16-16116

Nellie	N22 Kitchen Steamer - Back	7/6/16 8:06 AM	8/11/16	38829	COPPER	0.135	1.3	mg/L	16-16116
Nellie	N23 Kitchen Steamer - Back	7/6/16 8:07 AM	8/11/16	38830	COPPER	0.100	1.3	mg/L	16-16116
Nellie	N24 Kitchen Triple Sink	7/6/16 8:13 AM	8/11/16	38831	COPPER	0.069	1.3	mg/L	16-16116
Nellie	N25 Kitchen Triple Sink	7/6/16 8:15 AM	8/11/16	38832	COPPER	0.039	1.3	mg/L	16-16116
CIP	C-1 Kitchen 1	8/5/16 8:35 AM	8/22/16	48381	COPPER	0.136	1.3	mg/L	16-19952
CIP	c-2 Kitchen 2	8/5/16 8:36 AM	8/22/16	48382	COPPER	0.095	1.3	mg/L	16-19952
CIP	C-3 Kitchen 3	8/5/16 8:36 AM	8/22/16	48383	COPPER	0.105	1.3	mg/L	16-19952
CIP	C-4 Custodian	8/5/16 8:38 AM	8/22/16	48384	COPPER	0.061	1.3	mg/L	16-19952
CIP	C-5 Fountain Hall	8/5/16 8:39 AM	8/22/16	48385	COPPER	0.162	1.3	mg/L	16-19952
CIP	C-6 Fountain S-Hall	8/5/16 8:38 AM	8/22/16	48386	COPPER	0.100	1.3	mg/L	16-19952
CIP	C-7 Class 1 east	8/5/16 8:41 AM	8/22/16	48387	COPPER	0.235	1.3	mg/L	16-19952
CIP	C-8 Class 1 North	8/5/16 8:42 AM	8/22/16	48388	COPPER	0.215	1.3	mg/L	16-19952
CIP	C-9 Br Middle	8/5/16 8:43 AM	8/22/16	48389	COPPER	0.173	1.3	mg/L	16-19952
CIP	C-10 Br middle 2	8/5/16 8:46 AM	8/22/16	48390	COPPER	0.180	1.3	mg/L	16-19952
CIP	C-11 Class middle 1	8/5/16 8:44 AM	8/22/16	48391	COPPER	0.082	1.3	mg/L	16-19952
CIP	C-12 Class middle 2	8/5/16 8:45 AM	8/22/16	48392	COPPER	0.067	1.3	mg/L	16-19952
CIP	C-13 Bath 1	8/5/16 8:45 AM	8/22/16	48393	COPPER	0.232	1.3	mg/L	16-19952
CIP	C-14 Bath 2	8/5/16 8:46 AM	8/22/16	48394	COPPER	0.236	1.3	mg/L	16-19952
CIP	C-15 Class 3 west	8/5/16 8:47 AM	8/22/16	48395	COPPER	0.141	1.3	mg/L	16-19952
CIP	C-16 Class 3 East	8/5/16 8:48 AM	8/23/16	48396	COPPER	0.063	1.3	mg/L	16-19952
WES	20 wes	8/4/16 11:12 AM	8/22/16	48408	COPPER	0.070	1.3	mg/L	16-19954
WES	73 wes	8/4/16 12:30 PM	8/22/16	48409	COPPER	ND	1.3	mg/L	16-19954
WES	74 wes	8/4/16 12:34 PM	8/22/16	48410	COPPER	0.017	1.3	mg/L	16-19954
WES	75 wes	8/4/16 12:41 PM	8/22/16	48411	COPPER	ND	1.3	mg/L	16-19954
WES	76 wes	8/4/16 10:04 AM	8/22/16	48412	COPPER	0.014	1.3	mg/L	16-19954
WES	77 wes	8/4/16 10:08 AM	8/22/16	48413	COPPER	0.011	1.3	mg/L	16-19954
WES	78 wes	8/4/16 10:00 AM	8/22/16	48414	COPPER	0.022	1.3	mg/L	16-19954
WES	79 wes	8/4/16 10:00 AM	8/22/16	48415	COPPER	0.045	1.3	mg/L	16-19954
WES	80 wes	8/4/16 12:37 PM	8/22/16	48416	COPPER	0.121	1.3	mg/L	16-19954
WES	81 wes	8/4/16 12:32 PM	8/22/16	48417	COPPER	0.051	1.3	mg/L	16-19954
WES	63 wes	8/4/16 10:38 AM	8/22/16	48418	COPPER	0.011	1.3	mg/L	16-19954
WES	64 wes	8/4/16 10:40 AM	8/22/16	48419	COPPER	0.009	1.3	mg/L	16-19954
WES	65 wes	8/4/16 10:44 AM	8/22/16	48420	COPPER	0.033	1.3	mg/L	16-19954
WES	66 wes	8/4/16 10:45 AM	8/22/16	48421	COPPER	0.056	1.3	mg/L	16-19954
WES	72 wes	8/4/16 10:48 AM	8/22/16	48422	COPPER	0.025	1.3	mg/L	16-19954
WES	67 wes	8/4/16 10:50 AM	8/22/16	48423	COPPER	0.032	1.3	mg/L	16-19954
WES	68 wes	8/4/16 10:52 AM	8/22/16	48424	COPPER	0.050	1.3	mg/L	16-19954
WES	69 wes	8/4/16 10:57 AM	8/22/16	48425	COPPER	0.015	1.3	mg/L	16-19954
WES	18 wes	8/4/16 11:11 AM	8/22/16	48426	COPPER	0.009	1.3	mg/L	16-19954
WES	19 wes	8/4/16 11:12 AM	8/22/16	48427	COPPER	0.039	1.3	mg/L	16-19954
WES	54 wes	8/4/16 9:47 AM	8/22/16	48428	COPPER	0.022	1.3	mg/L	16-19954
WES	71 wes	8/4/16 9:49 AM	8/22/16	48429	COPPER	0.019	1.3	mg/L	16-19954

WES	55 wes	8/4/16 9:52 AM	8/22/16	48430	COPPER	0.246	1.3	mg/L	16-19954
WES	56 wes	8/4/16 9:54 AM	8/22/16	48431	COPPER	0.164	1.3	mg/L	16-19954
WES	57 wes	8/4/16 9:55 AM	8/22/16	48432	COPPER	0.161	1.3	mg/L	16-19954
WES	58 wes	8/4/16 9:58 AM	8/22/16	48433	COPPER	0.013	1.3	mg/L	16-19954
WES	59 wes	8/4/16 10:01 AM	8/22/16	48434	COPPER	0.058	1.3	mg/L	16-19954
WES	60 wes	8/4/16 10:05 AM	8/22/16	48435	COPPER	0.012	1.3	mg/L	16-19954
WES	61 wes	8/4/16 10:31 AM	8/22/16	48436	COPPER	0.025	1.3	mg/L	16-19954
WES	62 wes	8/4/16 10:35 AM	8/22/16	48437	COPPER	0.014	1.3	mg/L	16-19954
WES	35 wes	8/4/16 8:45 AM	8/22/16	48438	COPPER	0.062	1.3	mg/L	16-19954
WES	36 wes	8/4/16 8:47 AM	8/22/16	48439	COPPER	0.186	1.3	mg/L	16-19954
WES	40 wes	8/4/16 8:50 AM	8/22/16	48440	COPPER	0.011	1.3	mg/L	16-19954
WES	41 wes	8/4/16 8:51 AM	8/22/16	48441	COPPER	0.016	1.3	mg/L	16-19954
WES	70 wes	8/4/16 8:54 AM	8/22/16	48442	COPPER	0.018	1.3	mg/L	16-19954
WES	37 wes	8/4/16 8:56 AM	8/22/16	48443	COPPER	0.046	1.3	mg/L	16-19954
WES	38 wes	8/4/16 8:59 AM	8/22/16	48444	COPPER	0.011	1.3	mg/L	16-19954
WES	39 wes	8/4/16 9:02 AM	8/22/16	48445	COPPER	ND	1.3	mg/L	16-19954
WES	42 wes	8/4/16 9:11 AM	8/22/16	48446	COPPER	0.020	1.3	mg/L	16-19954
WES	43 wes	8/4/16 9:13 AM	8/22/16	48447	COPPER	0.017	1.3	mg/L	16-19954
WES	16 wes	8/4/16 7:30 AM	8/22/16	48448	COPPER	0.027	1.3	mg/L	16-19954
WES	70 wes	8/4/16 7:34 AM	8/22/16	48449	COPPER	0.027	1.3	mg/L	16-19954
WES	31 wes	8/4/16 7:36 AM	8/22/16	48450	COPPER	0.060	1.3	mg/L	16-19954
WES	30 wes	8/4/16 7:39 AM	8/22/16	48451	COPPER	0.020	1.3	mg/L	16-19954
WES	29 wes	8/4/16 7:43 AM	8/22/16	48452	COPPER	0.011	1.3	mg/L	16-19954
WES	28 wes	8/4/16 8:27 AM	8/22/16	48453	COPPER	0.043	1.3	mg/L	16-19954
WES	69 wes	8/4/16 8:29 AM	8/22/16	48454	COPPER	0.021	1.3	mg/L	16-19954
WES	32 wes	8/4/16 8:32 AM	8/22/16	48455	COPPER	ND	1.3	mg/L	16-19954
WES	33 wes	8/4/16 8:34 AM	8/22/16	48456	COPPER	0.021	1.3	mg/L	16-19954
WES	34 wes	8/4/16 8:42 AM	8/22/16	48457	COPPER	0.102	1.3	mg/L	16-19954
WES	44 wes	8/4/16 9:16 AM	8/22/16	48458	COPPER	0.013	1.3	mg/L	16-19954
WES	45 wes	8/4/16 9:21 AM	8/22/16	48459	COPPER	0.060	1.3	mg/L	16-19954
WES	46 wes	8/4/16 9:24 AM	8/22/16	48460	COPPER	0.017	1.3	mg/L	16-19954
WES	47 wes	8/4/16 9:28 AM	8/22/16	48461	COPPER	0.018	1.3	mg/L	16-19954
WES	48 wes	8/4/16 9:30 AM	8/22/16	48462	COPPER	0.019	1.3	mg/L	16-19954
WES	49 wes	8/4/16 9:33 AM	8/22/16	48463	COPPER	0.025	1.3	mg/L	16-19954
WES	50 wes	8/4/16 9:36 AM	8/22/16	48464	COPPER	0.028	1.3	mg/L	16-19954
WES	51 wes	8/4/16 9:40 AM	8/22/16	48465	COPPER	0.102	1.3	mg/L	16-19954
WES	52 wes	8/4/16 9:42 AM	8/22/16	48466	COPPER	0.103	1.3	mg/L	16-19954
WES	53 wes	8/4/16 9:43 AM	8/22/16	48467	COPPER	0.149	1.3	mg/L	16-19954
Lincoln Elementary School	F-1 Room #1	8/4/16 7:00 AM	8/22/16	49122	COPPER	0.629	1.3	mg/L	16-20213
Lincoln Elementary School	F-2 Office both sinks	8/4/16 7:12 AM	8/22/16	49123	COPPER	0.311	1.3	mg/L	16-20213
Lincoln Elementary School	F-3 Office both sinks	8/4/16 7:12 AM	8/22/16	49124	COPPER	0.705	1.3	mg/L	16-20213
Lincoln Elementary School	F-4 Room #6	8/4/16 7:22 AM	8/22/16	49125	COPPER	0.297	1.3	mg/L	16-20213

Lincoln Elementary School	F-5 Room #6	8/4/16 7:22 AM	8/22/16	49126	COPPER	0.882	1.3	mg/L	16-20213
Lincoln Elementary School	F-6 Room#8	8/4/16 7:30 AM	8/23/16	49127	COPPER	1.29	1.3	mg/L	16-20213
Lincoln Elementary School	F7 Room #10	8/4/16 7:35 AM	8/22/16	49128	COPPER	0.354	1.3	mg/L	16-20213
Lincoln Elementary School	F8 Room #14	8/4/16 7:39 AM	8/22/16	49129	COPPER	0.629	1.3	mg/L	16-20213
Lincoln Elementary School	F9 Room #14	8/4/16 7:39 AM	8/22/16	49130	COPPER	0.980	1.3	mg/L	16-20213
Lincoln Elementary School	F10 Room #16	8/4/16 8:30 AM	8/22/16	49131	COPPER	0.650	1.3	mg/L	16-20213
Lincoln Elementary School	F11 Room #18	8/4/16 8:36 AM	8/22/16	49132	COPPER	0.785	1.3	mg/L	16-20213
Lincoln Elementary School	F12 Room #19	8/4/16 8:39 AM	8/23/16	49133	COPPER	1.21	1.3	mg/L	16-20213
Lincoln Elementary School	F13 Room #19	8/4/16 8:39 AM	8/22/16	49134	COPPER	0.640	1.3	mg/L	16-20213
Lincoln Elementary School	F14 Room #20	8/4/16 8:43 AM	8/22/16	49135	COPPER	0.826	1.3	mg/L	16-20213
Lincoln Elementary School	F15 Room #17	8/4/16 8:47 AM	8/22/16	49136	COPPER	0.362	1.3	mg/L	16-20213
Lincoln Elementary School	F16 Room #15	8/4/16 8:52 AM	8/22/16	49137	COPPER	0.314	1.3	mg/L	16-20213
Lincoln Elementary School	F17 Front Hallway boys both	8/4/16 9:00 AM	8/22/16	49138	COPPER	0.260	1.3	mg/L	16-20213
Lincoln Elementary School	F18 Front Hallway boys both	8/4/16 9:00 AM	8/22/16	49139	COPPER	0.215	1.3	mg/L	16-20213
Lincoln Elementary School	F19 Front Hallway boys both	8/4/16 9:00 AM	8/22/16	49140	COPPER	0.366	1.3	mg/L	16-20213
Lincoln Elementary School	F20 Cost. Closet	8/4/16 9:04 AM	8/22/16	49141	COPPER	0.104	1.3	mg/L	16-20213
Lincoln Elementary School	F21 Front Hallway Grils both	8/4/16 9:08 AM	8/22/16	49142	COPPER	0.092	1.3	mg/L	16-20213
Lincoln Elementary School	F22 Front Hallway Grils both	8/4/16 9:08 AM	8/22/16	49143	COPPER	0.184	1.3	mg/L	16-20213
Lincoln Elementary School	F23 Front Hallway Grils both	8/4/16 9:08 AM	8/22/16	49144	COPPER	0.135	1.3	mg/L	16-20213
Lincoln Elementary School	F24 Back hallway Girls both	8/4/16 9:18 AM	8/22/16	49145	COPPER	0.195	1.3	mg/L	16-20213
Lincoln Elementary School	F25 Back hallway Girls both	8/4/16 9:18 AM	8/22/16	49146	COPPER	0.156	1.3	mg/L	16-20213
Lincoln Elementary School	F26 Back hallway Girls both	8/4/16 9:18 AM	8/22/16	49147	COPPER	0.163	1.3	mg/L	16-20213
Lincoln Elementary School	F27 Cost. Closet retime	8/4/16 9:22 AM	8/22/16	49148	COPPER	0.140	1.3	mg/L	16-20213
Lincoln Elementary School	F28 Cost. Closet retime	8/4/16 9:22 AM	8/22/16	49149	COPPER	0.225	1.3	mg/L	16-20213
Lincoln Elementary School	F29 Back hallway Boys both	8/4/16 9:35 AM	8/22/16	49150	COPPER	0.470	1.3	mg/L	16-20213
Lincoln Elementary School	F30 Back hallway Boys both	8/4/16 9:35 AM	8/22/16	49151	COPPER	0.098	1.3	mg/L	16-20213
Lincoln Elementary School	F31 Room 29	8/4/16 9:40 AM	8/22/16	49152	COPPER	0.120	1.3	mg/L	16-20213
Lincoln Elementary School	F32 Room 32	8/4/16 9:53 AM	8/22/16	49153	COPPER	0.199	1.3	mg/L	16-20213
Lincoln Elementary School	F33 Kitchen	8/4/16 10:05 AM	8/22/16	49154	COPPER	0.191	1.3	mg/L	16-20213
Lincoln Elementary School	F34 Kitchen	8/4/16 10:05 AM	8/22/16	49155	COPPER	0.092	1.3	mg/L	16-20213
Lincoln Elementary School	F35 Kitchen	8/4/16 10:05 AM	8/22/16	49156	COPPER	0.099	1.3	mg/L	16-20213
Lincoln Elementary School	F36 Kitchen	8/4/16 10:05 AM	8/22/16	49157	COPPER	0.249	1.3	mg/L	16-20213
Lincoln Elementary School	F37 Outside kitchen	8/4/16 10:10 AM	8/22/16	49158	COPPER	0.040	1.3	mg/L	16-20213
Lincoln Elementary School	F38 Laundry	8/4/16 10:15 AM	8/22/16	49159	COPPER	0.077	1.3	mg/L	16-20213
Lincoln Elementary School	F39 Garden	8/4/16 10:20 AM	8/22/16	49160	COPPER	0.041	1.3	mg/L	16-20213
Lincoln Elementary School	F40 Gym boys bath	8/4/16 10:40 AM	8/22/16	49161	COPPER	0.029	1.3	mg/L	16-20213
Lincoln Elementary School	F41 Gym boys bath	8/4/16 10:40 AM	8/22/16	49162	COPPER	0.770	1.3	mg/L	16-20213
Lincoln Elementary School	F42 Gym boys bath	8/4/16 10:40 AM	8/22/16	49163	COPPER	0.692	1.3	mg/L	16-20213
Lincoln Elementary School	F43 Gym girls bath	8/4/16 10:55 AM	8/22/16	49164	COPPER	0.399	1.3	mg/L	16-20213
Lincoln Elementary School	F44 Gym girls bath	8/4/16 10:55 AM	8/22/16	49165	COPPER	0.028	1.3	mg/L	16-20213
Lincoln Elementary School	F45 Gym girls bath	8/4/16 10:55 AM	8/22/16	49166	COPPER	0.312	1.3	mg/L	16-20213
Lincoln Elementary School	F46 Gym girls bath	8/4/16 10:55 AM	8/22/16	49167	COPPER	0.027	1.3	mg/L	16-20213



Lincoln Elementary School	F47 Gym girls bath	8/4/16 10:55 AM	8/23/16	49168	COPPER	1.56	1.3	mg/L	16-20213
Lincoln Elementary School	F48 Room 42	8/4/16 11:10 AM	8/22/16	49169	COPPER	0.371	1.3	mg/L	16-20213
Lincoln Elementary School	F49 Kimle boys bath sink	8/4/16 11:15 AM	8/22/16	49170	COPPER	0.243	1.3	mg/L	16-20213
Lincoln Elementary School	F50 Life Skills both	8/4/16 11:20 AM	8/22/16	49171	COPPER	0.503	1.3	mg/L	16-20213
Lincoln Elementary School	F51 P.lot Front school	8/4/16 11:30 AM	8/22/16	49172	COPPER	0.140	1.3	mg/L	16-20213
Lincoln Elementary School	F52 P.lot Front school	8/4/16 11:30 AM	8/22/16	49173	COPPER	0.021	1.3	mg/L	16-20213
FPMS	F1 Custodian office	8/4/16 7:35 AM	8/22/16	49174	COPPER	0.089	1.3	mg/L	16-20214
FPMS	F2 Commons	8/4/16 7:45 AM	8/22/16	49175	COPPER	0.159	1.3	mg/L	16-20214
FPMS	F3 Dish room	8/4/16 7:50 AM	8/22/16	49176	COPPER	0.201	1.3	mg/L	16-20214
FPMS	F4 Dish room	8/4/16 7:50 AM	8/22/16	49177	COPPER	0.201	1.3	mg/L	16-20214
FPMS	F5 Kitchen	8/4/16 7:52 AM	8/22/16	49178	COPPER	0.189	1.3	mg/L	16-20214
FPMS	F6 Kitchen	8/4/16 7:53 AM	8/22/16	49179	COPPER	0.231	1.3	mg/L	16-20214
FPMS	F7 FP Office	8/4/16 7:55 AM	8/22/16	49180	COPPER	0.309	1.3	mg/L	16-20214
FPMS	F8 Staff room	8/4/16 7:56 AM	8/22/16	49181	COPPER	0.243	1.3	mg/L	16-20214
FPMS	F9 Staff room	8/4/16 7:57 AM	8/22/16	49182	COPPER	ND	1.3	mg/L	16-20214
FPMS	F10 Boile Rm	8/4/16 8:00 AM	8/22/16	49183	COPPER	0.021	1.3	mg/L	16-20214
FPMS	F11 Room 28	8/4/16 11:15 AM	8/22/16	49184	COPPER	0.303	1.3	mg/L	16-20214
FPMS	F12 Room 28	8/4/16 11:15 AM	8/22/16	49185	COPPER	0.206	1.3	mg/L	16-20214
FPMS	F13 Room 28	8/4/16 11:16 AM	8/22/16	49186	COPPER	0.203	1.3	mg/L	16-20214
FPMS	F14 Room 28	8/4/16 11:16 AM	8/22/16	49187	COPPER	0.205	1.3	mg/L	16-20214
FPMS	F15 Hall C	8/4/16 10:20 AM	8/22/16	49188	COPPER	0.263	1.3	mg/L	16-20214
FPMS	F16 Rm 31	8/4/16 11:24 AM	8/22/16	49189	COPPER	0.063	1.3	mg/L	16-20214
FPMS	F17 Rm 35	8/4/16 11:25 AM	8/22/16	49190	COPPER	0.247	1.3	mg/L	16-20214
FPMS	F18 Hall D	8/4/16 11:26 AM	8/22/16	49191	COPPER	0.232	1.3	mg/L	16-20214
FPMS	F19 Rm 24	8/4/16 11:38 AM	8/22/16	49192	COPPER	0.145	1.3	mg/L	16-20214
FPMS	F20 Rm 25	8/4/16 11:30 AM	8/22/16	49193	COPPER	0.099	1.3	mg/L	16-20214
FPMS	F21 Rm 9	8/4/16 11:50 AM	8/22/16	49194	COPPER	0.239	1.3	mg/L	16-20214
FPMS	F22 Rm 12	8/4/16 11:55 AM	8/22/16	49195	COPPER	0.509	1.3	mg/L	16-20214
FPMS	F23 Rm 12	8/4/16 11:56 AM	8/22/16	49196	COPPER	0.382	1.3	mg/L	16-20214
FPMS	F24 Rm 34	8/4/16 12:58 PM	8/22/16	49197	COPPER	0.211	1.3	mg/L	16-20214
FPMS	F25 Rm 34	8/4/16 12:58 PM	8/22/16	49198	COPPER	0.265	1.3	mg/L	16-20214
FPMS	F26 Hall D Boy R-R	8/4/16 1:08 PM	8/22/16	49199	COPPER	0.102	1.3	mg/L	16-20214
FPMS	F27 Hall D Girl R-R	8/4/16 1:09 PM	8/22/16	49200	COPPER	0.187	1.3	mg/L	16-20214
FPMS	F28 Hall D Custodin Closet	8/4/16 1:15 PM	8/22/16	49201	COPPER	0.099	1.3	mg/L	16-20214
FPMS	F29 Rm 36	8/4/16 1:18 PM	8/22/16	49202	COPPER	0.270	1.3	mg/L	16-20214
FPMS	F30 Rm 36	8/4/16 1:19 PM	8/22/16	49203	COPPER	0.272	1.3	mg/L	16-20214
FPMS	F31 Boy Shower Rm	8/4/16 10:57 AM	8/22/16	49204	COPPER	0.065	1.3	mg/L	16-20214
FPMS	F32 Boy Shower Rm	8/4/16 10:57 AM	8/22/16	49205	COPPER	0.088	1.3	mg/L	16-20214
FPMS	F33 Boy Shower Rm	8/4/16 11:02 AM	8/22/16	49206	COPPER	0.322	1.3	mg/L	16-20214
FPMS	F34 Boy Shower Rm	8/4/16 11:02 AM	8/22/16	49207	COPPER	0.318	1.3	mg/L	16-20214
FPMS	F35 Boy Shower Rm	8/4/16 11:04 AM	8/22/16	49208	COPPER	0.430	1.3	mg/L	16-20214
FPMS	F36 Boy Shower Rm	8/4/16 11:02 AM	8/22/16	49209	COPPER	0.134	1.3	mg/L	16-20214

FPMS	F37 Boy Locker -r	8/4/16 11:06 AM	8/22/16	49210	COPPER	0.086	1.3	mg/L	16-20214
FPMS	F38 Boy Locker -r	8/4/16 11:06 AM	8/22/16	49211	COPPER	0.106	1.3	mg/L	16-20214
FPMS	F39 Hall C-w-rest Rm	8/4/16 11:14 AM	8/22/16	49212	COPPER	0.026	1.3	mg/L	16-20214
FPMS	F40 Hall C-M rest Rm	8/4/16 11:10 AM	8/22/16	49213	COPPER	0.155	1.3	mg/L	16-20214
FPMS	F41 DO Kitchen	8/4/16 8:05 AM	8/22/16	49214	COPPER	0.054	1.3	mg/L	16-20214
FPMS	F42 DO Restroom 1	8/4/16 8:07 AM	8/22/16	49215	COPPER	0.076	1.3	mg/L	16-20214
FPMS	F43 DO Restroom 2	8/4/16 8:08 AM	8/22/16	49216	COPPER	0.075	1.3	mg/L	16-20214
FPMS	F44 Hall A Staff RR	8/4/16 8:37 AM	8/22/16	49217	COPPER	0.215	1.3	mg/L	16-20214
FPMS	F45 Hall A	8/4/16 8:55 AM	8/22/16	49218	COPPER	0.103	1.3	mg/L	16-20214
FPMS	F46 Hall A Boy RR	8/4/16 8:41 AM	8/22/16	49219	COPPER	0.057	1.3	mg/L	16-20214
FPMS	F47 Hall A Boy RR	8/4/16 8:41 AM	8/22/16	49220	COPPER	0.044	1.3	mg/L	16-20214
FPMS	F48 Hall A Boy RR	8/4/16 8:41 AM	8/22/16	49221	COPPER	0.097	1.3	mg/L	16-20214
FPMS	F49 Hall A Custodial Closet	8/4/16 8:43 AM	8/22/16	49222	COPPER	0.045	1.3	mg/L	16-20214
FPMS	F50 Hall Girl RR	8/4/16 8:44 AM	8/22/16	49223	COPPER	0.094	1.3	mg/L	16-20214
FPMS	F51 Girl Shower RM	8/4/16 10:34 AM	8/22/16	49224	COPPER	0.065	1.3	mg/L	16-20214
FPMS	F52 Girl Shower RM	8/4/16 10:34 AM	8/22/16	49225	COPPER	0.097	1.3	mg/L	16-20214
FPMS	F53 Girl Shower RM	8/4/16 10:34 AM	8/22/16	49226	COPPER	0.030	1.3	mg/L	16-20214
FPMS	F54 Boy Coach Shower RM	8/4/16 10:45 AM	8/22/16	49227	COPPER	0.014	1.3	mg/L	16-20214
FPMS	F55 Boy Coach RR	8/4/16 10:45 AM	8/22/16	49228	COPPER	0.071	1.3	mg/L	16-20214
FPMS	F56 Boy Shower RM	8/4/16 10:54 AM	8/22/16	49229	COPPER	0.032	1.3	mg/L	16-20214
FPMS	F57 Boy Shower RM	8/4/16 10:54 AM	8/22/16	49230	COPPER	0.075	1.3	mg/L	16-20214
FPMS	F58 Boy Shower RM	8/4/16 10:54 AM	8/22/16	49231	COPPER	0.055	1.3	mg/L	16-20214
FPMS	F59 Boy Shower RM	8/4/16 10:57 AM	8/22/16	49232	COPPER	0.086	1.3	mg/L	16-20214
FPMS	F60 Boy Shower RM	8/4/16 10:57 AM	8/22/16	49233	COPPER	0.526	1.3	mg/L	16-20214
FPMS	F61 Gym	8/4/16 10:10 AM	8/22/16	49234	COPPER	0.029	1.3	mg/L	16-20214
FPMS	F62 Coach RR Girls	8/4/16 10:18 AM	8/22/16	49235	COPPER	0.331	1.3	mg/L	16-20214
FPMS	F63 Girl Locker RM	8/4/16 10:20 AM	8/22/16	49236	COPPER	0.213	1.3	mg/L	16-20214
FPMS	F64 Girl Locker RM	8/4/16 10:20 AM	8/22/16	49237	COPPER	0.114	1.3	mg/L	16-20214
FPMS	F65 Girl Shower RM	8/4/16 10:30 AM	8/22/16	49238	COPPER	0.108	1.3	mg/L	16-20214
FPMS	F66 Girl Shower RM	8/4/16 10:30 AM	8/22/16	49239	COPPER	0.264	1.3	mg/L	16-20214
FPMS	F67 Girl Shower RM	8/4/16 10:30 AM	8/22/16	49240	COPPER	0.061	1.3	mg/L	16-20214
FPMS	F68 Girl Shower RM	8/4/16 10:32 AM	8/22/16	49241	COPPER	0.134	1.3	mg/L	16-20214
FPMS	F69 Girl Shower RM	8/4/16 10:32 AM	8/22/16	49242	COPPER	0.515	1.3	mg/L	16-20214
FPMS	F70 Girl Shower RM	8/4/16 10:32 AM	8/22/16	49243	COPPER	0.243	1.3	mg/L	16-20214
FPMS	F71 Hall A Girls RR	8/4/16 8:46 AM	8/22/16	49244	COPPER	0.083	1.3	mg/L	16-20214
FPMS	F72 Hall A Girls RR	8/4/16 8:46 AM	8/22/16	49245	COPPER	0.104	1.3	mg/L	16-20214
FPMS	F73 Room 6	8/4/16 8:52 AM	8/22/16	49246	COPPER	0.076	1.3	mg/L	16-20214
FPMS	F74 Hall A	8/4/16 8:55 AM	8/22/16	49247	COPPER	0.100	1.3	mg/L	16-20214
FPMS	F75 Hall A	8/4/16 8:39 AM	8/22/16	49248	COPPER	0.028	1.3	mg/L	16-20214
FPMS	F76 Room 4	8/4/16 9:23 AM	8/22/16	49249	COPPER	0.185	1.3	mg/L	16-20214
FPMS	F77 Room 4	8/4/16 9:25 AM	8/22/16	49250	COPPER	0.235	1.3	mg/L	16-20214
FPMS	F78 Room 16	8/4/16 9:51 AM	8/22/16	49251	COPPER	0.145	1.3	mg/L	16-20214

FPMS	F79 Hall B girl R/R	8/4/16 9:54 AM	8/22/16	49252	COPPER	0.041	1.3	mg/L	16-20214
FPMS	F80 Hall B girl R/R	8/4/16 9:54 AM	8/22/16	49253	COPPER	0.059	1.3	mg/L	16-20214
FPMS	F81 Hall B girl R/R	8/4/16 9:55 AM	8/22/16	49254	COPPER	0.080	1.3	mg/L	16-20214
FPMS	F82 Hall B boy R/R	8/4/16 9:59 AM	8/22/16	49255	COPPER	0.057	1.3	mg/L	16-20214
FPMS	F83 Hall B boy R/R	8/4/16 9:59 AM	8/22/16	49256	COPPER	0.067	1.3	mg/L	16-20214
FPMS	F84 Hall B boy R/R	8/4/16 9:59 AM	8/22/16	49257	COPPER	0.044	1.3	mg/L	16-20214
FPMS	F85 Hall B	8/4/16 10:04 AM	8/22/16	49258	COPPER	0.105	1.3	mg/L	16-20214
FPMS	F86 Hall B	8/4/16 10:06 AM	8/22/16	49259	COPPER	0.090	1.3	mg/L	16-20214
FPMS	F87 Custodic closet hall B	8/4/16 10:07 AM	8/22/16	49260	COPPER	0.025	1.3	mg/L	16-20214
FPMS	F88 Gym	8/4/16 10:09 AM	8/22/16	49261	COPPER	0.006	1.3	mg/L	16-20214
FPMS	F89 Gym	8/4/16 10:09 AM	8/22/16	49262	COPPER	0.011	1.3	mg/L	16-20214
FPMS	F90 Gym	8/4/16 10:00 AM	8/22/16	49263	COPPER	0.031	1.3	mg/L	16-20214
FPMS	F91 Rm 48	8/4/16 1:20 PM	8/22/16	49264	COPPER	0.275	1.3	mg/L	16-20214
FPMS	F92 girl shower locker	8/4/16 10:35 AM	8/22/16	49265	COPPER	0.114	1.3	mg/L	16-20214
O-Welcome	O-1 Fountain	8/5/16 8:00 AM	8/22/16	49266	COPPER	0.351	1.3	mg/L	16-20215
O-Welcome	O-2 Front Br	8/5/16 8:01 AM	8/22/16	49267	COPPER	0.086	1.3	mg/L	16-20215
O-Welcome	O-3 Kitchen	8/5/16 8:02 AM	8/22/16	49268	COPPER	0.082	1.3	mg/L	16-20215
O-Welcome	O-4 Back Br	8/5/16 8:02 AM	8/22/16	49269	COPPER	0.044	1.3	mg/L	16-20215
O-Welcome	O-5 East Hose BB	8/5/16 8:05 AM	8/22/16	49270	COPPER	0.172	1.3	mg/L	16-20215
O-Welcome	O-6 North Hose BB	8/5/16 8:06 AM	8/22/16	49271	COPPER	0.141	1.3	mg/L	16-20215
Nellie	N26 S Outside D/Fountain	8/4/16 8:09 AM	8/25/16	50575	COPPER	0.007	1.3	mg/L	16-20664
Nellie	N27 S Outside Spicket	8/4/16 8:10 AM	8/25/16	50576	COPPER	0.023	1.3	mg/L	16-20664
Nellie	N28 Kitchen Sprayer	8/4/16 8:16 AM	8/25/16	50577	COPPER	0.014	1.3	mg/L	16-20664
Nellie	N29 Handwash Sink	8/4/16 8:17 AM	8/25/16	50578	COPPER	0.026	1.3	mg/L	16-20664
Nellie	N30 Kitchen Floor Sink	8/4/16 8:18 AM	8/25/16	50579	COPPER	0.044	1.3	mg/L	16-20664
Nellie	N31 Room 17 Water Faucet	8/4/16 8:24 AM	8/25/16	50580	COPPER	0.013	1.3	mg/L	16-20664
Nellie	N32 Staff Room w/Faucet	8/4/16 8:27 AM	8/25/16	50581	COPPER	0.016	1.3	mg/L	16-20664
Nellie	N33 Office Nurse Station Faucet	8/4/16 8:30 AM	8/25/16	50582	COPPER	0.007	1.3	mg/L	16-20664
Nellie	N34 Kinder Custodial Closet	8/4/16 8:37 AM	8/25/16	50583	COPPER	0.022	1.3	mg/L	16-20664
Nellie	N35 Handicap Restroom Sink	8/4/16 8:40 AM	8/25/16	50584	COPPER	0.102	1.3	mg/L	16-20664
Nellie	N36 Handicap Restroom Shower	8/4/16 8:41 AM	8/25/16	50585	COPPER	0.166	1.3	mg/L	16-20664
Nellie	N37 Room 19 w/Faucet	8/4/16 8:44 AM	8/25/16	50586	COPPER	0.032	1.3	mg/L	16-20664
Nellie	N38 Room 18 w/Faucet	8/4/16 8:45 AM	8/24/16	50587	COPPER	0.032	1.3	mg/L	16-20664
Nellie	N39 Outside Staff Room Spicket	8/4/16 8:51 AM	8/24/16	50588	COPPER	0.009	1.3	mg/L	16-20664
Nellie	N40 Outside Room 325 Spicket	8/4/16 8:52 AM	8/24/16	50589	COPPER	0.005	1.3	mg/L	16-20664
Nellie	N41 Room 3 w/Faucet	8/4/16 8:55 AM	8/24/16	50590	COPPER	0.008	1.3	mg/L	16-20664
Nellie	N42 Room 2 w/Faucet	8/4/16 8:57 AM	8/24/16	50591	COPPER	0.011	1.3	mg/L	16-20664
Nellie	N43 Room 5 w/Faucet	8/4/16 9:01 AM	8/24/16	50592	COPPER	ND	1.3	mg/L	16-20664
Nellie	N44 Room 6 w/Faucet	8/4/16 9:02 AM	8/24/16	50593	COPPER	0.005	1.3	mg/L	16-20664
Nellie	N45 Room 7 Faucet	8/4/16 9:05 AM	8/24/16	50594	COPPER	0.018	1.3	mg/L	16-20664
Nellie	N46 Room 7-A Faucet	8/4/16 9:06 AM	8/24/16	50595	COPPER	0.006	1.3	mg/L	16-20664
Nellie	N47 Library Hall Custodial Closet	8/4/16 9:10 AM	8/24/16	50596	COPPER	ND	1.3	mg/L	16-20664

Nellie	N48 Library back room Faucet	8/4/16 9:11 AM	8/24/16	50597	COPPER	0.005	1.3	mg/L	16-20664
Nellie	N49 Room 9 w/Faucet	8/4/16 9:15 AM	8/24/16	50598	COPPER	0.025	1.3	mg/L	16-20664
Nellie	N50 Room 10 Faucet	8/4/16 9:17 AM	8/24/16	50599	COPPER	0.025	1.3	mg/L	16-20664
Nellie	N51 Room 11 Faucet	8/4/16 9:20 AM	8/24/16	50600	COPPER	0.015	1.3	mg/L	16-20664
Nellie	N52 Room 13 Faucet	8/4/16 9:21 AM	8/24/16	50601	COPPER	0.038	1.3	mg/L	16-20664
Nellie	N53 Room 12 Faucet	8/4/16 9:22 AM	8/24/16	50602	COPPER	0.039	1.3	mg/L	16-20664
Nellie	N54 Room 14 Faucet	8/4/16 9:35 AM	8/24/16	50603	COPPER	0.033	1.3	mg/L	16-20664
Nellie	N55 Room 15 Faucet	8/4/16 9:36 AM	8/24/16	50604	COPPER	0.024	1.3	mg/L	16-20664
Nellie	N56 East Courtyard	8/4/16 9:38 AM	8/24/16	50605	COPPER	0.024	1.3	mg/L	16-20664
Nellie	N57 West Courtyard	8/4/16 9:41 AM	8/24/16	50606	COPPER	0.055	1.3	mg/L	16-20664
Nellie	N58 Custodial Office	8/4/16 9:43 AM	8/24/16	50607	COPPER	0.036	1.3	mg/L	16-20664
Nellie	N59 Office "A" Restroom	8/4/16 1:15 PM	8/24/16	50608	COPPER	0.024	1.3	mg/L	16-20664
Nellie	N60 Office "B" Restroom	8/4/16 1:16 PM	8/24/16	50609	COPPER	0.028	1.3	mg/L	16-20664
Nellie	N61 Kinder Boy's Restroom	8/4/16 1:20 PM	8/24/16	50610	COPPER	0.011	1.3	mg/L	16-20664
Nellie	N62 Kinder Boy's Restroom	8/4/16 1:20 PM	8/24/16	50611	COPPER	0.009	1.3	mg/L	16-20664
Nellie	N63 Kinder Boy's Restroom	8/4/16 1:21 PM	8/24/16	50612	COPPER	0.014	1.3	mg/L	16-20664
Nellie	N64 Kinder Girl's Restroom	8/4/16 1:27 PM	8/24/16	50613	COPPER	0.010	1.3	mg/L	16-20664
Nellie	N65 Kinder Girl's Restroom	8/4/16 1:27 PM	8/24/16	50614	COPPER	0.012	1.3	mg/L	16-20664
Nellie	N66 Kinder Girl's Restroom	8/4/16 1:28 PM	8/24/16	50615	COPPER	0.010	1.3	mg/L	16-20664
Nellie	N67 Library Boy's Restroom	8/4/16 1:38 PM	8/24/16	50616	COPPER	0.009	1.3	mg/L	16-20664
Nellie	N68 Library Boy's Restroom	8/4/16 1:38 PM	8/24/16	50617	COPPER	0.010	1.3	mg/L	16-20664
Nellie	N69 Library Boy's Restroom	8/4/16 1:39 PM	8/24/16	50618	COPPER	0.012	1.3	mg/L	16-20664
Nellie	N70 Library Girl's Restroom	8/4/16 1:44 PM	8/24/16	50619	COPPER	0.021	1.3	mg/L	16-20664
Nellie	N71 Library Girl's Restroom	8/4/16 1:44 PM	8/24/16	50620	COPPER	0.020	1.3	mg/L	16-20664
Nellie	N72 Library Girl's Restroom	8/4/16 1:45 PM	8/24/16	50621	COPPER	0.023	1.3	mg/L	16-20664
Nellie	N73 Kitchen Restroom	8/4/16 1:47 PM	8/24/16	50622	COPPER	0.011	1.3	mg/L	16-20664
High School - MOD	mod 1 907	8/4/16 10:45 AM	8/24/16	50624	COPPER	0.008	1.3	mg/L	16-20666
High School - MOD	mod 2 907	8/4/16 10:46 AM	8/24/16	50625	COPPER	0.008	1.3	mg/L	16-20666
High School - MOD	mod 3 907	8/4/16 10:46 AM	8/24/16	50626	COPPER	0.006	1.3	mg/L	16-20666
High School - MOD	mod 4 907	8/4/16 10:48 AM	8/24/16	50627	COPPER	0.005	1.3	mg/L	16-20666
High School - MOD	mod 5 906	8/4/16 10:56 AM	8/24/16	50628	COPPER	ND	1.3	mg/L	16-20666
High School - MOD	mod 6 906	8/4/16 10:57 AM	8/24/16	50629	COPPER	ND	1.3	mg/L	16-20666
High School - MOD	mod 7 906	8/4/16 10:55 AM	8/24/16	50630	COPPER	ND	1.3	mg/L	16-20666
High School - MOD	mod 8 904	8/4/16 11:00 AM	8/24/16	50631	COPPER	ND	1.3	mg/L	16-20666
High School - MOD	mod 9 904	8/4/16 11:01 AM	8/24/16	50632	COPPER	0.005	1.3	mg/L	16-20666
High School - MOD	mod 10 902	8/4/16 11:06 AM	8/24/16	50633	COPPER	ND	1.3	mg/L	16-20666
High School - MOD	mod 11 902	8/4/16 11:07 AM	8/24/16	50634	COPPER	ND	1.3	mg/L	16-20666
High School - MOD	mod 12 902	8/4/16 11:08 AM	8/24/16	50635	COPPER	ND	1.3	mg/L	16-20666
High School - MOD	mod 13 902	8/4/16 11:09 AM	8/24/16	50636	COPPER	ND	1.3	mg/L	16-20666
High School - MOD	mod 14 902	8/4/16 11:10 AM	8/24/16	50637	COPPER	ND	1.3	mg/L	16-20666
High School - MOD	mod 15 902	8/4/16 11:11 AM	8/24/16	50638	COPPER	ND	1.3	mg/L	16-20666
High School - MOD	mod 16 mod bathroom boys	8/4/16 11:18 AM	8/24/16	50639	COPPER	0.024	1.3	mg/L	16-20666

High School - MOD	mod 17 mod bathroom boys	8/4/16 11:18 AM	8/24/16	50640	COPPER	0.023	1.3	mg/L	16-20666
High School - MOD	mod 18 mod bathroom boys	8/4/16 11:19 AM	8/24/16	50641	COPPER	0.023	1.3	mg/L	16-20666
High School - MOD	mod 19 mod bath boys	8/4/16 11:19 AM	8/24/16	50642	COPPER	0.024	1.3	mg/L	16-20666
High School - MOD	mod 20 mod bath boys	8/4/16 11:20 AM	8/24/16	50643	COPPER	0.014	1.3	mg/L	16-20666
High School - MOD	mod 21 mod bath boys	8/4/16 11:20 AM	8/24/16	50644	COPPER	0.017	1.3	mg/L	16-20666
High School - MOD	mod 22 mod bath boys	8/4/16 11:21 AM	8/24/16	50645	COPPER	0.012	1.3	mg/L	16-20666
High School - MOD	mod 23 mod bath boys	8/4/16 11:21 AM	8/24/16	50646	COPPER	0.011	1.3	mg/L	16-20666
High School - MOD	mod 24 mod bath boys	8/4/16 11:24 AM	8/24/16	50647	COPPER	0.013	1.3	mg/L	16-20666
High School - MOD	mod 25 mod bath boys	8/4/16 11:24 AM	8/24/16	50648	COPPER	0.013	1.3	mg/L	16-20666
High School - MOD	mod 26 mod bath boys	8/4/16 11:25 AM	8/24/16	50649	COPPER	0.018	1.3	mg/L	16-20666
High School - MOD	mod 27 mod bath boys	8/4/16 11:26 AM	8/24/16	50650	COPPER	0.023	1.3	mg/L	16-20666
High School - MOD	mod 28 mod bath boys	8/4/16 11:26 AM	8/24/16	50651	COPPER	0.026	1.3	mg/L	16-20666
High School - MOD	mod 29 mod bath boys	8/4/16 11:27 AM	8/24/16	50652	COPPER	0.014	1.3	mg/L	16-20666
High School - MOD	mod 30 mod bath boys	8/4/16 11:28 AM	8/24/16	50653	COPPER	0.031	1.3	mg/L	16-20666
High School - MOD	mod 31 mod bath boys	8/4/16 11:28 AM	8/24/16	50654	COPPER	0.014	1.3	mg/L	16-20666
High School - MOD	mod 32 mod bath boys	8/4/16 11:28 AM	8/24/16	50655	COPPER	0.011	1.3	mg/L	16-20666
High School - MOD	mod 33 mod bath boys	8/4/16 11:29 AM	8/24/16	50656	COPPER	0.013	1.3	mg/L	16-20666
High School - MOD	mod 34 mod bath girls	8/4/16 11:34 AM	8/24/16	50657	COPPER	0.327	1.3	mg/L	16-20666
High School - MOD	mod 35 mod bath girls	8/4/16 11:35 AM	8/24/16	50658	COPPER	0.382	1.3	mg/L	16-20666
High School - MOD	mod 36 mod bath girls	8/4/16 11:35 AM	8/24/16	50659	COPPER	0.308	1.3	mg/L	16-20666
High School - MOD	mod 37 mod bath girls	8/4/16 11:36 AM	8/24/16	50660	COPPER	0.373	1.3	mg/L	16-20666
High School - MOD	mod 38 mod bath girls	8/4/16 11:37 AM	8/24/16	50661	COPPER	0.293	1.3	mg/L	16-20666
High School - MOD	mod 39 mod bath girls	8/4/16 11:37 AM	8/24/16	50662	COPPER	0.332	1.3	mg/L	16-20666
High School - MOD	mod 40 mod bath girls	8/4/16 11:38 AM	8/24/16	50663	COPPER	0.290	1.3	mg/L	16-20666
High School - MOD	mod 41 mod bath girls	8/4/16 11:38 AM	8/24/16	50664	COPPER	0.120	1.3	mg/L	16-20666
High School - MOD	mod 42 mod bath girls	8/4/16 11:39 AM	8/24/16	50665	COPPER	0.129	1.3	mg/L	16-20666
High School - MOD	mod 43 mod bath girls	8/4/16 11:40 AM	8/24/16	50666	COPPER	0.182	1.3	mg/L	16-20666
High School - MOD	mod 44 mod bath girls	8/4/16 11:41 AM	8/24/16	50667	COPPER	0.092	1.3	mg/L	16-20666
High School - MOD	Agg 1 outside east agg build	8/4/16 1:42 PM	8/24/16	50668	COPPER	ND	1.3	mg/L	16-20666
High School - MOD	Green 1 inside west green house	8/4/16 1:44 PM	8/24/16	50669	COPPER	0.014	1.3	mg/L	16-20666
High School - MOD	Green 2 inside east green house	8/4/16 1:48 PM	8/24/16	50670	COPPER	0.011	1.3	mg/L	16-20666
High School - MOD	Green 3 outside east green house	8/4/16 1:49 PM	8/24/16	50671	COPPER	0.012	1.3	mg/L	16-20666
WHS	W-1 Loading dock	8/4/16 7:21 AM	8/25/16	51011	COPPER	0.011	1.3	mg/L	16-20821
WHS	W-2 Loading dock	8/4/16 7:22 AM	8/25/16	51012	COPPER	0.026	1.3	mg/L	16-20821
WHS	W-3 Kitchen	8/4/16 7:25 AM	8/25/16	51013	COPPER	ND	1.3	mg/L	16-20821
WHS	W-4 Kitchen	8/4/16 7:26 AM	8/25/16	51014	COPPER	0.228	1.3	mg/L	16-20821
WHS	W-5 Kitchen KP	8/4/16 7:27 AM	8/25/16	51015	COPPER	0.240	1.3	mg/L	16-20821
WHS	W-6 Kitchen	8/4/16 7:28 AM	8/25/16	51016	COPPER	0.273	1.3	mg/L	16-20821
WHS	W-7 Kitchen	8/4/16 7:29 AM	8/25/16	51017	COPPER	0.143	1.3	mg/L	16-20821
WHS	W-8 Kitchen	8/4/16 7:30 AM	8/25/16	51018	COPPER	0.006	1.3	mg/L	16-20821
WHS	W-9 Kitchen	8/4/16 7:31 AM	8/25/16	51019	COPPER	0.023	1.3	mg/L	16-20821
WHS	W-10 Custodian Closet	8/4/16 7:36 AM	8/25/16	51020	COPPER	0.014	1.3	mg/L	16-20821

WHS	W-11 Shower	8/4/16 7:37 AM	8/25/16	51021	COPPER	0.373	1.3	mg/L	16-20821
WHS	W-12 Sink	8/4/16 7:38 AM	8/25/16	51022	COPPER	0.212	1.3	mg/L	16-20821
WHS	W-13 Female Restroom	8/4/16 7:39 AM	8/25/16	51023	COPPER	0.043	1.3	mg/L	16-20821
WHS	W-14 Female Restroom	8/4/16 7:40 AM	8/25/16	51024	COPPER	0.023	1.3	mg/L	16-20821
WHS	W-15 Female Restroom	8/4/16 7:41 AM	8/25/16	51025	COPPER	0.011	1.3	mg/L	16-20821
WHS	W-16 Male Restroom	8/4/16 7:42 AM	8/25/16	51026	COPPER	0.019	1.3	mg/L	16-20821
WHS	W-17 Male Restroom	8/4/16 7:43 AM	8/25/16	51027	COPPER	0.022	1.3	mg/L	16-20821
WHS	W-18 Male Restroom	8/4/16 7:44 AM	8/25/16	51028	COPPER	0.019	1.3	mg/L	16-20821
WHS	W-19 Sci Lab RM 101	8/4/16 7:50 AM	8/25/16	51029	COPPER	0.304	1.3	mg/L	16-20821
WHS	W-20 Sci Lab RM 101	8/4/16 7:51 AM	8/25/16	51030	COPPER	0.252	1.3	mg/L	16-20821
WHS	W-21 Sci Lab RM 101	8/4/16 7:51 AM	8/25/16	51031	COPPER	0.085	1.3	mg/L	16-20821
WHS	W-22 Sci Lab RM 101	8/4/16 7:52 AM	8/25/16	51032	COPPER	0.408	1.3	mg/L	16-20821
WHS	W-23 Sci Lab RM 101	8/4/16 7:53 AM	8/25/16	51033	COPPER	0.428	1.3	mg/L	16-20821
WHS	W-24 Sci Lab RM 101	8/4/16 7:54 AM	8/25/16	51034	COPPER	0.236	1.3	mg/L	16-20821
WHS	W-25 Sci Lab RM 101	8/4/16 7:55 AM	8/25/16	51035	COPPER	0.976	1.3	mg/L	16-20821
WHS	W-26 Sci Lab RM 101	8/4/16 7:56 AM	8/25/16	51036	COPPER	0.241	1.3	mg/L	16-20821
WHS	W-27 Sci Lab RM 101	8/4/16 7:57 AM	8/25/16	51037	COPPER	0.338	1.3	mg/L	16-20821
WHS	W-28 Sci Lab RM 101	8/4/16 7:58 AM	8/25/16	51038	COPPER	0.955	1.3	mg/L	16-20821
WHS	W-29 Sci Lab RM 101	8/4/16 7:58 AM	8/25/16	51039	COPPER	0.273	1.3	mg/L	16-20821
WHS	W-30 Sci Lab RM 102	8/4/16 8:04 AM	8/25/16	51040	COPPER	0.167	1.3	mg/L	16-20821
WHS	W-31 Sci Lab RM 102	8/4/16 8:06 AM	8/25/16	51041	COPPER	0.177	1.3	mg/L	16-20821
WHS	W-32 Sci Lab RM 102	8/4/16 8:07 AM	8/25/16	51042	COPPER	0.266	1.3	mg/L	16-20821
WHS	W-33 Sci Lab RM 102	8/4/16 8:07 AM	8/25/16	51043	COPPER	0.255	1.3	mg/L	16-20821
WHS	W-34 Sci Lab RM 102	8/4/16 8:08 AM	8/25/16	51044	COPPER	0.287	1.3	mg/L	16-20821
WHS	W-35 Sci Lab RM 102	8/4/16 8:09 AM	8/25/16	51045	COPPER	0.086	1.3	mg/L	16-20821
WHS	W-36 Sci Lab RM 102	8/4/16 8:10 AM	8/25/16	51046	COPPER	0.428	1.3	mg/L	16-20821
WHS	W-37 Sci Lab RM 102	8/4/16 8:11 AM	8/25/16	51047	COPPER	0.161	1.3	mg/L	16-20821
WHS	W-38 Sci Lab RM 102	8/4/16 8:12 AM	8/25/16	51048	COPPER	0.183	1.3	mg/L	16-20821
WHS	W-39 Sci Lab RM 102	8/4/16 8:13 AM	8/25/16	51049	COPPER	0.276	1.3	mg/L	16-20821
WHS	W-40 Sci Lab RM 102	8/4/16 8:14 AM	8/25/16	51050	COPPER	0.199	1.3	mg/L	16-20821
WHS	W-41 Sci Lab RM 103	8/4/16 8:19 AM	8/25/16	51051	COPPER	0.024	1.3	mg/L	16-20821
WHS	W-42 Sci Lab RM 103	8/4/16 8:19 AM	8/25/16	51052	COPPER	ND	1.3	mg/L	16-20821
WHS	W-43 Sci Lab RM 103	8/4/16 8:20 AM	8/25/16	51053	COPPER	0.005	1.3	mg/L	16-20821
WHS	W-44 Sci Lab RM 103	8/4/16 8:21 AM	8/25/16	51054	COPPER	0.014	1.3	mg/L	16-20821
WHS	W-45 Sci Lab RM 103	8/4/16 8:22 AM	8/25/16	51055	COPPER	0.005	1.3	mg/L	16-20821
WHS	W-46 Sci Lab RM 103	8/4/16 8:23 AM	8/25/16	51056	COPPER	0.103	1.3	mg/L	16-20821
WHS	W-47 WEBSS Office	8/4/16 8:26 AM	8/25/16	51057	COPPER	0.083	1.3	mg/L	16-20821
WHS	W-48 Sci Lab RM 104	8/4/16 8:28 AM	8/25/16	51058	COPPER	0.204	1.3	mg/L	16-20821
WHS	W-49 Sci Lab RM 104	8/4/16 8:29 AM	8/25/16	51059	COPPER	0.139	1.3	mg/L	16-20821
WHS	W-50 Sci Lab RM 104	8/4/16 8:30 AM	8/25/16	51060	COPPER	0.275	1.3	mg/L	16-20821
WHS	W-51 Sci Lab RM 104	8/4/16 8:31 AM	8/25/16	51061	COPPER	0.173	1.3	mg/L	16-20821
WHS	W-52 Sci Lab RM 104	8/4/16 8:32 AM	8/25/16	51062	COPPER	1.040	1.3	mg/L	16-20821

WHS	W-53 Sci Lab RM 105	8/4/16 8:34 AM	8/25/16	51063	COPPER	ND	1.3	mg/L	16-20821
WHS	W-54 Sci Lab RM 105	8/4/16 8:35 AM	8/25/16	51064	COPPER	0.006	1.3	mg/L	16-20821
WHS	W-55 Sci Lab RM 105	8/4/16 8:37 AM	8/25/16	51065	COPPER	0.203	1.3	mg/L	16-20821
WHS	W-56 Nurse Office	8/4/16 8:42 AM	8/25/16	51066	COPPER	ND	1.3	mg/L	16-20821
WHS	W-57 Nurse Office	8/4/16 8:43 AM	8/25/16	51067	COPPER	ND	1.3	mg/L	16-20821
WHS	W-58 Bistro	8/4/16 8:46 AM	8/25/16	51068	COPPER	0.055	1.3	mg/L	16-20821
WHS	W-59 Male RR	8/4/16 8:50 AM	8/25/16	51069	COPPER	0.203	1.3	mg/L	16-20821
WHS	W-60 Male RR	8/4/16 8:50 AM	8/25/16	51070	COPPER	0.158	1.3	mg/L	16-20821
WHS	W-61 Male RR	8/4/16 8:51 AM	8/25/16	51071	COPPER	0.209	1.3	mg/L	16-20821
WHS	W-62 Male RR	8/4/16 8:52 AM	8/25/16	51072	COPPER	0.202	1.3	mg/L	16-20821
WHS	W-63 Female RR	8/4/16 8:53 AM	8/25/16	51073	COPPER	0.188	1.3	mg/L	16-20821
WHS	W-64 Female RR	8/4/16 8:54 AM	8/25/16	51074	COPPER	0.193	1.3	mg/L	16-20821
WHS	W-65 Female RR	8/4/16 8:54 AM	8/25/16	51075	COPPER	0.166	1.3	mg/L	16-20821
WHS	W-66 Female RR	8/4/16 8:55 AM	8/25/16	51076	COPPER	0.182	1.3	mg/L	16-20821
WHS	W-67 Custodian RM 411	8/4/16 8:59 AM	8/25/16	51077	COPPER	0.234	1.3	mg/L	16-20821
WHS	W-68 Office Female RR	8/4/16 9:02 AM	8/25/16	51078	COPPER	0.257	1.3	mg/L	16-20821
WHS	W-69 Office Female RR	8/4/16 9:03 AM	8/25/16	51079	COPPER	0.240	1.3	mg/L	16-20821
WHS	W-70 Office Male RR	8/4/16 9:04 AM	8/25/16	51080	COPPER	0.215	1.3	mg/L	16-20821
WHS	W-71 Staff Art Male RR	8/4/16 9:10 AM	8/25/16	51081	COPPER	0.205	1.3	mg/L	16-20821
WHS	W-72 Art Male RR	8/4/16 9:12 AM	8/25/16	51082	COPPER	0.232	1.3	mg/L	16-20821
WHS	W-73 Art Male RR	8/4/16 9:12 AM	8/25/16	51083	COPPER	0.226	1.3	mg/L	16-20821
WHS	W-74 Art Male RR	8/4/16 9:13 AM	8/25/16	51084	COPPER	0.189	1.3	mg/L	16-20821
WHS	W-75 Art Male RR	8/4/16 9:14 AM	8/25/16	51085	COPPER	0.188	1.3	mg/L	16-20821
WHS	W-76 Staff Art Female RR	8/4/16 9:15 AM	8/25/16	51086	COPPER	0.234	1.3	mg/L	16-20821
WHS	W-77 Art Female RR	8/4/16 9:17 AM	8/25/16	51087	COPPER	0.312	1.3	mg/L	16-20821
WHS	W-78 Art Female RR	8/4/16 9:18 AM	8/25/16	51088	COPPER	0.235	1.3	mg/L	16-20821
WHS	W-79 Art Female RR	8/4/16 9:18 AM	8/25/16	51089	COPPER	0.214	1.3	mg/L	16-20821
WHS	W-80 Art Female RR	8/4/16 9:19 AM	8/25/16	51090	COPPER	0.204	1.3	mg/L	16-20821
WHS	W-81 Art Custodian Closet	8/4/16 9:22 AM	8/25/16	51091	COPPER	0.091	1.3	mg/L	16-20821
WHS	W-82 Art RM 510	8/4/16 9:25 AM	8/25/16	51092	COPPER	0.247	1.3	mg/L	16-20821
WHS	W-83 Art RM 510	8/4/16 9:25 AM	8/25/16	51093	COPPER	0.229	1.3	mg/L	16-20821
WHS	W-84 Art RM 513	8/4/16 9:28 AM	8/25/16	51094	COPPER	0.259	1.3	mg/L	16-20821
WHS	W-85 Art RM 513	8/4/16 9:28 AM	8/25/16	51095	COPPER	0.224	1.3	mg/L	16-20821
WHS	W-86 Art RM 513	8/4/16 9:29 AM	8/25/16	51096	COPPER	0.240	1.3	mg/L	16-20821
WHS	W-87 Art RM 515	8/4/16 9:30 AM	8/25/16	51097	COPPER	0.191	1.3	mg/L	16-20821
WHS	W-88 Stage	8/4/16 9:31 AM	8/25/16	51098	COPPER	0.389	1.3	mg/L	16-20821
WHS	W-89 WEBSS Workroom LNG	8/4/16 9:40 AM	8/25/16	51099	COPPER	0.271	1.3	mg/L	16-20821
WHS	W-90 WEBSS Workroom RR	8/4/16 9:43 AM	8/25/16	51100	COPPER	0.179	1.3	mg/L	16-20821
WHS	W-91 WEBSS Workroom RR	8/4/16 9:44 AM	8/25/16	51101	COPPER	0.136	1.3	mg/L	16-20821
WHS	W-92 Male RR	8/4/16 10:18 AM	8/25/16	51102	COPPER	0.040	1.3	mg/L	16-20821
WHS	W-93 Male RR	8/4/16 10:19 AM	8/25/16	51103	COPPER	0.042	1.3	mg/L	16-20821
WHS	W-94 Male RR	8/4/16 10:20 AM	8/25/16	51104	COPPER	0.053	1.3	mg/L	16-20821

WHS	W-95 Female RR	8/4/16 10:21 AM	8/25/16	51105	COPPER	0.011	1.3	mg/L	16-20821
WHS	W-96 Female RR	8/4/16 10:21 AM	8/25/16	51106	COPPER	0.015	1.3	mg/L	16-20821
WHS	W-97 Female RR	8/4/16 10:22 AM	8/25/16	51107	COPPER	0.038	1.3	mg/L	16-20821
WHS	W-98 Gym Custodian 729	8/4/16 10:26 AM	8/25/16	51108	COPPER	ND	1.3	mg/L	16-20821
WHS	W-99 Gym Ice Machine 728	8/4/16 10:30 AM	8/25/16	51109	COPPER	0.061	1.3	mg/L	16-20821
WHS	W-100 Staff Sink 701	8/4/16 10:33 AM	8/25/16	51110	COPPER	0.007	1.3	mg/L	16-20821
WHS	W-101 Staff Shower 701	8/4/16 10:35 AM	8/25/16	51111	COPPER	0.007	1.3	mg/L	16-20821
WHS	W-102 Girls LKRM Sink	8/4/16 10:37 AM	8/25/16	51112	COPPER	0.006	1.3	mg/L	16-20821
WHS	W-103 Girls LKRM Sink	8/4/16 10:36 AM	8/25/16	51113	COPPER	0.012	1.3	mg/L	16-20821
WHS	W-104 Girls SHR 1-1	8/4/16 10:44 AM	8/25/16	51114	COPPER	0.039	1.3	mg/L	16-20821
WHS	W-105 Girls SHR 1-2	8/4/16 10:46 AM	8/25/16	51115	COPPER	0.028	1.3	mg/L	16-20821
WHS	W-106 Girls SHR 1-3	8/4/16 10:47 AM	8/25/16	51116	COPPER	0.020	1.3	mg/L	16-20821
WHS	W-107 Girls SHR 1-4	8/4/16 10:48 AM	8/25/16	51117	COPPER	0.020	1.3	mg/L	16-20821
WHS	W-108 Girls SHR 1-5	8/4/16 10:49 AM	8/25/16	51118	COPPER	0.033	1.3	mg/L	16-20821
WHS	W-109 Girls SHR 2-1	8/4/16 10:50 AM	8/25/16	51119	COPPER	0.015	1.3	mg/L	16-20821
WHS	W-110 Girls SHR 2-2	8/4/16 10:51 AM	8/25/16	51120	COPPER	0.013	1.3	mg/L	16-20821
WHS	W-111 Girls SHR 2-3	8/4/16 10:53 AM	8/25/16	51121	COPPER	0.015	1.3	mg/L	16-20821
WHS	W-112 Girls SHR 2-5	8/4/16 10:54 AM	8/25/16	51122	COPPER	0.013	1.3	mg/L	16-20821
WHS	W-113 Girls SHR 3-4	8/4/16 10:57 AM	8/25/16	51123	COPPER	0.401	1.3	mg/L	16-20821
WHS	W-114 Girls SHR 3-1	8/4/16 10:56 AM	8/25/16	51124	COPPER	0.017	1.3	mg/L	16-20821
WHS	W-115 Girls SHR 3-2	8/4/16 10:58 AM	8/25/16	51125	COPPER	0.020	1.3	mg/L	16-20821
WHS	W-116 Girls SHR 3-3	8/4/16 10:59 AM	8/25/16	51126	COPPER	0.021	1.3	mg/L	16-20821
WHS	W-117 Girls SHR 3-5	8/4/16 10:59 AM	8/25/16	51127	COPPER	0.015	1.3	mg/L	16-20821
WHS	W-118 REFF CHG RM	8/4/16 11:03 AM	8/25/16	51128	COPPER	0.009	1.3	mg/L	16-20821
WHS	W-119 REFF CHG RM	8/4/16 11:03 AM	8/25/16	51129	COPPER	0.005	1.3	mg/L	16-20821
WHS	W-120 Staff SHR	8/4/16 11:09 AM	8/25/16	51130	COPPER	0.014	1.3	mg/L	16-20821
WHS	W-121 Staff Sink	8/4/16 11:10 AM	8/25/16	51131	COPPER	0.008	1.3	mg/L	16-20821
WHS	W-122 Boys LKR Sink	8/4/16 11:12 AM	8/25/16	51132	COPPER	0.021	1.3	mg/L	16-20821
WHS	W-123 Boys LKR Sink	8/4/16 11:13 AM	8/25/16	51133	COPPER	0.032	1.3	mg/L	16-20821
WHS	W-124 Boys LKR 1-1	8/4/16 11:19 AM	8/25/16	51134	COPPER	0.275	1.3	mg/L	16-20821
WHS	W-125 Boys LKR 1-2	8/4/16 11:20 AM	8/25/16	51135	COPPER	0.059	1.3	mg/L	16-20821
WHS	W-126 Boys LKR 1-3	8/4/16 11:21 AM	8/25/16	51136	COPPER	0.096	1.3	mg/L	16-20821
WHS	W-127 Boys LKR 1-4	8/4/16 11:21 AM	8/25/16	51137	COPPER	0.039	1.3	mg/L	16-20821
WHS	W-128 Boys LKR 1-5	8/4/16 11:22 AM	8/25/16	51138	COPPER	0.041	1.3	mg/L	16-20821
WHS	W-129 Boys LKR 2-1	8/4/16 11:24 AM	8/25/16	51139	COPPER	0.086	1.3	mg/L	16-20821
WHS	W-130 Boys LKR 2-2	8/4/16 11:25 AM	8/25/16	51140	COPPER	0.082	1.3	mg/L	16-20821
WHS	W-131 Boys LKR 2-3	8/4/16 11:26 AM	8/25/16	51141	COPPER	0.161	1.3	mg/L	16-20821
WHS	W-132 Boys LKR 2-4	8/4/16 11:27 AM	8/25/16	51142	COPPER	0.067	1.3	mg/L	16-20821
WHS	W-133 Boys LKR 2-5	8/4/16 11:27 AM	8/25/16	51143	COPPER	0.083	1.3	mg/L	16-20821
WHS	W-134 Boys LKR 3-1	8/4/16 11:29 AM	8/25/16	51144	COPPER	0.185	1.3	mg/L	16-20821
WHS	W-135 Boys LKR 3-2	8/4/16 11:30 AM	8/25/16	51145	COPPER	0.086	1.3	mg/L	16-20821
WHS	W-136 Boys LKR 3-3	8/4/16 11:30 AM	8/25/16	51146	COPPER	0.083	1.3	mg/L	16-20821



WHS	W-137 Boys LKR 3-4	8/4/16 11:31 AM	8/25/16	51147	COPPER	0.058	1.3	mg/L	16-20821
WHS	W-138 Mens Team Sink	8/4/16 11:36 AM	8/25/16	51148	COPPER	0.036	1.3	mg/L	16-20821
WHS	W-139 Mens Team Sink	8/4/16 11:37 AM	8/25/16	51149	COPPER	0.043	1.3	mg/L	16-20821
WHS	W-140 Mens Team Sink	8/4/16 11:38 AM	8/25/16	51150	COPPER	0.054	1.3	mg/L	16-20821
WHS	W-141 Mens Team Sink	8/4/16 11:38 AM	8/25/16	51151	COPPER	0.060	1.3	mg/L	16-20821
WHS	W-142 Mens Team Staff Sink	8/4/16 11:40 AM	8/25/16	51152	COPPER	0.163	1.3	mg/L	16-20821
WHS	W-143 Mens Team Staff Shower	8/4/16 11:41 AM	8/25/16	51153	COPPER	0.138	1.3	mg/L	16-20821
WHS	W-144 Mens Team SHR	8/4/16 11:45 AM	8/25/16	51154	COPPER	0.049	1.3	mg/L	16-20821
WHS	W-145 Mens Team SHR	8/4/16 11:46 AM	8/25/16	51155	COPPER	0.063	1.3	mg/L	16-20821
WHS	W-146 Mens Team SHR	8/4/16 11:46 AM	8/25/16	51156	COPPER	0.058	1.3	mg/L	16-20821
WHS	W-147 Mens Team SHR	8/4/16 11:47 AM	8/25/16	51157	COPPER	0.053	1.3	mg/L	16-20821
WHS	W-148 Mens Team SHR	8/4/16 11:48 AM	8/25/16	51158	COPPER	0.064	1.3	mg/L	16-20821
WHS	W-149 Mens Team SHR	8/4/16 11:50 AM	8/25/16	51159	COPPER	0.058	1.3	mg/L	16-20821
WHS	W-150 Mens Team SHR	8/4/16 11:51 AM	8/25/16	51160	COPPER	0.078	1.3	mg/L	16-20821
WHS	W-151 Mens Team SHR	8/4/16 11:51 AM	8/25/16	51161	COPPER	0.058	1.3	mg/L	16-20821
WHS	W-152 Mens Team SHR	8/4/16 11:52 AM	8/25/16	51162	COPPER	0.058	1.3	mg/L	16-20821
WHS	W-153 Weight RM Mens RR	8/4/16 11:56 AM	8/25/16	51163	COPPER	0.072	1.3	mg/L	16-20821
WHS	W-154 Weight RM Mens RR	8/4/16 11:57 AM	8/25/16	51164	COPPER	0.074	1.3	mg/L	16-20821
WHS	W-155 Weight RM Mens RR	8/4/16 11:57 AM	8/25/16	51165	COPPER	0.079	1.3	mg/L	16-20821
WHS	W-156 Weight RM Mens RR	8/4/16 11:58 AM	8/25/16	51166	COPPER	0.080	1.3	mg/L	16-20821
WHS	W-157 Weight RM Female RR	8/4/16 11:59 AM	8/25/16	51167	COPPER	0.176	1.3	mg/L	16-20821
WHS	W-158 Weight RM Female RR	8/4/16 12:00 PM	8/25/16	51168	COPPER	0.170	1.3	mg/L	16-20821
WHS	W-159 Weight RM Female RR	8/4/16 12:01 PM	8/25/16	51169	COPPER	0.168	1.3	mg/L	16-20821
WHS	W-160 Weight RM Female RR	8/4/16 12:01 PM	8/25/16	51170	COPPER	0.161	1.3	mg/L	16-20821
WHS	W-161 Female Team Staff SHR	8/4/16 12:40 PM	8/25/16	51171	COPPER	0.222	1.3	mg/L	16-20821
WHS	W-162 Female Team Staff Sink	8/4/16 12:41 PM	8/25/16	51172	COPPER	0.080	1.3	mg/L	16-20821
WHS	W-163 Female Team Sink	8/4/16 12:42 PM	8/25/16	51173	COPPER	0.228	1.3	mg/L	16-20821
WHS	W-164 Female Team Sink	8/4/16 12:43 PM	8/25/16	51174	COPPER	0.213	1.3	mg/L	16-20821
WHS	W-165 Female Team Sink	8/4/16 12:44 PM	8/25/16	51175	COPPER	0.217	1.3	mg/L	16-20821
WHS	W-166 Female Team Sink	8/4/16 12:44 PM	8/25/16	51176	COPPER	0.193	1.3	mg/L	16-20821
WHS	W-167 Female Team SHR	8/4/16 12:47 PM	8/25/16	51177	COPPER	0.119	1.3	mg/L	16-20821
WHS	W-168 Female Team SHR	8/4/16 12:48 PM	8/25/16	51178	COPPER	0.143	1.3	mg/L	16-20821
WHS	W-169 Female Team SHR	8/4/16 12:49 PM	8/25/16	51179	COPPER	0.121	1.3	mg/L	16-20821
WHS	W-170 Female Team SHR	8/4/16 12:50 PM	8/25/16	51180	COPPER	0.145	1.3	mg/L	16-20821
WHS	W-171 Female Team SHR	8/4/16 12:51 PM	8/25/16	51181	COPPER	0.084	1.3	mg/L	16-20821
WHS	W-172 Female Team SHR	8/4/16 12:51 PM	8/25/16	51182	COPPER	0.056	1.3	mg/L	16-20821
WHS	W-173 Female Team SHR	8/4/16 12:52 PM	8/25/16	51183	COPPER	0.070	1.3	mg/L	16-20821
WHS	W-174 Female Team SHR	8/4/16 12:53 PM	8/25/16	51184	COPPER	0.083	1.3	mg/L	16-20821
WHS	W-175 Female Team SHR	8/4/16 12:53 PM	8/25/16	51185	COPPER	0.083	1.3	mg/L	16-20821
WHS	W-176 WHS Sink Athletic Train	8/4/16 12:57 PM	8/25/16	51186	COPPER	ND	1.3	mg/L	16-20821
WHS	W-177 WHS Ice Machine Athletic Train	8/4/16 1:01 PM	8/25/16	51187	COPPER	0.132	1.3	mg/L	16-20821
WHS	W-178 Outdoor	8/4/16 1:07 PM	8/25/16	51188	COPPER	0.202	1.3	mg/L	16-20821

WHS	W-179 Outdoor	8/4/16 1:10 PM	8/25/16	51189	COPPER	0.005	1.3	mg/L	16-20821
WHS	W-180 Outdoor	8/4/16 1:13 PM	8/25/16	51190	COPPER	0.269	1.3	mg/L	16-20821
WHS	W-181 Outdoor	8/4/16 1:16 PM	8/25/16	51191	COPPER	0.297	1.3	mg/L	16-20821
WHS	W-182 Outdoor	8/4/16 1:19 PM	8/25/16	51192	COPPER	0.343	1.3	mg/L	16-20821
WHS	W-183 Outdoor	8/4/16 1:20 PM	8/25/16	51193	COPPER	0.392	1.3	mg/L	16-20821
WHS	W-184 Outdoor	8/4/16 1:22 PM	8/25/16	51194	COPPER	0.006	1.3	mg/L	16-20821
WHS	W-185 Outdoor	8/4/16 1:24 PM	8/25/16	51195	COPPER	0.009	1.3	mg/L	16-20821
WHS	W-186 Outdoor	8/4/16 1:25 PM	8/25/16	51196	COPPER	ND	1.3	mg/L	16-20821
WHS	W-187 Outdoor	8/4/16 1:28 PM	8/25/16	51197	COPPER	0.007	1.3	mg/L	16-20821
WHS	W-188 Outdoor	8/4/16 1:30 PM	8/25/16	51198	COPPER	0.065	1.3	mg/L	16-20821
WHS	W-189 Outdoor	8/4/16 1:32 PM	8/25/16	51199	COPPER	0.061	1.3	mg/L	16-20821
WHS	W-190 Concession Sink	8/4/16 1:38 PM	8/25/16	51200	COPPER	0.087	1.3	mg/L	16-20821
WHS	W-191 Outdoor	8/4/16 1:46 PM	8/25/16	51201	COPPER	0.013	1.3	mg/L	16-20821
WHS	W-192 Girls Sport RR	8/4/16 1:48 PM	8/25/16	51202	COPPER	0.170	1.3	mg/L	16-20821
WHS	W-193 Girls Sport RR	8/4/16 1:48 PM	8/25/16	51203	COPPER	0.161	1.3	mg/L	16-20821
WHS	W-194 Boys Sport RR	8/4/16 1:49 PM	8/25/16	51204	COPPER	0.213	1.3	mg/L	16-20821
WHS	W-195 Boys Sport RR	8/4/16 1:50 PM	8/25/16	51205	COPPER	0.201	1.3	mg/L	16-20821
WHS	W-196 Ath Training Cntr	8/4/16 1:53 PM	8/25/16	51206	COPPER	0.055	1.3	mg/L	16-20821
WHS	W-197 Ath Training Cntr Ice Machine	8/4/16 1:55 PM	8/25/16	51207	COPPER	0.195	1.3	mg/L	16-20821
WHS	W-198 Ath Training Cntr Sink	8/4/16 1:55 PM	8/25/16	51208	COPPER	0.208	1.3	mg/L	16-20821
WHS	W-199 Ath Training Cntr Sink	8/4/16 1:58 PM	8/25/16	51209	COPPER	0.231	1.3	mg/L	16-20821
WHS	W-200 Outdoor	8/4/16 1:59 PM	8/25/16	51210	COPPER	0.144	1.3	mg/L	16-20821
WHS	W-201 Concession STD	8/4/16 2:00 PM	8/25/16	51211	COPPER	0.164	1.3	mg/L	16-20821
WHS	W-202 Concession STD	8/4/16 2:01 PM	8/25/16	51212	COPPER	0.057	1.3	mg/L	16-20821
High School - Softball & T	Soft Ball 1 West Soft ball field	8/4/16 1:55 PM	8/25/16	51213	COPPER	0.016	1.3	mg/L	16-20822
High School - Softball & T	Soft Ball 2 South Soft ball Field	8/4/16 2:01 PM	8/25/16	51214	COPPER	0.013	1.3	mg/L	16-20822
High School - Softball & T	Bleachers 1 South Foot ball Field Bleachers	8/4/16 2:17 PM	8/25/16	51215	COPPER	ND	1.3	mg/L	16-20822
High School - Softball & T	T-1 Tennis court stroage	8/4/16 2:23 PM	8/26/16	51216	COPPER	0.050	1.3	mg/L	16-20822
High School - Softball & T	T-2 Tennis court faucet	8/4/16 2:24 PM	8/26/16	51217	COPPER	0.006	1.3	mg/L	16-20822
High School - Softball & T	T-3 Tennis court fountain	8/4/16 2:25 PM	8/26/16	51218	COPPER	0.030	1.3	mg/L	16-20822
High School - Softball & T	T-4 Boys bath Tennis Court	8/4/16 2:26 PM	8/26/16	51219	COPPER	0.056	1.3	mg/L	16-20822
High School - Softball & T	T-5 Girls bath tennis court	8/4/16 2:27 PM	8/26/16	51220	COPPER	0.055	1.3	mg/L	16-20822
High School - CLC	CLC 1 CLC bath 1	8/4/16 1:01 PM	8/26/16	51226	COPPER	0.046	1.3	mg/L	16-20827
High School - CLC	CLC 2 CLC bath 2	8/4/16 1:02 PM	8/26/16	51227	COPPER	0.506	1.3	mg/L	16-20827
High School - CLC	CLC 3 CLC laundry	8/4/16 1:03 PM	8/26/16	51228	COPPER	0.202	1.3	mg/L	16-20827
High School - CLC	CLC 4 CLC kitchen	8/4/16 1:04 PM	8/26/16	51229	COPPER	0.272	1.3	mg/L	16-20827
High School - CLC	CLC 5 CLC preschool	8/4/16 1:06 PM	8/26/16	51230	COPPER	0.029	1.3	mg/L	16-20827
High School - CLC	CLC 6 CLC preschool bath	8/4/16 1:06 PM	8/26/16	51231	COPPER	0.140	1.3	mg/L	16-20827
High School - CLC	CLC 7 CLC infant-toddler	8/4/16 1:08 PM	8/26/16	51232	COPPER	0.275	1.3	mg/L	16-20827
High School - CLC	CLC 8 CLC infant-toddler bath	8/4/16 1:09 PM	8/26/16	51233	COPPER	0.298	1.3	mg/L	16-20827
High School - CLC	CLC EXT 9 CLC west hose BIB	8/4/16 1:12 PM	8/26/16	51234	COPPER	0.217	1.3	mg/L	16-20827
High School - CLC	CLC EXT 10 CLC east hose Bib	8/4/16 1:12 PM	8/26/16	51235	COPPER	0.023	1.3	mg/L	16-20827

Success	SU-1 Up Girls bath	8/5/16 7:27 AM	8/26/16	51238	COPPER	0.051	1.3	mg/L	16-20829
Success	SU-2 Class 201	8/5/16 7:28 AM	8/26/16	51239	COPPER	0.050	1.3	mg/L	16-20829
Success	SU-3 Up Boys Bath	8/5/16 7:29 AM	8/26/16	51240	COPPER	0.078	1.3	mg/L	16-20829
Success	SU-4 Upstair Fountain	8/5/16 7:31 AM	8/26/16	51241	COPPER	0.077	1.3	mg/L	16-20829
Success	SU-5 Classroom	8/5/16 7:32 AM	8/26/16	51242	COPPER	0.059	1.3	mg/L	16-20829
Success	Su-6 Down Boys Bath	8/5/16 7:24 AM	8/26/16	51243	COPPER	0.096	1.3	mg/L	16-20829
Success	SU-7 Custodian 1	8/5/16 7:25 AM	8/26/16	51244	COPPER	0.059	1.3	mg/L	16-20829
Success	SU-8 Down Girls Bath	8/5/16 7:23 AM	8/26/16	51245	COPPER	0.117	1.3	mg/L	16-20829
Success	SU-9 Kitchen	8/5/16 7:22 AM	8/26/16	51246	COPPER	0.057	1.3	mg/L	16-20829
Success	SU-10 Hose Bibb	8/5/16 7:35 AM	8/26/16	51247	COPPER	0.055	1.3	mg/L	16-20829
High School - AIS	AIS 1 R818	8/4/16 8:15 AM	8/26/16	51248	COPPER	0.017	1.3	mg/L	16-20830
High School - AIS	AIS 2 R818	8/4/16 8:16 AM	8/26/16	51249	COPPER	0.068	1.3	mg/L	16-20830
High School - AIS	AIS 3 R818	8/4/16 8:17 AM	8/26/16	51250	COPPER	0.147	1.3	mg/L	16-20830
High School - AIS	AIS 4 R818	8/4/16 8:17 AM	8/26/16	51251	COPPER	0.176	1.3	mg/L	16-20830
High School - AIS	AIS 5 R818	8/4/16 8:19 AM	8/26/16	51252	COPPER	0.132	1.3	mg/L	16-20830
High School - AIS	AIS 6 R816	8/4/16 8:21 AM	8/26/16	51253	COPPER	0.166	1.3	mg/L	16-20830
High School - AIS	AIS 7 R814	8/4/16 8:22 AM	8/26/16	51254	COPPER	0.191	1.3	mg/L	16-20830
High School - AIS	AIS 8 Janitor Closet 1	8/4/16 8:24 AM	8/26/16	51255	COPPER	0.201	1.3	mg/L	16-20830
High School - AIS	AIS 9 Girls bath 1	8/4/16 8:26 AM	8/26/16	51256	COPPER	0.083	1.3	mg/L	16-20830
High School - AIS	AIS 10 Girls bath 1	8/4/16 8:28 AM	8/26/16	51257	COPPER	0.088	1.3	mg/L	16-20830
High School - AIS	AIS 11 Girls bath 1	8/4/16 8:29 AM	8/26/16	51258	COPPER	0.071	1.3	mg/L	16-20830
High School - AIS	AIS 12 R801	8/4/16 8:32 AM	8/26/16	51259	COPPER	0.240	1.3	mg/L	16-20830
High School - AIS	AIS 13 R803	8/4/16 8:33 AM	8/26/16	51260	COPPER	0.229	1.3	mg/L	16-20830
High School - AIS	AIS 14 Boys bath 1	8/4/16 8:36 AM	8/26/16	51261	COPPER	0.176	1.3	mg/L	16-20830
High School - AIS	AIS 15 Boys bath 1	8/4/16 8:36 AM	8/26/16	51262	COPPER	0.169	1.3	mg/L	16-20830
High School - AIS	AIS 16 Boys bath 1	8/4/16 8:36 AM	8/26/16	51263	COPPER	0.148	1.3	mg/L	16-20830
High School - AIS	AIS 17 Janitor Closet 2	8/4/16 8:41 AM	8/26/16	51264	COPPER	0.182	1.3	mg/L	16-20830
High School - AIS	AIS 18 R805	8/4/16 8:43 AM	8/26/16	51265	COPPER	0.046	1.3	mg/L	16-20830
High School - AIS	AIS 19 R807	8/4/16 8:44 AM	8/26/16	51266	COPPER	0.213	1.3	mg/L	16-20830
High School - AIS	AIS 20 R809	8/4/16 8:46 AM	8/26/16	51267	COPPER	0.189	1.3	mg/L	16-20830
High School - AIS	AIS 21 Staffroom	8/4/16 8:48 AM	8/26/16	51268	COPPER	0.232	1.3	mg/L	16-20830
High School - AIS	AIS 22 Staff Bath	8/4/16 8:49 AM	8/26/16	51269	COPPER	0.075	1.3	mg/L	16-20830
High School - AIS	AIS 23 Janitor Room 3	8/4/16 8:51 AM	8/26/16	51270	COPPER	0.152	1.3	mg/L	16-20830
High School - AIS	AIS 24 Girls bath 2	8/4/16 8:55 AM	8/26/16	51271	COPPER	0.120	1.3	mg/L	16-20830
High School - AIS	AIS 25 Girls bath 2	8/4/16 8:54 AM	8/26/16	51272	COPPER	0.091	1.3	mg/L	16-20830
High School - AIS	AIS 26 Girls bath 2	8/4/16 8:53 AM	8/26/16	51273	COPPER	0.135	1.3	mg/L	16-20830
High School - AIS	AIS 27 R814	8/4/16 9:11 AM	8/26/16	51274	COPPER	0.038	1.3	mg/L	16-20830
High School - AIS	AIS 28 R811	8/4/16 9:12 AM	8/26/16	51275	COPPER	0.035	1.3	mg/L	16-20830
High School - AIS	AIS 29 R811	8/4/16 9:13 AM	8/26/16	51276	COPPER	0.030	1.3	mg/L	16-20830
High School - AIS	AIS 30 R811	8/4/16 9:14 AM	8/26/16	51277	COPPER	0.031	1.3	mg/L	16-20830
High School - AIS	AIS 31 R811	8/4/16 9:16 AM	8/26/16	51278	COPPER	0.029	1.3	mg/L	16-20830
High School - AIS	AIS 32 R812	8/4/16 9:16 AM	8/26/16	51279	COPPER	0.031	1.3	mg/L	16-20830

High School - AIS	AIS 33 R812	8/4/16 9:20 AM	8/26/16	51280	COPPER	0.026	1.3	mg/L	16-20830
High School - AIS	AIS 34 R812	8/4/16 9:20 AM	8/26/16	51281	COPPER	0.026	1.3	mg/L	16-20830
High School - AIS	AIS 35 R812	8/4/16 9:21 AM	8/26/16	51282	COPPER	0.024	1.3	mg/L	16-20830
High School - AIS	AIS 36 R812	8/4/16 9:22 AM	8/26/16	51283	COPPER	0.021	1.3	mg/L	16-20830
High School - AIS	AIS 37 Boys bath 2	8/4/16 9:24 AM	8/26/16	51284	COPPER	0.193	1.3	mg/L	16-20830
High School - AIS	AIS 38 Boys bath 2	8/4/16 9:25 AM	8/26/16	51285	COPPER	0.207	1.3	mg/L	16-20830
High School - AIS	AIS 39 Boys bath 2	8/4/16 9:26 AM	8/26/16	51286	COPPER	0.186	1.3	mg/L	16-20830
High School - AIS	AIS 40 Break Room	8/4/16 9:27 AM	8/26/16	51287	COPPER	0.027	1.3	mg/L	16-20830
High School - AIS	AIS 41 R810	8/4/16 9:28 AM	8/26/16	51288	COPPER	0.186	1.3	mg/L	16-20830
High School - AIS	AIS 42 Multipurpose	8/4/16 9:29 AM	8/26/16	51289	COPPER	0.141	1.3	mg/L	16-20830
High School - AIS	AIS 43 Girls bath 3	8/4/16 9:33 AM	8/26/16	51290	COPPER	0.188	1.3	mg/L	16-20830
High School - AIS	AIS 44 Girls bath 3	8/4/16 9:34 AM	8/26/16	51291	COPPER	0.182	1.3	mg/L	16-20830
High School - AIS	AIS 45 Girls bath 3	8/4/16 9:34 AM	8/26/16	51292	COPPER	0.200	1.3	mg/L	16-20830
High School - AIS	AIS 46 R804	8/4/16 9:36 AM	8/26/16	51293	COPPER	0.205	1.3	mg/L	16-20830
High School - AIS	AIS 47 R802	8/4/16 9:38 AM	8/26/16	51294	COPPER	0.196	1.3	mg/L	16-20830
High School - AIS	AIS 48 Boys bath 3	8/4/16 9:41 AM	8/26/16	51295	COPPER	0.083	1.3	mg/L	16-20830
High School - AIS	AIS 49 Boys bath 3	8/4/16 9:40 AM	8/26/16	51296	COPPER	0.065	1.3	mg/L	16-20830
High School - AIS	AIS 50 Staff Bath	8/4/16 9:42 AM	8/26/16	51297	COPPER	0.213	1.3	mg/L	16-20830
High School - AIS	AIS 51 R813	8/4/16 9:43 AM	8/26/16	51298	COPPER	0.182	1.3	mg/L	16-20830
High School - AIS	AIS 52 R815	8/4/16 9:45 AM	8/26/16	51299	COPPER	0.200	1.3	mg/L	16-20830
High School - AIS	AIS 53 R817	8/4/16 9:47 AM	8/26/16	51300	COPPER	0.194	1.3	mg/L	16-20830
High School - AIS	AIS EXT 54 East ext hose BIB	8/4/16 10:28 AM	8/26/16	51301	COPPER	0.017	1.3	mg/L	16-20830
High School - AIS	AIS EXT 55 West ext hose BIB	8/4/16 10:29 AM	8/26/16	51302	COPPER	0.060	1.3	mg/L	16-20830
High School - AIS	AIS EXT 56 North ext hose BIB	8/4/16 10:34 AM	8/26/16	51303	COPPER	0.033	1.3	mg/L	16-20830
High School - AIS	AIS EXT 57 South ext hose BIB	8/4/16 10:36 AM	8/26/16	51304	COPPER	0.032	1.3	mg/L	16-20830
Maint	M 1 Shop	8/5/16 6:19 AM	8/30/16	51306	COPPER	0.111	1.3	mg/L	16-20832
Maint	M 2 Shop	8/5/16 6:21 AM	8/30/16	51307	COPPER	0.157	1.3	mg/L	16-20832
Maint	M 3 Fountain Shop	8/5/16 6:23 AM	8/30/16	51308	COPPER	0.169	1.3	mg/L	16-20832
Maint	M 4 Shop	8/5/16 6:25 AM	8/30/16	51309	COPPER	0.161	1.3	mg/L	16-20832
Maint	M 5 Shower Shop	8/5/16 6:27 AM	8/30/16	51310	COPPER	0.199	1.3	mg/L	16-20832
Maint	M 6 Show B-R	8/5/16 6:28 AM	8/30/16	51311	COPPER	0.066	1.3	mg/L	16-20832
Maint	M 7 Utility sink breakroom	8/5/16 6:30 AM	8/30/16	51312	COPPER	0.187	1.3	mg/L	16-20832
Maint	M 8 Kitchen sink breakroom	8/5/16 6:31 AM	8/30/16	51313	COPPER	0.194	1.3	mg/L	16-20832
Maint	M 9 S hose BIB	8/5/16 6:38 AM	8/30/16	51314	COPPER	0.012	1.3	mg/L	16-20832
Maint	M 10 N hose BIB	8/5/16 6:40 AM	8/30/16	51315	COPPER	0.013	1.3	mg/L	16-20832
Bridges	B-1 Down #1 Br	8/5/16 7:50 AM	8/26/16	51316	COPPER	0.113	1.3	mg/L	16-20833
Bridges	B-2 Down #2 Br	8/5/16 7:48 AM	8/26/16	51317	COPPER	0.149	1.3	mg/L	16-20833
Bridges	B-3 Down Fountain	8/5/16 7:49 AM	8/26/16	51318	COPPER	0.265	1.3	mg/L	16-20833
Bridges	B-4 Up Br	8/5/16 7:48 AM	8/26/16	51319	COPPER	0.178	1.3	mg/L	16-20833
Bridges	B-5 Custodian	8/5/16 7:47 AM	8/26/16	51320	COPPER	0.221	1.3	mg/L	16-20833
Bridges	B-6 Kitchen	8/5/16 7:46 AM	8/26/16	51321	COPPER	0.067	1.3	mg/L	16-20833
Bridges	B-7 Staff Br	8/5/16 7:45 AM	8/26/16	51322	COPPER	0.185	1.3	mg/L	16-20833

DO	D-1 Kitchen	8/5/16 10:00 AM	8/26/16	51323	COPPER	0.089	1.3	mg/L	16-20834
DO	D-2 Bath Down left	8/5/16 10:04 AM	8/26/16	51324	COPPER	0.084	1.3	mg/L	16-20834
DO	D-3 bath down right	8/5/16 10:05 AM	8/26/16	51325	COPPER	0.090	1.3	mg/L	16-20834
DO	D-4 Fountain short	8/5/16 10:06 AM	8/26/16	51326	COPPER	0.238	1.3	mg/L	16-20834
DO	D-5 Fountain tall	8/5/16 10:06 AM	8/26/16	51327	COPPER	0.254	1.3	mg/L	16-20834
DO	D-6 mens bath down left	8/5/16 10:07 AM	8/26/16	51328	COPPER	0.095	1.3	mg/L	16-20834
DO	D-7 mens bath down right	8/5/16 10:08 AM	8/26/16	51329	COPPER	0.086	1.3	mg/L	16-20834
DO	D-8 mens bath up	8/5/16 10:08 AM	8/26/16	51330	COPPER	0.098	1.3	mg/L	16-20834
DO	D-9 woman bath up	8/5/16 10:09 AM	8/26/16	51331	COPPER	0.065	1.3	mg/L	16-20834
DO	D-10 east hose BIB	8/5/16 10:14 AM	8/26/16	51332	COPPER	0.108	1.3	mg/L	16-20834
DO	D-11 N W Hose BIB	8/5/16 10:15 AM	8/26/16	51333	COPPER	0.292	1.3	mg/L	16-20834
DO	D-12 S W Hose BIB	8/5/16 10:16 AM	8/26/16	51334	COPPER	1.65	1.3	mg/L	16-20834
Heritage	HERR HE Lobby B2	8/4/16 6:34 AM	8/26/16	51342	COPPER	0.174	1.3	mg/L	16-20838
Heritage	HERR HE Lobby G1	8/4/16 6:30 AM	8/26/16	51343	COPPER	0.160	1.3	mg/L	16-20838
Heritage	HERR HE Lobby B1	8/4/16 6:34 AM	8/26/16	51344	COPPER	0.171	1.3	mg/L	16-20838
Heritage	HERR HE Lobby G3	8/4/16 6:32 AM	8/26/16	51345	COPPER	0.180	1.3	mg/L	16-20838
Heritage	HERR Core Staff 1	8/4/16 6:53 AM	8/26/16	51346	COPPER	0.193	1.3	mg/L	16-20838
Heritage	HERR HE life skills RR	8/4/16 6:52 AM	8/26/16	51347	COPPER	0.237	1.3	mg/L	16-20838
Heritage	HERR HE Staff RR Women	8/4/16 6:38 AM	8/26/16	51348	COPPER	0.192	1.3	mg/L	16-20838
Heritage	HERR HE E Pod B1	8/4/16 6:42 AM	8/26/16	51349	COPPER	0.176	1.3	mg/L	16-20838
Heritage	HERR HE Lobby G2	8/4/16 6:31 AM	8/26/16	51350	COPPER	0.185	1.3	mg/L	16-20838
Heritage	HERR HE Staff RR Men	8/4/16 6:37 AM	8/26/16	51351	COPPER	0.197	1.3	mg/L	16-20838
Heritage	HERR HE E Pod G2	8/4/16 6:41 AM	8/26/16	51352	COPPER	0.193	1.3	mg/L	16-20838
Heritage	HERR E Pod G1	8/4/16 6:40 AM	8/26/16	51353	COPPER	0.231	1.3	mg/L	16-20838
Heritage	HERR HE Lobby B3	8/4/16 6:35 AM	8/26/16	51354	COPPER	0.174	1.3	mg/L	16-20838
Heritage	HERR F Pod B2	8/4/16 6:56 AM	8/26/16	51355	COPPER	0.207	1.3	mg/L	16-20838
Heritage	HERR Core Staff RR 2	8/4/16 6:54 AM	8/26/16	51356	COPPER	0.200	1.3	mg/L	16-20838
Heritage	HERR F Pod G2	8/4/16 6:58 AM	8/26/16	51357	COPPER	0.188	1.3	mg/L	16-20838
Heritage	HERR F Pod B1	8/4/16 6:55 AM	8/26/16	51358	COPPER	0.215	1.3	mg/L	16-20838
Heritage	HERR G Pod G2	8/4/16 7:11 AM	8/26/16	51359	COPPER	0.204	1.3	mg/L	16-20838
Heritage	HERR G Pod G1	8/4/16 7:10 AM	8/26/16	51360	COPPER	0.208	1.3	mg/L	16-20838
Heritage	HERR F Pod G1	8/4/16 6:57 AM	8/26/16	51361	COPPER	0.194	1.3	mg/L	16-20838
Heritage	HERR HE Lobby B4	8/4/16 6:36 AM	8/26/16	51362	COPPER	0.197	1.3	mg/L	16-20838
Heritage	HERR HERR E Pod B2	8/4/16 6:43 AM	8/26/16	51363	COPPER	0.178	1.3	mg/L	16-20838
Heritage	HERR HE Lobby G4	8/4/16 6:33 AM	8/26/16	51364	COPPER	0.173	1.3	mg/L	16-20838
Heritage	HARR EB1	8/4/16 9:54 AM	8/26/16	51365	COPPER	0.114	1.3	mg/L	16-20838
Heritage	HARR EG3	8/4/16 9:53 AM	8/26/16	51366	COPPER	0.126	1.3	mg/L	16-20838
Heritage	HARR EG2	8/4/16 9:53 AM	8/26/16	51367	COPPER	0.101	1.3	mg/L	16-20838
Heritage	HARR WG3	8/4/16 9:50 AM	8/26/16	51368	COPPER	0.098	1.3	mg/L	16-20838
Heritage	HARR EG1	8/4/16 9:52 AM	8/26/16	51369	COPPER	0.127	1.3	mg/L	16-20838
Heritage	HARR WG1	8/4/16 9:48 AM	8/26/16	51370	COPPER	0.084	1.3	mg/L	16-20838
Heritage	HARR Staff 1	8/4/16 9:56 AM	8/26/16	51371	COPPER	0.123	1.3	mg/L	16-20838

Heritage	HARR Staff 2	8/4/16 9:57 AM	8/26/16	51372	COPPER	0.071	1.3	mg/L	16-20838
Heritage	HERR G Pod B1	8/4/16 7:12 AM	8/26/16	51373	COPPER	0.202	1.3	mg/L	16-20838
Heritage	HERR G Pod B2	8/4/16 7:13 AM	8/26/16	51374	COPPER	0.207	1.3	mg/L	16-20838
Heritage	HACR Rm 38	8/4/16 10:19 AM	8/26/16	51375	COPPER	0.055	1.3	mg/L	16-20838
Heritage	HACR Rm 39	8/4/16 10:20 AM	8/26/16	51376	COPPER	0.051	1.3	mg/L	16-20838
Heritage	HACR Rm 36	8/4/16 10:17 AM	8/26/16	51377	COPPER	0.053	1.3	mg/L	16-20838
Heritage	HACR Rm 47	8/4/16 10:27 AM	8/26/16	51378	COPPER	0.048	1.3	mg/L	16-20838
Heritage	HARR EB2	8/4/16 9:55 AM	8/26/16	51379	COPPER	0.133	1.3	mg/L	16-20838
Heritage	HARR EB3	8/4/16 9:56 AM	8/26/16	51380	COPPER	0.121	1.3	mg/L	16-20838
Heritage	HARR WB2	8/4/16 9:47 AM	8/26/16	51381	COPPER	0.107	1.3	mg/L	16-20838
Heritage	HARR WB3	8/4/16 9:48 AM	8/26/16	51382	COPPER	0.098	1.3	mg/L	16-20838
Heritage	HARR WB1	8/4/16 9:46 AM	8/26/16	51383	COPPER	0.108	1.3	mg/L	16-20838
Heritage	HARR WG2	8/4/16 9:49 AM	8/26/16	51384	COPPER	0.087	1.3	mg/L	16-20838
Heritage	HACR Rm 44	8/4/16 10:23 AM	8/26/16	51385	COPPER	0.062	1.3	mg/L	16-20838
Heritage	HACR Rm 41	8/4/16 10:21 AM	8/26/16	51386	COPPER	0.053	1.3	mg/L	16-20838
Heritage	HACR Rm 35	8/4/16 10:16 AM	8/26/16	51387	COPPER	0.047	1.3	mg/L	16-20838
Heritage	HACR Rm 48	8/4/16 10:28 AM	8/26/16	51388	COPPER	0.046	1.3	mg/L	16-20838
Heritage	HACR Rm 46	8/4/16 10:26 AM	8/26/16	51389	COPPER	0.045	1.3	mg/L	16-20838
Heritage	HACR Rm 42	8/4/16 10:22 AM	8/26/16	51390	COPPER	0.042	1.3	mg/L	16-20838
Heritage	HACR Rm 37	8/4/16 10:18 AM	8/26/16	51391	COPPER	0.147	1.3	mg/L	16-20838
Heritage	HACR Rm 43	8/4/16 10:24 AM	8/26/16	51392	COPPER	0.040	1.3	mg/L	16-20838
Heritage	HACR Rm 34	8/4/16 10:15 AM	8/26/16	51393	COPPER	0.050	1.3	mg/L	16-20838
Heritage	HACR Rm 45	8/4/16 10:25 AM	8/26/16	51394	COPPER	0.044	1.3	mg/L	16-20838
Heritage	HECR Rm 15	8/4/16 7:00 AM	8/26/16	51395	COPPER	0.377	1.3	mg/L	16-20838
Heritage	HECR Rm 6	8/4/16 6:49 AM	8/26/16	51396	COPPER	0.217	1.3	mg/L	16-20838
Heritage	HECR Rm 12	8/4/16 7:05 AM	8/26/16	51397	COPPER	0.367	1.3	mg/L	16-20838
Heritage	HECR Rm 20	8/4/16 7:20 AM	8/26/16	51398	COPPER	0.225	1.3	mg/L	16-20838
Heritage	HECR Rm 24	8/4/16 6:17 AM	8/26/16	51399	COPPER	0.209	1.3	mg/L	16-20838
Heritage	HECR Rm 18	8/4/16 7:21 AM	8/26/16	51400	COPPER	0.206	1.3	mg/L	16-20838
Heritage	HECR Rm 23	8/4/16 7:15 AM	8/26/16	51401	COPPER	0.266	1.3	mg/L	16-20838
Heritage	HECR Rm 22	8/4/16 7:19 AM	8/26/16	51402	COPPER	0.246	1.3	mg/L	16-20838
Heritage	HECR Rm 21	8/4/16 7:14 AM	8/26/16	51403	COPPER	0.387	1.3	mg/L	16-20838
Heritage	HECR Rm 25	8/4/16 7:16 AM	8/26/16	51404	COPPER	0.316	1.3	mg/L	16-20838
Heritage	HECR Rm 16	8/4/16 7:03 AM	8/26/16	51405	COPPER	0.457	1.3	mg/L	16-20838
Heritage	HECR Rm 2	8/4/16 6:28 AM	8/26/16	51406	COPPER	0.206	1.3	mg/L	16-20838
Heritage	HECR Rm 1	8/4/16 6:25 AM	8/26/16	51407	COPPER	0.261	1.3	mg/L	16-20838
Heritage	HECR Rm 19	8/4/16 7:09 AM	8/26/16	51408	COPPER	0.254	1.3	mg/L	16-20838
Heritage	HECR Rm 13	8/4/16 6:59 AM	8/26/16	51409	COPPER	0.219	1.3	mg/L	16-20838
Heritage	HECR Rm 10	8/4/16 7:06 AM	8/26/16	51410	COPPER	0.239	1.3	mg/L	16-20838
Heritage	HECR Rm 17	8/4/16 7:02 AM	8/26/16	51411	COPPER	0.244	1.3	mg/L	16-20838
Heritage	HECR Rm 11	8/4/16 6:59 AM	8/26/16	51412	COPPER	0.205	1.3	mg/L	16-20838
Heritage	HECR Rm 14	8/4/16 7:04 AM	8/30/16	51413	COPPER	1.24	1.3	mg/L	16-20838

Heritage	HECR Rm 3	8/4/16 6:44 AM	8/26/16	51414	COPPER	0.198	1.3	mg/L	16-20838
Heritage	K K Chem disp sink	8/4/16 6:20 AM	8/26/16	51415	COPPER	0.161	1.3	mg/L	16-20838
Heritage	K Dishwasher sink	8/4/16 6:19 AM	8/26/16	51416	COPPER	0.149	1.3	mg/L	16-20838
Heritage	K Kitchen RR	8/4/16 6:16 AM	8/26/16	51417	COPPER	0.211	1.3	mg/L	16-20838
Heritage	K Handwash 2	8/4/16 6:18 AM	8/26/16	51418	COPPER	0.205	1.3	mg/L	16-20838
Heritage	K Handwash 1	8/4/16 6:17 AM	8/26/16	51419	COPPER	0.190	1.3	mg/L	16-20838
Heritage	HECR Rm 7	8/4/16 6:46 AM	8/26/16	51420	COPPER	0.204	1.3	mg/L	16-20838
Heritage	HECR Rm 9	8/4/16 6:48 AM	8/26/16	51421	COPPER	0.236	1.3	mg/L	16-20838
Heritage	HECR Rm 4	8/4/16 6:50 AM	8/26/16	51422	COPPER	0.418	1.3	mg/L	16-20838
Heritage	HECR Rm 8	8/4/16 6:48 AM	8/26/16	51423	COPPER	0.249	1.3	mg/L	16-20838
Heritage	HECR Rm 5	8/4/16 6:45 AM	8/26/16	51424	COPPER	0.224	1.3	mg/L	16-20838
Heritage	HE Health Rm Health Rm	8/4/16 6:27 AM	8/26/16	51425	COPPER	0.256	1.3	mg/L	16-20838
Heritage	C Annex W	8/4/16 9:45 AM	8/26/16	51426	COPPER	0.035	1.3	mg/L	16-20838
Heritage	C Annex E	8/4/16 9:51 AM	8/26/16	51427	COPPER	0.084	1.3	mg/L	16-20838
Heritage	C HE Core	8/4/16 7:07 AM	8/26/16	51428	COPPER	0.249	1.3	mg/L	16-20838
Heritage	C Café main	8/4/16 6:23 AM	8/26/16	51429	COPPER	0.229	1.3	mg/L	16-20838
Heritage	HE Pod F Pod	8/4/16 7:01 AM	8/26/16	51430	COPPER	0.205	1.3	mg/L	16-20838
Heritage	HE Pod G Pod	8/4/16 7:18 AM	8/26/16	51431	COPPER	0.184	1.3	mg/L	16-20838
Heritage	HE Pod Pod E	8/4/16 6:47 AM	8/26/16	51432	COPPER	0.221	1.3	mg/L	16-20838
Heritage	Kitchen Kitchen small kettle	8/4/16 6:22 AM	8/26/16	51433	COPPER	0.125	1.3	mg/L	16-20838
Heritage	K Kitchen Large Kettle	8/4/16 6:21 AM	8/26/16	51434	COPPER	0.154	1.3	mg/L	16-20838
Heritage	E Loading Dock	8/4/16 10:52 AM	8/26/16	51435	COPPER	0.330	1.3	mg/L	16-20838
Heritage	E 2nd grade	8/4/16 10:45 AM	8/26/16	51436	COPPER	0.479	1.3	mg/L	16-20838
Heritage	E Generator	8/4/16 10:50 AM	8/26/16	51437	COPPER	0.425	1.3	mg/L	16-20838
Heritage	E HE Annex Front	8/4/16 10:38 AM	8/26/16	51438	COPPER	0.049	1.3	mg/L	16-20838
Heritage	E Kpod E	8/4/16 10:39 AM	8/26/16	51439	COPPER	0.409	1.3	mg/L	16-20838
Heritage	E HE Annex Rear	8/4/16 10:40 AM	8/26/16	51440	COPPER	0.136	1.3	mg/L	16-20838
Heritage	E 1st grade	8/4/16 10:43 AM	8/26/16	51441	COPPER	0.419	1.3	mg/L	16-20838
Heritage	E K Pod W	8/4/16 10:46 AM	8/26/16	51442	COPPER	0.232	1.3	mg/L	16-20838
Heritage	E HE Office	8/4/16 10:48 AM	8/26/16	51443	COPPER	0.287	1.3	mg/L	16-20838
Heritage	HE Core He Media Work Rm	8/4/16 6:51 AM	8/26/16	51444	COPPER	0.361	1.3	mg/L	16-20838
VCR	L B Shower 1	8/4/16 7:40 AM	8/26/16	51467	COPPER	0.588	1.3	mg/L	16-20851
VCR	L B Shower 2	8/4/16 7:41 AM	8/26/16	51468	COPPER	0.293	1.3	mg/L	16-20851
VCR	L B Shower 4	8/4/16 7:43 AM	8/26/16	51469	COPPER	0.336	1.3	mg/L	16-20851
VCR	L G Coach Shower	8/4/16 7:34 AM	8/26/16	51470	COPPER	0.207	1.3	mg/L	16-20851
VCR	L G coach sink	8/4/16 7:35 AM	8/26/16	51471	COPPER	0.251	1.3	mg/L	16-20851
VCR	L G RR 3	8/4/16 7:33 AM	8/26/16	51472	COPPER	0.319	1.3	mg/L	16-20851
VCR	L G RR 1	8/4/16 7:32 AM	8/26/16	51473	COPPER	0.254	1.3	mg/L	16-20851
VCR	L G RR 2	8/4/16 7:33 AM	8/26/16	51474	COPPER	0.391	1.3	mg/L	16-20851
VCR	L B Shower 3	8/4/16 7:42 AM	8/30/16	51475	COPPER	2.22	1.3	mg/L	16-20851
VCR	L G Shower 4	8/4/16 7:31 AM	8/26/16	51476	COPPER	0.330	1.3	mg/L	16-20851
VCR	L G Shower 3	8/4/16 7:30 AM	8/30/16	51477	COPPER	0.840	1.3	mg/L	16-20851

VCR	L G Shower 2	8/4/16 7:29 AM	8/26/16	51478	COPPER	0.431	1.3	mg/L	16-20851
VCR	L G Shower 1	8/4/16 7:28 AM	8/26/16	51479	COPPER	0.126	1.3	mg/L	16-20851
VCR	L B RR 2	8/4/16 7:39 AM	8/26/16	51480	COPPER	0.209	1.3	mg/L	16-20851
VCR	L B Coach Shower	8/4/16 7:36 AM	8/26/16	51481	COPPER	0.264	1.3	mg/L	16-20851
VCR	L B RR 1	8/4/16 7:38 AM	8/26/16	51482	COPPER	0.223	1.3	mg/L	16-20851
VCR	L B Coach sink	8/4/16 7:37 AM	8/26/16	51483	COPPER	0.216	1.3	mg/L	16-20851
VCR	L B RR 3	8/4/16 7:39 AM	8/26/16	51484	COPPER	0.209	1.3	mg/L	16-20851
VCR	V Core Upstairs sink	8/4/16 9:20 AM	8/26/16	51485	COPPER	0.250	1.3	mg/L	16-20851
VCR	V Office Health Rm	8/4/16 7:54 AM	8/26/16	51486	COPPER	0.203	1.3	mg/L	16-20851
VCR	VC Band Hall	8/4/16 7:46 AM	8/26/16	51487	COPPER	0.188	1.3	mg/L	16-20851
VCR	VC Valor Downstairs	8/4/16 8:49 AM	8/26/16	51488	COPPER	0.137	1.3	mg/L	16-20851
VCR	VC V upstairs	8/4/16 9:11 AM	8/26/16	51489	COPPER	0.125	1.3	mg/L	16-20851
VCR	VE Laundry	8/4/16 1:40 PM	8/26/16	51490	COPPER	0.268	1.3	mg/L	16-20851
VCR	VE V Office	8/4/16 1:41 PM	8/26/16	51491	COPPER	0.208	1.3	mg/L	16-20851
VCR	VE V band hall	8/4/16 1:43 PM	8/26/16	51492	COPPER	0.305	1.3	mg/L	16-20851
VCR	VE Science Closet S2	8/4/16 1:34 PM	8/26/16	51493	COPPER	0.357	1.3	mg/L	16-20851
VCR	VRR Life skills	8/4/16 8:44 AM	8/26/16	51494	COPPER	0.204	1.3	mg/L	16-20851
VCR	VRR Lobby G2	8/4/16 7:51 AM	8/26/16	51495	COPPER	0.187	1.3	mg/L	16-20851
VCR	VRR Work Rm Staff 2	8/4/16 8:03 AM	8/26/16	51496	COPPER	0.291	1.3	mg/L	16-20851
VCR	VRR downstairs G1	8/4/16 8:51 AM	8/26/16	51497	COPPER	0.218	1.3	mg/L	16-20851
VCR	VRR Downstairs staff	8/4/16 9:00 AM	8/26/16	51498	COPPER	0.228	1.3	mg/L	16-20851
VCR	VRR Downstairs B1	8/4/16 8:53 AM	8/26/16	51499	COPPER	0.238	1.3	mg/L	16-20851
VCR	VRR Workroom staff 1	8/4/16 8:02 AM	8/26/16	51500	COPPER	0.219	1.3	mg/L	16-20851
VCR	VRR downstairs G2	8/4/16 8:52 AM	8/26/16	51501	COPPER	0.238	1.3	mg/L	16-20851
VCR	VRR Upstairs B2	8/4/16 9:16 AM	8/26/16	51502	COPPER	0.225	1.3	mg/L	16-20851
VCR	VRR Downstairs B2	8/4/16 8:54 AM	8/26/16	51503	COPPER	0.228	1.3	mg/L	16-20851
VCR	VRR Lobby G1	8/4/16 7:50 AM	8/26/16	51504	COPPER	0.195	1.3	mg/L	16-20851
VCR	VRR Lobby B1	8/4/16 7:52 AM	8/26/16	51505	COPPER	0.196	1.3	mg/L	16-20851
VCR	VRR Lobby B2	8/4/16 7:53 AM	8/26/16	51506	COPPER	0.225	1.3	mg/L	16-20851
VCR	VRR Upstairs G2	8/4/16 9:14 AM	8/26/16	51507	COPPER	0.231	1.3	mg/L	16-20851
VCR	VRR Upstairs G1	8/4/16 9:13 AM	8/26/16	51508	COPPER	0.217	1.3	mg/L	16-20851
VCR	VRR Upstairs B1	8/4/16 9:15 AM	8/26/16	51509	COPPER	0.237	1.3	mg/L	16-20851
VCR	VRR Upstairs Staff	8/4/16 9:19 AM	8/26/16	51510	COPPER	0.214	1.3	mg/L	16-20851
VCR	VCR 201	8/4/16 9:38 AM	8/26/16	51511	COPPER	0.377	1.3	mg/L	16-20851
VCR	VCR 104 S6	8/4/16 9:08 AM	8/26/16	51512	COPPER	0.200	1.3	mg/L	16-20851
VCR	VCR 104 S1	8/4/16 9:06 AM	8/26/16	51513	COPPER	0.815	1.3	mg/L	16-20851
VCR	VCR 209	8/4/16 9:24 AM	8/26/16	51514	COPPER	1.465	1.3	mg/L	16-20851
VCR	VCR 205 S8	8/4/16 9:33 AM	8/26/16	51515	COPPER	0.318	1.3	mg/L	16-20851
VCR	VCR 207	8/4/16 9:25 AM	8/26/16	51516	COPPER	0.221	1.3	mg/L	16-20851
VCR	VCR 208	8/4/16 9:17 AM	8/26/16	51517	COPPER	0.248	1.3	mg/L	16-20851
VCR	VCR 104 S3	8/4/16 9:57 AM	8/26/16	51518	COPPER	0.673	1.3	mg/L	16-20851
VCR	VCR 104 S2	8/4/16 9:56 AM	8/26/16	51519	COPPER	0.372	1.3	mg/L	16-20851



VCR	VCR 104 S8	8/4/16 9:10 AM	8/26/16	51520	COPPER	0.401	1.3	mg/L	16-20851
VCR	VCR 104 S7	8/4/16 9:09 AM	8/26/16	51521	COPPER	0.282	1.3	mg/L	16-20851
VCR	VCR 206	8/4/16 9:17 AM	8/26/16	51522	COPPER	0.297	1.3	mg/L	16-20851
VCR	VCR 104 S4	8/4/16 9:57 AM	8/26/16	51523	COPPER	6.529	1.3	mg/L	16-20851
VCR	VCR 104 S5	8/4/16 9:08 AM	8/26/16	51524	COPPER	1.015	1.3	mg/L	16-20851
VCR	VCR 205 S7	8/4/16 9:32 AM	8/26/16	51525	COPPER	0.336	1.3	mg/L	16-20851
VCR	VCR 205 S6	8/4/16 9:31 AM	8/26/16	51526	COPPER	0.254	1.3	mg/L	16-20851
VCR	VCR 210	8/4/16 9:18 AM	8/26/16	51527	COPPER	0.226	1.3	mg/L	16-20851
VCR	VCR 203	8/4/16 9:37 AM	8/26/16	51528	COPPER	0.221	1.3	mg/L	16-20851
VCR	VCR 205 S5	8/4/16 9:30 AM	8/26/16	51529	COPPER	0.298	1.3	mg/L	16-20851
VCR	VCR 204	8/4/16 9:36 AM	8/26/16	51530	COPPER	0.249	1.3	mg/L	16-20851
VCR	VCR 211	8/4/16 9:13 AM	8/26/16	51531	COPPER	0.248	1.3	mg/L	16-20851
VCR	VCR 205 S4	8/4/16 9:29 AM	8/26/16	51532	COPPER	0.495	1.3	mg/L	16-20851
VCR	VCR 205 S1	8/4/16 9:26 AM	8/26/16	51533	COPPER	0.393	1.3	mg/L	16-20851
VCR	VCR 205 S2	8/4/16 9:27 AM	8/26/16	51534	COPPER	0.258	1.3	mg/L	16-20851
VCR	VCR 212	8/4/16 9:22 AM	8/26/16	51535	COPPER	0.363	1.3	mg/L	16-20851
VCR	VCR 205 S3	8/4/16 9:28 AM	8/26/16	51536	COPPER	0.283	1.3	mg/L	16-20851
VCR	VCR 105 S2	8/4/16 8:56 AM	8/26/16	51537	COPPER	0.215	1.3	mg/L	16-20851
VCR	VCR 105 S4	8/4/16 8:58 AM	8/26/16	51538	COPPER	0.284	1.3	mg/L	16-20851
VCR	VCR 105 S1	8/4/16 8:56 AM	8/26/16	51539	COPPER	0.258	1.3	mg/L	16-20851
VCR	VCR 105 S3	8/4/16 8:57 AM	8/26/16	51540	COPPER	0.382	1.3	mg/L	16-20851
VCR	VCR 101	8/4/16 8:45 AM	8/26/16	51541	COPPER	0.274	1.3	mg/L	16-20851
VCR	VCR 106	8/4/16 9:05 AM	8/26/16	51542	COPPER	0.268	1.3	mg/L	16-20851
VCR	VCR 103	8/4/16 8:55 AM	8/26/16	51543	COPPER	0.675	1.3	mg/L	16-20851
VCR	VCR Library Office	8/4/16 9:47 AM	8/26/16	51544	COPPER	0.260	1.3	mg/L	16-20851
VCR	VCR Band	8/4/16 7:45 AM	8/26/16	51545	COPPER	0.239	1.3	mg/L	16-20851
VCR	VCR 105 S5	8/4/16 8:59 AM	8/26/16	51546	COPPER	0.277	1.3	mg/L	16-20851
VCR	VCR 108	8/4/16 9:04 AM	8/26/16	51547	COPPER	0.291	1.3	mg/L	16-20851
VCR	VCR A6	8/4/16 7:54 AM	8/26/16	51548	COPPER	0.242	1.3	mg/L	16-20851
VCR	VCR A6 Office	8/4/16 7:55 AM	8/26/16	51549	COPPER	0.226	1.3	mg/L	16-20851
VCR	VCR 109	8/4/16 9:03 AM	8/26/16	51550	COPPER	0.243	1.3	mg/L	16-20851
VCR	VCR 107 S2	8/4/16 9:02 AM	8/26/16	51551	COPPER	0.305	1.3	mg/L	16-20851
VCR	VCR 107 S1	8/4/16 9:01 AM	8/26/16	51552	COPPER	0.275	1.3	mg/L	16-20851
LES	A1 Kitchen	8/31/16 5:50 AM	9/12/16	52713	COPPER	0.067	1.3	mg/L	16-21391
LES	A2 Kitchen	8/31/16 5:50 AM	9/12/16	52714	COPPER	0.163	1.3	mg/L	16-21391
Nellie Retest	N28 N28 - Kitchen Sprayer	9/2/16 12:06 AM	9/14/16	53408	COPPER	0.085	1.3	mg/L	16-21705
High School	T2K High School Kitchen Sink	9/13/16 7:00 AM	9/15/16	55353	COPPER	0.021	1.3	mg/L	16-22614
High School	T2N High School Nurse Sink	9/13/16 7:15 AM	9/15/16	55354	COPPER	0.009	1.3	mg/L	16-22614
High School	T2116 High School Rm 116 Sink	9/13/16 7:20 AM	9/15/16	55355	COPPER	0.063	1.3	mg/L	16-22614
Heritage	H-1 Rm-1	10/18/16 7:30 AM	10/20/16	63716	COPPER	0.257	1.3	mg/L	16-26013
D/O	DO-1 Front Right Hose Bibb	10/18/16 8:35 AM	10/20/16	63717	COPPER	0.076	1.3	mg/L	16-26014
Nellie	N-1 Rm 13	10/18/16 7:08 AM	10/20/16	63719	COPPER	0.029	1.3	mg/L	16-26016

Valor	V-1 Girls Locker Rm Shower	10/18/16 7:22 AM	10/20/16	63720	COPPER	0.728	1.3	mg/L	16-26017
Valor	V-2 Girls Locker Rm Shower	10/18/16 7:22 AM	10/20/16	63721	COPPER	0.532	1.3	mg/L	16-26017
Valor	V-3 Boys Locker Rm Shower	10/18/16 7:25 AM	10/20/16	63722	COPPER	0.736	1.3	mg/L	16-26017
Valor	V-4 Boys Locker Rm Shower	10/18/16 7:25 AM	10/20/16	63723	COPPER	0.542	1.3	mg/L	16-26017
Valor	V-5 Boys Locker Rm Shower	10/18/16 7:25 AM	10/21/16	63724	COPPER	2.3	1.3	mg/L	16-26017
Valor	V-6 Boys Locker Rm Shower	10/18/16 7:26 AM	10/20/16	63725	COPPER	0.534	1.3	mg/L	16-26017
Valor	V-7 Rm 209 Faucet	10/18/16 7:31 AM	10/20/16	63726	COPPER	0.240	1.3	mg/L	16-26017
Valor	V-8 Rm 209 Bubbler	10/18/16 7:31 AM	10/20/16	63727	COPPER	0.242	1.3	mg/L	16-26017
Washington	WES-1 Girls Front Hall Bathroom	10/18/16 8:18 AM	10/20/16	63744	COPPER	0.110	1.3	mg/L	16-26024
Washington	WES-2 Rm 7	10/18/16 8:20 AM	10/20/16	63745	COPPER	0.023	1.3	mg/L	16-26024
Washington	WES-3 Rm 10	10/18/16 8:21 AM	10/20/16	63746	COPPER	0.081	1.3	mg/L	16-26024
Washington	WES-4 Rm 13	10/18/16 8:23 AM	10/20/16	63747	COPPER	0.012	1.3	mg/L	16-26024
Washington	WES-5 Rm 14	10/18/16 8:24 AM	10/20/16	63748	COPPER	0.073	1.3	mg/L	16-26024
Washington	WES-6 Rm 16	10/18/16 8:25 AM	10/20/16	63749	COPPER	0.072	1.3	mg/L	16-26024
High School	W-1 Girls Team Rm Coach Shower	10/18/16 7:55 AM	10/20/16	63750	COPPER	0.266	1.3	mg/L	16-26025
High School	W-2 Girls Locker Rm Shower	10/18/16 7:58 AM	10/20/16	63751	COPPER	0.130	1.3	mg/L	16-26025
High School	W-3 Boys Locker Rm Shower	10/18/16 7:58 AM	10/20/16	63752	COPPER	0.335	1.3	mg/L	16-26025
High School	W-4 Boys Locker Rm Shower	10/18/16 7:59 AM	10/20/16	63753	COPPER	0.283	1.3	mg/L	16-26025
High School	W-5 Boys Locker Rm Shower	10/18/16 7:59 AM	10/20/16	63754	COPPER	0.102	1.3	mg/L	16-26025
High School	W-6 Boys Locker Rm Shower	10/18/16 8:00 AM	10/20/16	63755	COPPER	0.136	1.3	mg/L	16-26025
High School	W-7 Boys Locker Rm Shower	10/18/16 8:01 AM	10/20/16	63756	COPPER	0.200	1.3	mg/L	16-26025
High School	W-8 Boys Locker Rm Shower	10/18/16 8:01 AM	10/20/16	63757	COPPER	0.208	1.3	mg/L	16-26025
High School	W-9 Boys Locker Rm Shower	10/18/16 8:03 AM	10/20/16	63758	COPPER	0.267	1.3	mg/L	16-26025
High School	W-10 Boys Locker Rm Shower	10/18/16 8:03 AM	10/20/16	63759	COPPER	0.074	1.3	mg/L	16-26025
High School	W-11 Boys Locker Rm Shower	10/18/16 8:05 AM	10/20/16	63760	COPPER	0.182	1.3	mg/L	16-26025
High School	W-12 Boys Locker Rm Shower	10/18/16 8:06 AM	10/20/16	63761	COPPER	0.089	1.3	mg/L	16-26025
High School	W-13 Boys Locker Rm Shower	10/18/16 8:06 AM	10/20/16	63762	COPPER	0.132	1.3	mg/L	16-26025
French Prairie	F-1 Girls Locker Rm Shower	10/18/16 6:38 AM	10/20/16	63763	COPPER	0.075	1.3	mg/L	16-26026
French Prairie	F-2 Girls Locker Rm Shower	10/18/16 6:39 AM	10/20/16	63764	COPPER	0.030	1.3	mg/L	16-26026
French Prairie	F-3 Girls Locker Rm Shower	10/18/16 6:39 AM	10/20/16	63765	COPPER	0.082	1.3	mg/L	16-26026
French Prairie	F-4 Girls Locker Rm Shower	10/18/16 6:39 AM	10/20/16	63766	COPPER	0.031	1.3	mg/L	16-26026
French Prairie	F-5 Girls Locker Rm Shower	10/18/16 6:40 AM	10/20/16	63767	COPPER	0.054	1.3	mg/L	16-26026
French Prairie	F-6 Girls Locker Rm Shower	10/18/16 6:40 AM	10/20/16	63768	COPPER	0.327	1.3	mg/L	16-26026
French Prairie	F-7 Girls Locker Rm Shower	10/18/16 6:40 AM	10/20/16	63769	COPPER	0.114	1.3	mg/L	16-26026
French Prairie	F-8 Girls Locker Rm Shower	10/18/16 6:41 AM	10/20/16	63770	COPPER	0.042	1.3	mg/L	16-26026
French Prairie	F-9 Girls Locker Rm Shower	10/18/16 6:41 AM	10/20/16	63771	COPPER	0.109	1.3	mg/L	16-26026
French Prairie	F-10 Girls Locker Rm Shower	10/18/16 6:42 AM	10/20/16	63772	COPPER	0.014	1.3	mg/L	16-26026
French Prairie	F-11 Girls Locker Rm Shower	10/18/16 6:44 AM	10/20/16	63773	COPPER	0.204	1.3	mg/L	16-26026
French Prairie	F-12 Boys Locker Rm Shower	10/18/16 6:47 AM	10/20/16	63774	COPPER	0.030	1.3	mg/L	16-26026
French Prairie	F-13 Boys Locker Rm Shower	10/18/16 6:48 AM	10/25/16	63775	COPPER	0.113	1.3	mg/L	16-26026
French Prairie	F-14 Boys Locker Rm Shower	10/18/16 6:48 AM	10/25/16	63776	COPPER	0.050	1.3	mg/L	16-26026
French Prairie	F-15 Boys Locker Rm Shower	10/18/16 6:49 AM	10/25/16	63777	COPPER	0.069	1.3	mg/L	16-26026

French Prairie	F-16 Boys Locker Rm Shower	10/18/16 6:49 AM	10/25/16	63778	COPPER	0.016	1.3	mg/L	16-26026
French Prairie	F-17 Boys Locker Rm Shower	10/18/16 6:50 AM	10/25/16	63779	COPPER	0.037	1.3	mg/L	16-26026
French Prairie	F-18 Boys Locker Rm Shower	10/18/16 6:50 AM	10/25/16	63780	COPPER	0.041	1.3	mg/L	16-26026
French Prairie	F-19 Boys Locker Rm Shower	10/18/16 6:50 AM	10/25/16	63781	COPPER	0.115	1.3	mg/L	16-26026
French Prairie	F-20 Boys Locker Rm Shower	10/18/16 6:52 AM	10/25/16	63782	COPPER	0.142	1.3	mg/L	16-26026
French Prairie	F-21 Boys Locker Rm Shower	10/18/16 6:52 AM	10/25/16	63783	COPPER	0.035	1.3	mg/L	16-26026
French Prairie	F-22 Boys Locker Rm Shower	10/18/16 6:52 AM	10/25/16	63784	COPPER	0.036	1.3	mg/L	16-26026
French Prairie	F-23 Boys Locker Rm Shower	10/18/16 6:55 AM	10/25/16	63785	COPPER	0.072	1.3	mg/L	16-26026
French Prairie	F-24 Boys Locker Rm Shower	10/18/16 6:56 AM	10/25/16	63786	COPPER	0.019	1.3	mg/L	16-26026
French Prairie	F-25 Boys Locker Rm Shower	10/18/16 6:56 AM	10/25/16	63787	COPPER	0.025	1.3	mg/L	16-26026
French Prairie	F-26 Boys Locker Rm Shower	10/18/16 6:58 AM	10/25/16	63788	COPPER	0.016	1.3	mg/L	16-26026
French Prairie	F-27 Boys Locker Rm Shower	10/18/16 6:58 AM	10/25/16	63789	COPPER	0.020	1.3	mg/L	16-26026
Lincoln	L-1 Girls Gym Bath Left	10/18/16 6:06 AM	10/25/16	63790	COPPER	0.081	1.3	mg/L	16-26027
Lincoln	L-2 Boys Gym Bath Left	10/18/16 6:08 AM	10/25/16	63791	COPPER	0.262	1.3	mg/L	16-26027
Lincoln	L-3 Boys Gym Bath Right	10/18/16 6:10 AM	10/25/16	63792	COPPER	0.041	1.3	mg/L	16-26027
Lincoln	L-4 Rm 6	10/18/16 6:12 AM	10/25/16	63793	COPPER	0.260	1.3	mg/L	16-26027
Lincoln	L-5 Rm 8	10/18/16 6:14 AM	10/25/16	63794	COPPER	0.248	1.3	mg/L	16-26027
Lincoln	L-6 Rm 14	10/18/16 6:15 AM	10/25/16	63795	COPPER	0.214	1.3	mg/L	16-26027
Lincoln	L-7 Rm 16	10/18/16 6:17 AM	10/25/16	63796	COPPER	0.091	1.3	mg/L	16-26027
Lincoln	L-8 Rm 18 Faucet	10/18/16 6:18 AM	10/25/16	63797	COPPER	0.196	1.3	mg/L	16-26027
Lincoln	L-9 Rm 18 Bubbler	10/18/16 6:18 AM	10/25/16	63798	COPPER	0.167	1.3	mg/L	16-26027
Lincoln	L-10 Rm 19 Faucet Left	10/18/16 6:20 AM	10/25/16	63799	COPPER	0.637	1.3	mg/L	16-26027
Lincoln	L-11 Rm 19 Bubbler	10/18/16 6:20 AM	10/25/16	63800	COPPER	0.431	1.3	mg/L	16-26027
Lincoln	L-12 Rm 19 High Faucet Right	10/18/16 6:20 AM	10/25/16	63801	COPPER	0.046	1.3	mg/L	16-26027
Lincoln	L-13 Rm 20 Faucet	10/18/16 6:22 AM	10/25/16	63802	COPPER	0.199	1.3	mg/L	16-26027
Lincoln	L-14 Rm 20 Bubbler	10/18/16 6:22 AM	10/25/16	63803	COPPER	0.190	1.3	mg/L	16-26027
Lincoln	L-15 North Hall Bubbler	10/18/16 6:25 AM	10/25/16	63804	COPPER	0.019	1.3	mg/L	16-26027
Lincoln	L-16 Rm 29	10/18/16 6:26 AM	10/25/16	63805	COPPER	0.115	1.3	mg/L	16-26027
Lincoln	L-17 Back Hallway Boys Right Bath	10/18/16 6:26 AM	10/25/16	63806	COPPER	0.171	1.3	mg/L	16-26027
Lincoln	L-18 Rm 32	10/18/16 6:27 AM	10/25/16	63807	COPPER	0.195	1.3	mg/L	16-26027
Lincoln	L-19 Rm 2 Faucet	10/18/16 6:29 AM	10/25/16	63808	COPPER	0.212	1.3	mg/L	16-26027
Lincoln	L-20 Rm 2 Bubbler	10/18/16 6:29 AM	10/25/16	63809	COPPER	0.034	1.3	mg/L	16-26027
Lincoln	L-21 Main Office Faucet	10/18/16 6:31 AM	10/25/16	63810	COPPER	0.034	1.3	mg/L	16-26027
Lincoln	L-22 Library Office Faucet	10/18/16 6:31 AM	10/25/16	63811	COPPER	0.006	1.3	mg/L	16-26027
Lincoln	L-23 Gym Girls Bath Right	10/18/16 6:32 AM	10/25/16	63812	COPPER	0.018	1.3	mg/L	16-26027