

October 2022

CLEAN

SAFE

HEALTHY

SCHOOLS

Amity Regional School
District No. 5

25 Newton Road

Woodbridge, CT 06525

Phone: 203-397-4817

Fax: 203-397-4864



Amity Regional School District No. 5

Facilities Department Monthly Report

Completed Projects:

- All snow removal equipment District-wide was serviced and ready for the start of the winter season.
- The District Office remodel was completed.
- A faulty light sensor for one of the gym lights at ARHS was replaced.
- A few damper actuators for the rooftop air handlers at AMSO were replaced by the District maintenance staff.
- District-wide winter preventative maintenance work on the air handlers was completed.

Projects in Process:

- Bid specifications are being developed for rerouting the two chilled water lines that currently run underground and up into the CTE classroom.
- All lighting fixtures in AMSO and AMSB are being re-lamped with different bulbs due to problems with existing bulbs.
- The glycol loop at AMSO is still continuing to be flushed and cleaned with the new filter in place.
- Bid specifications are being developed for remodeling the ARHS lecture hall.
- The DESIGO building management system software upgrade for ARHS is wrapping up.
- The outdoor classroom project for both AMSB and AMSO has begun. Piers and the slabs for both structures have been poured. Structures are scheduled to be shipped on December 5th.

Outstanding issues to be addressed: