


Report of Analysis

Name:	Parkway School Greenwich Public Schools - Cordes George 290 Greenwich Ave Greenwich, CT 06830-6521	Sample ID#:	301248
		Sample Type:	Drinking Water
		Sample Source:	PS017
Sample Date:	11/17/2022 7:30 AM	Sampler:	PD
Receipt Date:	11/17/2022 9:48 AM	PWS ID:	CT0570212
Report Date:	11/18/2022		
Sample Site:	DISTRIBUTION SYSTEM		

Parameter	Sample Result	Units	MCL	Method	RL	Analysis Date/Time	Analyst
Physical							
Color, apparent	<5	CU	15	SM 2120B-01	5	11/17/2022 14:30	LD
Odor	0	TON	3	SM2150B-2011	0	11/17/2022 14:30	LD
PH	7.56	pH	6.4 - 8.5	SM4500HB-2011	0	11/17/2022 09:48	PD
Turbidity	0.60	NTU	5	EPA 180.1	0.05	11/17/2022 14:30	LD

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
 * = Above Specified Limit

Report Approved by:  _____ CT Lic PH-0787 NY Lic 11706
 Lab Director

AquaEnvLab.com
 YorkLab.com
 203 270 9973

MCL (MCL – Maximum Contaminant Level)

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.