



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/22/2022
Received: 07/12/2022
Sampled By: C Spear
Work Order: 2195009

**C
L
I
E
N
T**
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Philo m/s
Project # : 2022044
Sample Type : Grab
PO # : 2022044

Sampling Location: Philomath m/s (middle school)

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2195009-01	Sample Name: 1900 0021 - 210 DW22A Sampled: 7/11/22 15:00 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/19/22 14:08
2195009-02	Sample Name: 1900 0021 - 211 NS22A Sampled: 7/11/22 15:01 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/19/22 14:08
2195009-03	Sample Name: 1900 0021 - 212 SF22A Sampled: 7/11/22 15:02 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/19/22 14:08
2195009-04	Sample Name: 1900 0021 - 213 BF 22A Sampled: 7/11/22 15:05 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/19/22 14:08
2195009-05	Sample Name: 1900 0021 - 214 BF 22A Sampled: 7/11/22 15:06 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/19/22 14:08
2195009-06	Sample Name: 1900 0021 - 215 DW22A Sampled: 7/11/22 15:10 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/19/22 14:08
2195009-07	Sample Name: 1900 0021 - 216 BF22A Sampled: 7/11/22 15:11 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/19/22 14:08
2195009-08	Sample Name: 1900 0021 - 217 BF22A Sampled: 7/11/22 15:12 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/19/22 14:08
2195009-09	Sample Name: 1900 0021 - 218 BF22A Sampled: 7/11/22 15:13 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/19/22 14:08
2195009-10	Sample Name: 1900 0021 - 219 DW22A Sampled: 7/11/22 15:15 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/19/22 14:08



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/22/2022
Received: 07/12/2022
Sampled By: C Spear
Work Order: 2195009

**C
L
I
E
N
T**
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Philo m/s
Project # : 2022044
Sample Type : Grab
PO # : 2022044

Sampling Location: Philomath m/s (middle school)

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2195009-11	Sample Name: 1900 0021 - 220 BF22A Sampled: 7/11/22 15:30 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/19/22 14:08
2195009-12	Sample Name: 1900 0021 - 221 BF22A Sampled: 7/11/22 15:31 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/19/22 14:08
2195009-13	Sample Name: 1900 0021 - 222 DW22A Sampled: 7/11/22 15:32 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/19/22 14:08
2195009-14	Sample Name: 1900 0021 - 223 KF22A Sampled: 7/11/22 15:40 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/19/22 14:08
2195009-15	Sample Name: 1900 0021 - 224 KF22A Sampled: 7/11/22 15:42 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/19/22 14:08
2195009-16	Sample Name: 1900 0021 - 225 KF22A Sampled: 7/11/22 15:43 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/19/22 14:08
2195009-17	Sample Name: 1900 0021 - 226 KF22A Sampled: 7/11/22 15:44 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/19/22 14:08
2195009-18	Sample Name: 1900 0021 - 227 DW22A Sampled: 7/11/22 15:45 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/19/22 14:08

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/22/2022
Received: 07/12/2022
Sampled By: C Spear
Work Order: 2195009

C Environmental Inspection Services
L
I Attn: Charles Spear
E 11981 Fargo Rd
N Aurora OR, 97002
T Phone: (503) 680-6398

Project: Philo m/s
Project # : 2022044
Sample Type : Grab
PO # : 2022044

Sampling Location: Philomath m/s (middle school)

Lab Number

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director