



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/20/2022
Received: 07/12/2022
Sampled By: C Spear
Work Order: 2194002

C
L
I
E
N
T
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Distr
Project # : Philomath LIW
Sample Type : Grab
PO # : 2022044

Sampling Location: District Office

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2194002-01	Sample Name: 19900000 001 SF 022A		Matrix: Drinking Water				
	Sampled: 7/10/22 8:10		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	12	ppb	1	15 ppb	07/18/22 15:57
2194002-02	Sample Name: 19900000 002 BF 022A		Matrix: Drinking Water				
	Sampled: 7/10/22 8:10		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	10	ppb	1	15 ppb	07/18/22 15:57
2194002-03	Sample Name: 19900000 003 BF 022A		Matrix: Drinking Water				
	Sampled: 7/10/22 8:11		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	88	ppb	10	15 ppb	07/18/22 15:57 MCLE
2194002-04	Sample Name: 19900000 004 BF 022A		Matrix: Drinking Water				
	Sampled: 7/10/22 8:11		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	8	ppb	1	15 ppb	07/18/22 15:57
2194002-05	Sample Name: 19900000 005 BF 022A		Matrix: Drinking Water				
	Sampled: 7/10/22 8:12		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	3	ppb	1	15 ppb	07/18/22 15:57
2194002-06	Sample Name: 19900000 006 CF 022A		Matrix: Drinking Water				
	Sampled: 7/10/22 8:12		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	14	ppb	1	15 ppb	07/18/22 15:57
2194002-07	Sample Name: 19900000 007 CF 022A		Matrix: Drinking Water				
	Sampled: 7/10/22 8:13		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	20	ppb	1	15 ppb	07/18/22 15:57 MCLE
2194002-08	Sample Name: 19900000 007 CF 022A		Matrix: Drinking Water				
	Sampled: 7/10/22 8:13		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	9	ppb	1	15 ppb	07/18/22 15:57

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/20/2022
Received: 07/12/2022
Sampled By: C Spear
Work Order: 2194002

C
L
I
E
N
T
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Distr
Project # : Philomath LIW
Sample Type : Grab
PO # : 2022044

Sampling Location: District Office

Lab Number

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director