



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 07/20/2022  
Received: 07/12/2022  
Sampled By: C.  
Work Order: 2194009

**C** Environmental Inspection Services  
**L** Attn: Charles Spear  
**I** 11981 Fargo Rd  
**E** Aurora OR, 97002  
**N** Phone: (503) 680-6398  
**T**

**Project:** Blodgett  
Project # : 2022044  
Sample Type : Grab  
PO # : 2022044

Sampling Location: Blodgett

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2194009-01</b>	<b>Sample Name:</b> 1900 0018 - 071 CF 22A <b>Sampled:</b> 7/11/22 10:30 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/18/22 15:57
<b>2194009-02</b>	<b>Sample Name:</b> 1900 0018 - 072 CF 22A <b>Sampled:</b> 7/11/22 10:33 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/18/22 15:57
<b>2194009-03</b>	<b>Sample Name:</b> 1900 0018 - 073 DW 22A <b>Sampled:</b> 7/11/22 10:35 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/18/22 15:57
<b>2194009-04</b>	<b>Sample Name:</b> 1900 0018 - 074 DW22A <b>Sampled:</b> 7/11/22 10:36 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/18/22 15:57
<b>2194009-05</b>	<b>Sample Name:</b> 1900 0018 - 075 BF 22A <b>Sampled:</b> 7/11/22 10:37 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	07/18/22 15:57
<b>2194009-06</b>	<b>Sample Name:</b> 1900 0018 - 076 BF 22A <b>Sampled:</b> 7/11/22 10:38 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/18/22 15:57
<b>2194009-07</b>	<b>Sample Name:</b> 1900 0018 - 077 BF 22A <b>Sampled:</b> 7/11/22 10:39 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/18/22 15:57
<b>2194009-08</b>	<b>Sample Name:</b> 1900 0018 - 078 KF 22A <b>Sampled:</b> 7/11/22 10:40 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	23	ppb	2	15 ppb	07/18/22 15:57 <b>MCLE</b>
<b>2194009-09</b>	<b>Sample Name:</b> 1900 0018 - 079 KF 22A <b>Sampled:</b> 7/11/22 10:40 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	07/18/22 15:57
<b>2194009-10</b>	<b>Sample Name:</b> 1900 0018 - 080 KF22A <b>Sampled:</b> 7/11/22 10:40 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	5	ppb	1	15 ppb	07/18/22 15:57



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/20/2022
Received: 07/12/2022
Sampled By: C.
Work Order: 2194009

CLIENT Environmental Inspection Services

Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Blodgett
Project #: 2022044
Sample Type: Grab
PO #: 2022044

Sampling Location: Blodgett

Lab Number

Table with 8 columns: Lab Number, Code, Method, Result, Units, MRL, EPA MCL\*, Analysis Date/ Time. Contains two rows of data for samples 2194009-11 and 2194009-12, including sample names, composition, and results.

MCLC This analyte exceeds the MCL limit.

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: [Signature]
Adriana Gonzalez-Gray
Laboratory Director