



Guzek Associates, Inc.

**Mechanical, Electrical, Structural,
Environmental, and Architectural Engineering**

**Phone: (570) 586-9700
Fax: (570) 586-6728
Email: guzekassoc@aol.com**

**401 DAVIS STREET
CLARKS SUMMIT, PA 18411-1837**

February 7, 2020

Scranton School District
425 North Washington Avenue
Scranton, PA 18503

Attention: Mr. Paul Dougherty

Reference: Limited Bulk Asbestos Inspection – Bancroft Elementary School
1st Floor – Room 105, Floor tile and mastic

Dear Mr. Dougherty:

On February 4, 2020, Guzek Associates was on-site at your request to inspect and sample floor tile of the above-referenced areas for the presence of asbestos-containing material. No other areas of the building were inspected during this inspection.

Samples were collected by Christopher Notari, a Pennsylvania Certified Asbestos Inspector (License #027028). All samples were sent to EMSL Analytical, Inc. in Cinnaminson, NJ, an accredited asbestos laboratory, for next day analysis. Per EPA, any sample that is equal to or greater than 1% asbestos is considered an asbestos-containing material (ACM) and must be handled and removed by a Certified Licensed Contractor and workers.


All bulk floor tile and mastic samples from the following room were reported by the laboratory to be "None Detected":

- Rooms 105 (Floor tile and mastic)

This supplemental report now provides the District with additional and new information on this specific room.

Should you have any questions on this report, please feel free to call me.

Very truly yours,



Joseph Guzek P.E.

Attachment: EMSL Laboratory Report (2 Page)



Asbestos Chain of Custody

EMSL Order Number (Lab Use Only):

042003023

Cinnaminson, NJ 08077
PHONE: 1-800-220-3675
FAX: (856) 786-5974

Company Name : Guzek Associates, Inc		EMSL Customer ID:	
Street: 401 Davis Street		City: Clarks Summit	State/Province: PA 47
Zip/Postal Code: 18411	Country: US	Telephone #: 5705869700	Fax #: 570-586-6728
Report To (Name): Joseph Guzek		Please Provide Results: ☐ Fax ☒ Email	
Email Address: guzekassoc@aol.com		Purchase Order:	
Project Name/Number: <i>Democraft</i>		EMSL Project ID (Internal Use Only):	
U.S. State Samples Taken: PA		CT Samples: ☐ Commercial/Taxable ☐ Residential/Tax Exempt	
EMSL-Bill to: ☐ Same ☐ Different - If Bill to is Different note Instructions in Comments** Third Party Billing requires written authorization from third party			
Turnaround Time (TAT) Options* - Please Check			
☐ 3 Hour ☒ 6 Hour ☐ 24 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☐ 2 Week			
*For TEM Air 3 hr through 6 hr, please call ahead to schedule. *There is a premium charge for 3 Hour TEM AHERA or EPA Level II TAT. You will be asked to sign an authorization form for this service. Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide.			
PCM - Air ☐ Check if samples are from NY ☐ NIOSH 7400 ☐ w/ OSHA 8hr. TWA PLM - Bulk (reporting limit) ☒ PLM EPA 600/R-93/116 (<1%) ☐ PLM EPA NOB (<1%) Point Count ☐ 400 (<0.25%) ☐ 1000 (<0.1%) Point Count w/Gravimetric ☐ 400 (<0.25%) ☐ 1000 (<0.1%) ☐ NYS 198.1 (friable in NY) ☐ NYS 198.6 NOB (non-friable-NY) ☐ NYS 198.8 SOF-V ☐ NIOSH 9002 (<1%)		TEM - Air ☐ 4-4.5hr TAT (AHERA only) ☐ AHERA 40 CFR, Part ☐ 763 NIOSH 7402 ☐ EPA Level II ☐ ISO 10312 TEM - Bulk ☐ TEM EPA NOB ☐ NYS NOB 198.4 (non-friable-NY) ☐ Chatfield SOP ☐ TEM Mass Analysis-EPA 600 sec. 2.5 TEM - Water: EPA 100.2 Fibers >10µm ☐ Waste ☐ Drinking All Fiber Sizes ☐ Waste ☐ Drinking	
TEM - Dust ☐ Microvac - ASTM D 5755 ☐ Wipe - ASTM D6480 ☐ Carpet Sonication (EPA 600/J-93/167)		Soil/Rock/Vermiculite ☐ PLM EPA 600/R-93/116 with milling prep (<1%) ☐ PLM EPA 600/R-93/116 with milling prep (<0.25%) ☐ TEM EPA 600/R-93/116 with milling prep (<0.1%) ☐ TEM Qualitative via Filtration Prep ☐ TEM Qualitative via Drop Mount Prep ☐ Cincinnati Method EPA 600/R-04/004 - PLM/TEM (BC only) Other: ☐	
☐ Check For Positive Stop - Clearly Identify Homogenous Group		Filter Pore Size (Air Samples): ☐ 0.8µm ☐ 0.45µm	
Samplers Name: <i>Chris Kotazi</i>		Samplers Signature: <i>C. Kotazi</i>	
Sample #	Sample Description	Volume/Area (Air) HA # (Bulk)	Date/Time Sampled
01T	Room 105 - Center of room	Bulk	2/4/20 3:00pm
02M	Room 105 - Center of room		
03T	Room 105 - Near radiator		
04M	Room 105 Near radiator		
Client Sample # (s): <i>01T - 04M</i>		Total # of Samples: <i>4</i>	
Relinquished (Client): <i>[Signature]</i>		Date: <i>2/4/20</i> Time: <i>5:40 pm</i>	
Received (Lab): <i>[Signature]</i>		Date: <i>2-5-20</i> Time: <i>9:46</i>	
Comments/Special Instructions:			



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077

Tel/Fax: (800) 220-3675 / (856) 786-5974

http://www.EMSL.com / cinnaslab@EMSL.com

EMSL Order: 042003023

Customer ID: CLAG50

Customer PO:

Project ID:

Attention: Joseph Guzek

Guzek Associates, Inc.

401 Davis Street

Clarks Summit, PA 18411

Phone: (570) 586-9700

Fax: (570) 586-6728

Received Date: 02/05/2020 9:45 AM

Analysis Date: 02/05/2020

Collected Date: 02/04/2020

Project: Banoroft

Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
01T 042003023-0001	Room 105 - Center of Room	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
02M 042003023-0002	Room 105 - Center of Room	Yellow Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
03T 042003023-0003	Room 105 - Near Radiator	Tan/White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
04M 042003023-0004	Room 105 - Near Radiator	Yellow Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected

Analyst(s)

Sarah Kleinbrahm (4)

Samantha Rundstrom, Laboratory Manager
or Other Approved Signatory

EMSL maintains liability limited to cost of analysis. The above analyses were performed in general compliance with Appendix E to Subpart E of 40 CFR (previously EPA 600/M4-82-020 "Interim Method"), but augmented with procedures outlined in the 1993 ("final") version of the method. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. All samples received in acceptable condition unless otherwise noted. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. EMSL recommends gravimetric reduction for all non-friable organically bound materials prior to analysis. Estimation of uncertainty is available on request.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NVLAP Lab Code 101048-0, AIHA-LAP, LLC-IHLAP Lab 100194, NYS ELAP 10872, NJ DEP 03036, PA ID# 68-00367, LA #04127

Initial report from: 02/05/2020 11:13:46