EMSL Analytical, Inc.

5221 Militia Hill Road Plymouth Meeting, PA 19462

Tel/Fax: (610) 828-3102 / (610) 828-3122

http://www.EMSL.com / plymouthmeetinglab@emsl.com

EMSL Order: 182000345
Customer ID: ALIC62
Customer PO:
Project ID:

Attention: Christa Knorr
Alicon Environmental, Inc.
101 Stoney Creek Road
Clarks Summit, PA 18411

Phone: (570) 563-2719
Fax: (570) 563-1505
Received Date: 02/03/2020 09:00 AM
Analysis Date: 02/03/2020
Collected Date: 02/01/2020

Project: SSD - Neil Armstrong Elementary

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm²)	Non Asb	Asbestos Type(s)	#Structures ≥0.5µ < 5µ	#Structures ≥5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
NAES-01	Room 07	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
182000345-0001										
NAES-02	Hallway Outside Planetarium	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
182000345-0002										
NAES-03	Room 119	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
182000345-0003										
NAES-04	Gymnasium	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
182000345-0004										
NAES-05	Ground Floor S.B.B.H. Room	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
182000345-0005										

Analyst(s)

Kevin Ream (5)

Michael Thoma, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm3 and structures/mm2 are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory 's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA NVLAP Lab Code 200699-0, Philadelphia ALL-292, VA 3333000315, AIHA-LAP, LLC IHLAP #178659

Initial report from: 02/03/2020 15:13 PM