



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-5974
<http://www.EMSL.com> / cinnaslab@EMSL.com

EMSL Order: 042002743

Customer ID: ALIC62

Customer PO:

Project ID:

Attention: Christa Knorr
Alicon Environmental, Inc.
101 Stoney Creek Road
Clarks Summit, PA 18411

Phone: (570) 563-2719

Fax: (570) 563-1505

Received Date: 02/01/2020 08:20 AM

Analysis Date: 02/01/2020

Collected Date: 01/31/2020

Project: SSD - Charles Sumner Elementary

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm ²)	Non Asb	Asbestos Type(s)	#Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥0.5μ < 5μ	≥5μ		(S/mm ²)	(S/cc)
CSES-01 042002743-0001	Stairwell No. 2	1200.00	0.0660	0	None Detected	0	0	0.0049	<15.00	<0.0049
CSES-02 042002743-0002	Multipurpose Room	1200.00	0.0660	0	None Detected	0	0	0.0049	<15.00	<0.0049
CSES-03 042002743-0003	Kindergarten Room No. 2	1200.00	0.0660	0	None Detected	0	0	0.0049	<15.00	<0.0049

Analyst(s)

Wayne Froehlich (3)

Samantha Rundstrom, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. EMSL is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. Samples received in good condition unless otherwise noted. The test results meet the requirements of NELAC unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NVLAP Lab Code 101048-0, AIHA-LAP, LLC-IHLAP Lab 100194, NYS ELAP 10872, NJ DEP 03036, PA ID# 68-00367, LA #04127

Initial report from: 02/01/2020 13:27 PM