



EMSL Analytical, Inc.

5221 Militia Hill Road Plymouth Meeting, PA 19462
Tel/Fax: (610) 828-3102 / (610) 828-3122
<http://www.EMSL.com> / plymouthmeetinglab@emsl.com

EMSL Order: 182000343

Customer ID: ALIC62

Customer PO:

Project ID:

Attention: Christa Knorr
Alicon Environmental, Inc.
101 Stoney Creek Road
Clarks Summit, PA 18411

Phone: (570) 563-2719

Fax: (570) 563-1505

Received Date: 02/03/2020 09:00 AM

Analysis Date: 02/03/2020

Collected Date: 02/01/2020

Project: SSD - Whittier Annex

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm ²)	Non Asb	Asbestos Type(s)	#Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥0.5μ < 5μ	≥5μ		(S/mm ²)	(S/cc)
WA-01 182000343-0001	Kitchen	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
WA-02 182000343-0002	Gymnasium	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
WA-03 182000343-0003	Room 211	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049
WA-04 182000343-0004	Room 305	1200.00	0.0650	0	None Detected	0	0	0.0049	<15.00	<0.0049

Analyst(s)

Kevin Ream (4)

Michael Thoma, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. Results reported in both structures/cm³ and structures/mm² are dependent on the volume of air sampled and measured by non-laboratory personnel are not the responsibility of EMSL and are not covered by the laboratory's NVLAP accreditation. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA NVLAP Lab Code 200699-0, Philadelphia ALL-292, VA 3333000315, AIHA-LAP, LLC IHLAP #178659

Initial report from: 02/03/2020 15:16 PM