

Evaluation of Lead in Drinking Water at Neil Armstrong Elementary

North Lincoln Avenue and Clearview Street
Scranton, PA 18508

Prepared for:

SCRANTON SCHOOL DISTRICT
425 N. Washington Ave.
Scranton, PA 18503

Prepared by:



GAI Job No.: SSD.19_673

Sample Date: January 26, 2019
Report Date: January 14, 2020

TABLE OF CONTENTS	Page No.
INTRODUCTION	2
BACKGROUND	2
SAMPLING PROCEDURES.....	3
SAMPLE RESULTS.....	4
RECOMMENDATIONS.....	5
APPENDIX A: SAMPLE CHAIN OF CUSTODY & ANALYTICAL RESULTS.....	6

INTRODUCTION

Under the 2018 Act 39 Pennsylvania School Code (Section 742) beginning in the 2018-2019 school year and every year thereafter, School Districts in Pennsylvania shall either analyze their drinking water for lead or conduct public meetings to discuss why testing was not conducted.

BACKGROUND

Lead is a naturally occurring heavy metal that is toxic when ingested or absorbed into the body. Children in particular are more susceptible to lead poisoning because they absorb more lead into their systems as they grow.

According to the United States Environmental Protection Agency (EPA), “even low levels of lead in the blood of children can result in:

- Behavior and learning problems
- Lower IQ and Hyperactivity
- Slowed growth
- Hearing problems
- Anemia

In rare cases, ingestion of lead can cause seizures, coma and even death” (Available at www.epa.gov/lead/learn-about-lead, April 4, 2016). Although, there are several ways that lead poisoning can occur in children. This report evaluates potential lead exposure only from drinking water within the **Neil Armstrong Elementary School**.

There are basically two (2) ways in which lead can enter drinking water. The first and least common route would be lead that is present in the source water. This route is extremely rare and would only be addressed if high levels of lead were discovered in the secondary flushed samples.

The second route for lead to enter drinking water (and most common), would be lead that has been leached out of the plumbing material as water passes through it. Although lead is no longer used in pipes or solder, it can still be found in older fittings, fixtures, and plumbing components. The ability of water to leach chemicals from piping and plumbing materials is known as corrosivity. Therefore, the more corrosive the water is, the more potential there is for lead to be leached out of the plumbing material. Additionally, as the length of time the water is in contact with the plumbing material increases, so does the potential for the leaching of lead.

SAMPLING PROCEDURES

Both the Environmental Protection Agency [EPA] and the Pennsylvania Department of Environmental Protection Agency [PADEP] have programs to evaluate and reduce the concentration of lead in drinking water. The Federal (EPA) Program, the **3Ts for Reducing Lead in Drinking Water**, was developed for schools and daycare centers. The State (PADEP) Program is directed toward public drinking water suppliers (*Lead Copper Rule, 1991*). The programs differ slightly in sample quantity. However, because EPA's program is geared specifically toward schools, EPA's 3Ts sampling protocols were utilized.

A lead sampling plan was developed by Guzek Associates, Inc. [GAI] with the assistance of school maintenance staff in accordance with **EPA's 3Ts for Reducing Lead in Drinking Water Toolkit** (available at: www.epa.gov/ground-water-and-drinking-water/3ts-reducing-lead-drinking-water-toolkit). Representative samples of water fountains and/or faucets with the likelihood of ingestion by children were located and sampled. For example, if a classroom has two identical water fountains, only one was sampled; or, if a faucet was located in a maintenance room where children had no access, it would not be sampled.

One sample was taken at each designated location at the Neil Armstrong Elementary School, according to EPA's 3T's Toolkit sampling protocols. The sample was taken under worst case scenario condition. All samples were taken as First Draw after the water sat (unused) in the pipes for a minimum of eight (8) hours.

Clean/new sample bottles containing a preservative were supplied by a local laboratory. Samples were transported to the laboratory on ice within the specified holding times.

SAMPLE RESULTS

The sample results were compared to both EPA's Remediation Trigger Level [RTL] of 0.020 mg/l and PADEP's Lead Action Level of 0.015 mg/l.

The following table summarizes the First Draw lead results sampled on December 26, 2019 from the Neil Armstrong Elementary School:

Sample ID:	Sample Location Description:	Lead Concentration (mg/l)	Lead RTL* (mg/l)	Lead Action Level** (mg/l)	Exceeds Action Level
ARM-01	Health Room – Sink	0.017	0.020	0.015	YES
ARM-02	Front Wing – Water Fountain (Outside Room 107)	<0.001	0.020	0.015	No
ARM-03	Room 107 – Water Fountain	0.002	0.020	0.015	No
ARM-04	Room 104 – Water Fountain	0.009	0.020	0.015	No
ARM-05	Room 112 – Water Fountain	0.002	0.020	0.015	No
ARM-06	Teachers Lounge – Sink	0.003	0.020	0.015	No
ARM-07	Library Office – Sink	0.008	0.020	0.015	No
ARM-08	Room 116 – Water Fountain	0.003	0.020	0.015	No
ARM-09	Room 124 – Sink	0.215	0.020	0.015	YES
ARM-10	Room 127 – Sink	0.101	0.020	0.015	YES
ARM-11	Cafeteria – Hand Washing Sink	0.002	0.020	0.015	No
ARM-12	Cafeteria – Dish Sink	0.002	0.020	0.015	No
ARM-13	Room 104 – Sink	0.006	0.020	0.015	No
ARM-14	Room 106 – Sink	0.005	0.020	0.015	No
ARM-15	Art Room – Sink	0.002	0.020	0.015	No
ARM-16	Rear Hallway – Water Fountain (Short)	0.005	0.020	0.015	No
ARM-17	Maintenance Room, Restroom – Sink	0.004	0.020	0.015	No
ARM-18	Basement, Coat Room – Left Sink	0.205	0.020	0.015	YES
ARM-19	Basement, Coat Room – Middle Sink	0.20	0.020	0.015	YES

* RTL is defined as the level at which remediation action should be taken to reduce potential exposure to lead in public school drinking water.

** Action Level is defined as the level at which action should be taken to reduce the concentration of lead in drinking water.

Samples ARM-01, ARM-09, ARM-10, ARM-18, and ARM-19 were reported by the laboratory as above the Action Level. If any sample result exceeded PADEP's Action Level (which is the most stringent), the School was contacted and it was recommended that the fountain/faucet be immediately taken out of service or signage be posted stating, "NOT FOR DRINKING/COOKING".

No other samples exceeded either EPA's Remediation Trigger Level [RTL] of 0.020 mg/l and PADEP's Lead Action Level of 0.015 mg/l.

The Laboratory Analytical Reports (with Chain-of-Custody Forms) are found in Appendix A of this report.

RECOMMENDATIONS

As previously stated, if a sample concentration of 0.015 mg/l of lead was exceeded, GAI contacted the School District and it was recommended that the drinking fountain or faucet of concern be immediately taken out of service or signage be posted stating, "NOT FOR DRINKING/COOKING". If no sample results exceeded the PADEP's Action Level or EPA's RTL, no remediation action was recommended.

As permanent control measure, GAI recommends the following:

- 1). Any fountain or faucet used for drinking with elevated lead content should be permanently removed and replaced with a bottled water cooler.
- 2). It is strongly recommended that any faucet with elevated lead be immediately taken out of service or be posted "NOT FOR DRINKING/COOKING". Because there is a possibility that Lead may be present in faucets that have not been tested, it is therefore recommended that untested faucets be posted as well. Postings should be inspected monthly and replaced as needed.
- 3). As a safeguard, a schedule of flushing drinking water fountains and cooking faucets should be established by the School at the beginning of each school year and after long holidays (e.g. Christmas/New Year, Thanksgiving).
- 4). Results of lead sampling and remediation actions should be posted on the School District's Website and in the Administrative Offices of the School. Also, according to the PA Public School Code No. 2018-39, an elevated lead level "shall be reported to the Department of Education and posted on the Department's publicly accessible Internet Website".

APPENDIX A: SAMPLE CHAIN OF CUSTODY & ANALYTICAL RESULTS



201 West Clay Avenue / Hazle Township, PA 18202

PHONE (570) 455-6011 - FAX (570) 455-6321

www.hawkmtnlabs.com

Report Narrative

Customer: Guzek Associates, Inc.
401 Davis Street
Clarks Summit, PA 18411

Report Date: 1/13/2020

Page 1 of 6

HawkMtn WO #: 1912-00987
Subject Line: Armstrong School Drinking Water Lead Analysis

Any information provided by client (CLT) has not been performed by HML and is not within the HML scope of accreditation.

All solid samples are reported on an "as received" basis unless otherwise noted.

The test results meet the requirements of 25 PA Code and Chapter 252, except where noted.

The information contained in this analytical report is the sole property of Hawk MTN Laboratories, Inc.

and that of the client. It cannot be reproduced in any form without the consent of Hawk MTN Labs, Inc. or the client for which this report was issued. The results contained in this report(s) are only representative of the sample(s) received. Conditions are dependant on location and time of the sampling event.

Hawk MTN Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

PA DEP 40-417 EPA PA00169



201 West Clay Avenue / Hazle Township, PA 18202

PHONE (570) 455-6011 - FAX (570) 455-6321

www.hawkmtnlabs.com

Certificate of Analysis

Customer: Guzek Associates, Inc.
401 Davis Street
Clarks Summit, PA 18411

Report Date: 1/13/2020

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:08
Date Received: 12/30/2019
Client Sample ID: ARM-01, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-001
Sampler: Client
Sample Point ID: ARM-01

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
* Lead, DW ICP-MS	0.0165 mg/L	1	0.001	EPA 200.8		KLM	1/7/20 22:31	

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:09
Date Received: 12/30/2019
Client Sample ID: ARM-02, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-002
Sampler: Client
Sample Point ID: ARM-02

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
Lead, DW ICP-MS	<0.001 mg/L	1	0.001	EPA 200.8		KLM	1/7/20 22:31	

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:10
Date Received: 12/30/2019
Client Sample ID: ARM-03, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-003
Sampler: Client
Sample Point ID: ARM-03

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
Lead, DW ICP-MS	0.00228 mg/L	1	0.001	EPA 200.8		KLM	1/7/20 22:31	

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:12
Date Received: 12/30/2019
Client Sample ID: ARM-04, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-004
Sampler: Client
Sample Point ID: ARM-04

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
Lead, DW ICP-MS	0.00865 mg/L	1	0.001	EPA 200.8		KLM	1/7/20 22:31	

PA DEP 40-417
EPA PA00169



201 West Clay Avenue / Hazle Township, PA 18202

PHONE (570) 455-6011 - FAX (570) 455-6321

www.hawkmtnlabs.com

Certificate of Analysis

Customer: Guzek Associates, Inc.
401 Davis Street
Clarks Summit, PA 18411

Report Date: 1/13/2020

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:18
Date Received: 12/30/2019
Client Sample ID: ARM-05, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-005
Sampler: Client
Sample Point ID: ARM-05

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
Lead, DW ICP-MS	0.00208 mg/L	1	0.001	EPA 200.8		KLM	1/7/20 22:31	

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:19
Date Received: 12/30/2019
Client Sample ID: ARM-06, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-006
Sampler: Client
Sample Point ID: ARM-06

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
Lead, DW ICP-MS	0.00272 mg/L	1	0.001	EPA 200.8		KLM	1/7/20 22:31	

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:20
Date Received: 12/30/2019
Client Sample ID: ARM-07, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-007
Sampler: Client
Sample Point ID: ARM-07

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
Lead, DW ICP-MS	0.00779 mg/L	1	0.001	EPA 200.8		KLM	1/7/20 22:31	

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:22
Date Received: 12/30/2019
Client Sample ID: ARM-08, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-008
Sampler: Client
Sample Point ID: ARM-08

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
Lead, DW ICP-MS	0.00278 mg/L	1	0.001	EPA 200.8		KLM	1/7/20 22:31	

PA DEP 40-417
EPA PA00169



201 West Clay Avenue / Hazle Township, PA 18202

PHONE (570) 455-6011 - FAX (570) 455-6321

www.hawkmtnlabs.com

Certificate of Analysis

Customer: Guzek Associates, Inc.
401 Davis Street
Clarks Summit, PA 18411

Report Date: 1/13/2020

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:29
Date Received: 12/30/2019
Client Sample ID: ARM-09, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-009
Sampler: Client
Sample Point ID: ARM-09

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
* Lead, DW ICP-MS	0.215 mg/L	5	0.001	EPA 200.8		KLM	1/7/20 22:31	

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:30
Date Received: 12/30/2019
Client Sample ID: ARM-10, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-010
Sampler: Client
Sample Point ID: ARM-10

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
* Lead, DW ICP-MS	0.101 mg/L	5	0.001	EPA 200.8		KLM	1/7/20 22:31	

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:34
Date Received: 12/30/2019
Client Sample ID: ARM-11, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-011
Sampler: Client
Sample Point ID: ARM-11

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
Lead, DW ICP-MS	0.00222 mg/L	1	0.001	EPA 200.8		KLM	1/7/20 22:31	

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:34
Date Received: 12/30/2019
Client Sample ID: ARM-12, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-012
Sampler: Client
Sample Point ID: ARM-12

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
Lead, DW ICP-MS	0.00176 mg/L	1	0.001	EPA 200.8		KLM	1/7/20 22:31	

PA DEP 40-417
EPA PA00169



201 West Clay Avenue / Hazle Township, PA 18202

PHONE (570) 455-6011 - FAX (570) 455-6321

www.hawkmtnlabs.com

Certificate of Analysis

Customer: Guzek Associates, Inc.
401 Davis Street
Clarks Summit, PA 18411

Report Date: 1/13/2020

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:12
Date Received: 12/30/2019
Client Sample ID: ARM-13, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-013
Sampler: Client
Sample Point ID: ARM-13

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
Lead, DW ICP-MS	0.00586 mg/L	1	0.001	EPA 200.8		KLM	1/7/20 22:31	

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:16
Date Received: 12/30/2019
Client Sample ID: ARM-14, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-014
Sampler: Client
Sample Point ID: ARM-14

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
Lead, DW ICP-MS	0.00463 mg/L	1	0.001	EPA 200.8		KLM	1/7/20 22:31	

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:24
Date Received: 12/30/2019
Client Sample ID: ARM-15, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-015
Sampler: Client
Sample Point ID: ARM-15

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
Lead, DW ICP-MS	0.00167 mg/L	1	0.001	EPA 200.8		KLM	1/7/20 22:31	

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:26
Date Received: 12/30/2019
Client Sample ID: ARM-16, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-016
Sampler: Client
Sample Point ID: ARM-16

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
Lead, DW ICP-MS	0.00457 mg/L	1	0.001	EPA 200.8		KLM	1/7/20 22:31	

PA DEP 40-417
EPA PA00169

Certificate of Analysis

Customer: Guzek Associates, Inc.
401 Davis Street
Clarks Summit, PA 18411

Report Date: 1/13/2020

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:32
Date Received: 12/30/2019
Client Sample ID: ARM-17, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-017
Sampler: Client
Sample Point ID: ARM-17

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
Lead, DW ICP-MS	0.00364 mg/L	1	0.001	EPA 200.8		KLM	1/7/20 22:31	

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:35
Date Received: 12/30/2019
Client Sample ID: ARM-18, Drinking Water Lead Analysis

HawkMtn WO #: 1912-00987-018
Sampler: Client
Sample Point ID: ARM-18

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
* Lead, DW ICP-MS	0.205 mg/L	5	0.001	EPA 200.8		KLM	1/7/20 22:31	

Material Tested: Potable Water
Date Sampled: 12/26/2019 Time Sampled: 7:35
Date Received: 12/30/2019
Client Sample ID: ARM-19, Drinking Water Lead Analysis


HawkMtn WO #: 1912-00987-019
Sampler: Client
Sample Point ID: ARM-19

<u>Test Name</u>	<u>Test Results</u>	<u>Dilution</u> <u>Factor</u>	<u>Quant</u> <u>Limit</u>	<u>Method</u>	<u>Qual</u>	<u>Tech</u>	<u>Start</u> <u>Date/Time</u>	<u>End</u> <u>Date/Time</u>
* Lead, DW ICP-MS	0.198 mg/L	5	0.001	EPA 200.8		KLM	1/7/20 22:31	

ND = Non Detect

These results relate only to the sample noted above.

This certificate is not to be reproduced except in full,
without the written approval of HawkMtn Labs



Jeff Gittleman, Lab Director

Composite
Start Date: Time: _____
End Date: Time: _____
Grab
Date: Time: _____
Date: Time: _____
Date: Time: _____
Date: Time: _____

Smp#	Bottle	Preservative	Rcvd	Smp#	Bottle	Preservative	Rcvd
001	Copper/Lead 11-Graduated	HNO3	☒	010	Copper/Lead 11-Graduated	HNO3	☒
002	Copper/Lead 11-Graduated	HNO3	☒	011	Copper/Lead 11-Graduated	HNO3	☒
003	Copper/Lead 11-Graduated	HNO3	☒	012	Copper/Lead 11-Graduated	HNO3	☒
004	Copper/Lead 11-Graduated	HNO3	☒	013	Copper/Lead 11-Graduated	HNO3	☒
005	Copper/Lead 11-Graduated	HNO3	☒	014	Copper/Lead 11-Graduated	HNO3	☒
006	Copper/Lead 11-Graduated	HNO3	☒				
007	Copper/Lead 11-Graduated	HNO3	☒				
008	Copper/Lead 11-Graduated	HNO3	☒				
009	Copper/Lead 11-Graduated	HNO3	☒				

Five additional bottles received - 8 oz HNO3

Smp #	Smp Site	Matrix/ Smp Type	Temp Upon Receipt	Sample Date	Sample Time	Field pH	Field Cl	Field Temp
001	ARM-01, Drinking Water Lead Analysis	Potable Water	10.0 °C	12/26/19	7:08 AM			°C
002	ARM-02, Drinking Water Lead Analysis	Potable Water	10.4 °C		7:09			°C
003	ARM-03, Drinking Water Lead Analysis	Potable Water	10.6 °C		7:10			°C
004	ARM-04, Drinking Water Lead Analysis	Potable Water	10.7 °C		7:12			°C
005	ARM-05, Drinking Water Lead Analysis	Potable Water	10.5 °C		7:18			°C
006	ARM-06, Drinking Water Lead Analysis	Potable Water	10.7 °C		7:19			°C
007	ARM-07, Drinking Water Lead Analysis	Potable Water	12.4 °C		7:20			°C
008	ARM-08, Drinking Water Lead Analysis	Potable Water	10.9 °C		7:22			°C
009	ARM-09, Drinking Water Lead Analysis	Potable Water	10.9 °C		7:29			°C
010	ARM-10, Drinking Water Lead Analysis	Potable Water	11.2 °C		7:30			°C

Receipt Info: Received on ice? ☒ Volatiles: Headspace present? ☒ Samples intact? ☒ Correct containers? ☒ Completed by: SLX Date: 12/30/19 Time: 1:17

Sampled By: Ch. H. Burt Tripp RELINQUISHED BY: Burt Tripp RECEIVED BY: Paul O'Hara RELINQUISHED BY: Paul O'Hara RECEIVED AT LAB: 12/30/19 LOGGED IN AT LAB: 12/30/19

Field Meter ID: N/A Notes: Client applied white out. Sg 12/30/19

QSP-008-F02B Rev 004 12/11/2019

Work Order #: 1912-00987 Purchase Order:
Site Name: Guzek Associates, Inc.
Contact: learl.gai@gmail.com

Chain of Custody & Analysis Record
HawkMtn Labs, Inc.
201 West Clay Ave, Hazle Township, PA 18202
Ph: (570) 455-6011 Fax (570) 455-6321

Pick Up Date: _____ Page 2 of 2

Printed By: AD
Bottles made by: CLT
Approved By: ADP
Checked By: AD

Composite	
Start Date: _____	Time: _____
End Date: _____	Time: _____
Grab	
Date: _____	Time: _____
Date: _____	Time: _____
Date: _____	Time: _____
Date: _____	Time: _____

Smp #	Smp Site	Matrix/ Smp Type	Tests		Temp Upon Receipt	Sample Date	Sample Time	Field pH	Field Cl	Field Temp
			Potable Water	DW-PB-MS						
011	ARM-11, Drinking Water Analysis	Potable Water		DW-PB-MS	10.9 °C	12/26/19	7:34 AM			°C
012	ARM-12, Drinking Water Analysis	Potable Water		DW-PB-MS	11.0 °C		7:34			°C
013	ARM-13, Drinking Water Analysis	Potable Water		DW-PB-MS	12.9 °C		7:12			°C
014	ARM-14, Drinking Water Analysis	Potable Water		DW-PB-MS	12.9 °C		7:16			°C
15					12.9		7:24			
16					13.4		7:26			
17					12.7		7:32			
18					12.5		7:35			
19					12.6		7:35			

Receipt Info: Recieved on ice? <u>Y</u> Samples intact? <u>Y</u>	COC intact and complete? <u>Y</u> Correct containers? <u>Y</u>	Adquate samples? <u>Y</u> Volatiles: Headspace present? <u>Y</u>	Completed by: <u>AD</u> Samples/COC/Analysis agree? <u>Y</u>	Time
---	---	---	---	------

Sampled By: CLT
Field Meter ID: N/A
Notes: _____

**All samples taken in 250mL
plastic HNO3 preserved bottles.**

RELINQUISHED BY: _____	Date: <u>12/30/19</u>	Time: <u>11:17</u>
RECEIVED BY: _____		
RELINQUISHED BY: _____	Date: <u>12/30/19</u>	Time: <u>11:17</u>
RECEIVED AT LAB: _____	Date: <u>12/30/19</u>	Time: <u>12:55</u>
LOGGED IN AT LAB: _____		

12/11/2019