


Report of Analysis

Name:	Parkway School Greenwich Public Schools - Cordes George 290 Greenwich Ave Greenwich, CT 06830-6521	Sample ID#:	301249
		Sample Type:	Drinking Water
		Sample Source:	Distribution
		Sampler:	PD
Sample Date:	11/17/2022 7:30 AM	PWS ID:	CT0570212
Receipt Date:	11/17/2022 9:48 AM		
Report Date:	11/28/2022		
Sample Site:	DISTRIBUTION SYSTEM		

Parameter	Sample Result	Units	MCL	Method	RL	Analysis Date/Time	Analyst
Metals							
Copper(01 - PS004)	0.05	mg/L	1.3	EPA 200.5	0.005	11/18/2022 11:01	BW
Lead(01 - PS004)	<1	ug/L	15	EPA 200.8	1	11/23/2022 13:35	TJB
Copper(02 - PS005)	0.13	mg/L	1.3	EPA 200.5	0.005	11/18/2022 11:01	BW
Lead(02 - PS005)	<1	ug/L	15	EPA 200.8	1	11/23/2022 13:40	TJB
Copper(03 - PS008)	0.09	mg/L	1.3	EPA 200.5	0.005	11/18/2022 11:03	BW
Lead(03 - PS008)	<1	ug/L	15	EPA 200.8	1	11/23/2022 13:45	TJB
Copper(04 - PS010)	0.14	mg/L	1.3	EPA 200.5	0.005	11/18/2022 11:03	BW
Lead(04 - PS010)	<1	ug/L	15	EPA 200.8	1	11/23/2022 13:50	TJB
Copper(05 - PS011)	0.17	mg/L	1.3	EPA 200.5	0.005	11/18/2022 11:03	BW
Lead(05 - PS011)	<1	ug/L	15	EPA 200.8	1	11/23/2022 13:55	TJB
Copper(06 - PS017)	0.06	mg/L	1.3	EPA 200.5	0.005	11/18/2022 11:03	BW
Lead(06 - PS017)	<1	ug/L	15	EPA 200.8	1	11/23/2022 14:12	TJB
Copper(07 - PS019)	0.09	mg/L	1.3	EPA 200.5	0.005	11/18/2022 11:18	BW
Lead(07 - PS019)	2.3	ug/L	15	EPA 200.8	1	11/23/2022 14:17	TJB
Copper(08 - PS023)	0.09	mg/L	1.3	EPA 200.5	0.005	11/18/2022 11:18	BW
Lead(08 - PS023)	1.3	ug/L	15	EPA 200.8	1	11/23/2022 14:22	TJB
Copper(09 - PS025)	0.07	mg/L	1.3	EPA 200.5	0.005	11/18/2022 11:18	BW
Lead(09 - PS025)	1.7	ug/L	15	EPA 200.8	1	11/23/2022 14:27	TJB
Copper(10 - PS029)	0.06	mg/L	1.3	EPA 200.5	0.005	11/18/2022 11:18	BW
Lead(10 - PS029)	<1	ug/L	15	EPA 200.8	1	11/23/2022 14:32	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
 * = Above Specified Limit

Report Approved by:  _____ CT Lic PH-0787 NY Lic 11706
 Lab Director

AquaEnvLab.com
 YorkLab.com
 203 270 9973

MCL (MCL – Maximum Contaminant Level)

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.