



## Drinking Water Results Report

Order ID: 2L02819

Suburban Water Technology  
1697A Swamp Pike  
Gilbertsville, PA 19525

Attn: Jeremy Crum

Project: PROASYS  
Philadelphia Charter School

PWSID:

Sample Number: 2L02819-01

Site: Maintenance Break Room

Sample ID:

Collector: MBR

Collect Date: 12/05/2022 9:45 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	12/12/22	LAD	12/13/22 13:48	LAD
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 2L02819-02

Site: Ground Floor Cafe Sink

Sample ID:

Collector: GF

Collect Date: 12/05/2022 9:48 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	12/12/22	LAD	12/13/22 13:45	LAD
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 2L02819-03

Site: 1st Floor Nurse's Sink

Sample ID:

Collector: IF

Collect Date: 12/05/2022 9:52 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	12/12/22	LAD	12/13/22 13:41	LAD
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 2L02819-04

Site: 2nd Floor Lounge Sink

Sample ID:

Collector: 2F

Collect Date: 12/05/2022 9:55 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	12/12/22	LAD	12/13/22 13:28	LAD
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 2L02819-05

Site: 3rd Floor Back Staff

Sample ID:

Collector: 3F

Collect Date: 12/05/2022 9:58 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	12/12/22	LAD	12/13/22 13:24	LAD
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Report Generated On: 12/19/2022 3:22 pm  
STL\_DW\_Results Revision #2.0

2L02819  
Effective: 09/01/2022





**Sample Receipt Conditions:**

· Sample(s) received with incomplete Chain of Custody form. At a minimum, Chain of Custody forms must contain a description of the sample location, matrix, the date and time of collection, the collector(s) initials or name, and the testing requested.

Units P/A = Present/Absent

Units P/F = Pass/Fail

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

MCL: Maximum Contaminant Level based on 40CFR part 141 and 143. MCL and Pass/Fail are provided for reference only.

RL: Reporting Limit. The lowest concentration reported for this sample. Results below the RL are considered Non-Detected.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Devin Kohler  
Project Manager I

Report Generated On: 12/19/2022 3:22 pm  
STL\_DW\_Results Revision #2.0

2L02819  
Effective: 09/01/2022





### Chain of Custody Record

1037F MacArthur Road, Reading, PA 19601  
610-375-TEST - Fax: 610-375-4090 - suburbantestinc.com



2L02819  
Devin Kohler

2hr  Other   
(Standard TAT will apply)

Client Name: ProAqys  
Address: 318 Hunder St, Shillington PA 19607 Phone: 610 419 9767  
Contact Name: Tyler Bonanno Email: tbonanno@proaqysinc.com  
P.O. Info: \_\_\_\_\_

Project Name: Milly Charles - 70000  
Address: 1197 Haworth St Philadelphia, PA 19124  
Regulatory ID (SDWA/Permit #): \_\_\_\_\_

Comments: (5) IL Graduated P.

*\* = Missing info / Incomplete COC  
ms 12/19/22*

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
X 1	Maintenance Break Room	12.5.22	0945	MBR	Lead	1					
X 2	Ground floor Cafe Sink		0948	GF		1					
X 3	1st Floor Nurse's Sink		0952	1F							
X 4	2nd Floor Lounge Sink		0955	2F							
X 5	3rd Floor Back Staff		0958	3F							

Suburban Testing Labs  
Lab Date/Time: 12-07-22 19:46 Lab Temp: 50  
Number of containers/cooler, match number on COC? Y/N  
Sample labels and COC are free of discrepancies: Y/N  
All containers intact? Y/N  
Received in lab within acceptable temperature limits? Y/N  
40 mL VOA vials free of headspace? Y/N  
Relinquished by: Ralph Kurma  
Received in lab by: CTB 12-7-22 1946  
Ice

Relinquished By: <u>[Signature]</u>	Count: <u>5</u>	Date: <u>12.7.22</u>	Temp °C: _____	Sample Conditions	Matrix Key	Sample Type Key	SDWA Sample Types	Preservative Key
Received By: <u>Joanne Pritchard</u>		Date: <u>12-7-22</u>	Temp °C: _____	Submitted with COC? <u>Y / N</u>	NPW = Non-Potable Water	G = Grab	D=Distribution	A = Ascorbic Acid
Relinquished By: <u>Joanne Pritchard</u>		Date: <u>12-7-22</u>	Temp °C: _____	Number of containers match number on COC? <u>Y / N</u>	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	C = Composite	E=Entry Point	OH = NaOH
Received in Lab By: <u>Ralph Kurma</u>		Date: <u>12-07-22</u>	Temp °C: <u>S.O.</u>	All containers intact? <u>Y / N</u>	PW = Potable Water (not for SDWA compliance)	BHC = 8 Hr. Composite	R=Raw	S = H <sub>2</sub> SO <sub>4</sub>
		Date: _____	Temp °C: _____	Tests within holding times? <u>Y / N</u>	SDWA = Safe Drinking Water Act Potable Sample	24HC = 24 Hr. Composite	C=Check	HDPE = High Density Polyethylene
		Date: _____	Temp °C: _____	40 mL VOA vials free of headspace? <u>Y / N</u>			S=Special	O = Other
		Date: _____	Temp °C: _____				M=Maximum Residence	NA = None Required

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.5 Effective April 24, 2020. Shaded areas are for STL use only.



**SUBURBAN TESTING LABS**

**Chain of Custody Record**

1037F MacArthur Road, Reading, PA 19605

610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com



TAT(Check One):  Standard  24hr  48hr  72hr  Other  
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: \_\_\_\_\_

*(Suburban Water Technology) mB121912*

Client Name: ProAsyst  
Address: 318 Handel St, Shillington PA 19607 Phone: 610 419 9767  
Contact Name: Tyle Bonouno Email: tbonouno@proasystinc.com  
P.O. Info: \_\_\_\_\_

Project Name: Philly Charter School  
Address: 1197 Haworth St Philadelphia, PA 19124  
Regulatory ID (SDWA/Permit #): \_\_\_\_\_

Comments:  
(S) IL graduated P.

*\* = missing info / incomplete IOL mms 12/19/22*

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:	
							Matrix	Sample Type	Bottle Type	Preservative		
X	<u>X = 43mL HNO3 added at 1330 12-9-22; Phase CTB (S2I1992)</u>											
X	<u>1 Maintenance Break Room</u>	<u>12.5.22</u>	<u>0945</u>	<u>MBR</u>	<u>Lead</u>	<u>1</u>						
X	<u>2 Ground floor Cafe Sink</u>		<u>0948</u>	<u>GF</u>		<u>1</u>						
X	<u>3 1st Floor Nurse's Sink</u>		<u>0952</u>	<u>1F</u>								
X	<u>4 2nd Floor Lounge Sink</u>		<u>0955</u>	<u>2F</u>								
X	<u>5 3rd Floor Back Staff</u>		<u>0958</u>	<u>3F</u>								

Suburban Testing Labs  
 Lab Date/Time: 12.07.22 19:46 Lab Temp: 50  
 Number of containers/cooler, match number on COC? Y/N  
 Sample labels and COC are free of discrepancies? Y/N  
 All containers intact? Y/N  
 Received in lab within acceptable temperature limits? Y/N  
 40 mL VOA vials free of headspace? Y/N  
 Relinquished by: Ralph Kurma  
 Received in lab by: CTB 12-7-22 1946  
Ice

Relinquished By: <u>[Signature]</u>	Count: _____	Date: <u>12.7.22</u>	Temp °C: _____	<b>Sample Conditions</b>	<b>Matrix Key</b>	<b>Type Key</b>
Received By: <u>Joanne Pritchard</u>	<u>5</u>	Date: <u>12-7-22</u>	Temp °C: _____	Submitted with COC? <u>Y / N</u>	NPW = Non-Potable Water	P = Plastic
Relinquished By: <u>Joanne Pritchard</u>	<u>5</u>	Date: <u>12-7-22</u>	Temp °C: _____	Number of containers match number on COC? <u>Y / N</u>	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	G = Glass
Received in Lab By: <u>Ralph Kurma</u>		Date: <u>12-07-22</u>	Temp °C: <u>5.0</u>	All containers intact? <u>Y / N</u>	PW = Potable Water (not for SDWA compliance)	GA = Glass Amber
		Date: <u>12-07-22</u>	Temp °C: _____	Tests within holding times? <u>Y / N</u>	SDWA = Safe Drinking Water Act Potable Sample	VOA = 40mL G or GA
		Date: <u>12-07-22</u>	Temp °C: _____	40 mL VOA vials free of headspace? <u>Y / N</u>		O = Other



2L02819  
Devin Kohler

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.5 Effective April 24, 2020. Shaded areas are for STL use only.



**SUBURBAN TESTING LABS**

**Chain of Custody Record**

1037F MacArthur Road, Reading, PA 19605

610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com



TAT (Check One):  Standard  24hr  48hr  72hr  Other  
 (Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: \_\_\_\_\_

*(Suburban Water Technology) mbs12/19/22*

Client Name: ProAsys  
 Address: 318 Hendel St, Shillington PA 19607 Phone: 610 419 9767  
 Contact Name: Tyle Bononno Email: tbononno@proasysinc.com  
 P.O. Info: \_\_\_\_\_

Project Name: Philly Charter School  
 Address: 1197 Haworth St Philadelphia, PA 19124  
 Regulatory ID (SDWA/Permit #): \_\_\_\_\_

Comments:

*(S) IL Graduated P.*

*\* = missing info / incomplete 10C mbs 12/19/22*

STL Sample Number	Sample Description / Site ID	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested	Bottle Quantity	See Codes Below				Comments / Field Data
							Matrix	Sample Type	Bottle Type	Preservative	
X 1	Maintenance Break Room X = 43mL HNO3 added at 1330 12-9-22; Phase CTB (S2#1992)	12-5-22	0945	MBR	Lead	1	PW	Grab			Confirmed by Client
X 2	Ground floor Cafe Sink	↓	0948	GF	↓	1	↓	↓			12/13/22
X 3	1st Floor Nurse's Sink	↓	0952	1F	↓						
X 4	2nd Floor Lounge Sink	↓	0955	2F	↓						
X 5	3rd Floor Back Staff	↓	0958	3F	↓						

Suburban Testing Labs  
 Lab Date/Time: 12-07-22 19:46 Lab Temp: 50

Number of containers/cooler, match number on COC?  Y /  N  
 Sample labels and COC are free of discrepancies?  Y /  N  
 All containers intact?  Y /  N  
 Received in lab within acceptable temperature limits?  Y /  N  
 40 mL VOA vials free of headspace?  Y /  N

Relinquished by: Ralph Kurma  
 Received in lab by: CTB 12-7-22 1946  
Ice

Relinquished By: <u>[Signature]</u>	Count: <u>5</u>	Date: <u>12-7-22</u>	Temp °C: _____	<b>Sample Conditions</b>	<b>Matrix Key</b>	<b>Sample Type Key</b>
Received By: <u>Jeanne Pritchard</u>		Date: <u>12-7-22</u>	Temp °C: _____	Submitted with COC? Y / N	NPW = Non-Potable Water	G = Grab
Relinquished By: <u>Jeanne Pritchard</u>		Date: <u>12-7-22</u>	Temp °C: _____	Number of containers match number on COC? Y / N	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	C = Composite
Received in Lab by: <u>Ralph Kurma</u>		Date: <u>12-07-22</u>	Temp °C: <u>5.0</u>	All containers intact? Y / N	PW = Potable Water (not for SDWA compliance)	8HC = 8 Hr. Composite
		Date: _____	Temp °C: _____	Tests within holding times? Y / N	SDWA = Safe Drinking Water Act Potable Sample	24HC = 24 Hr. Composite
		Date: _____	Temp °C: _____	40 mL VOA vials free of headspace? Y / N		



2L02819  
Devin Kohler

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SFL059 Rev. 1.5 Effective April 24, 2020. Shaded areas are for STL use only.