

Report of Analysis


Name:	Parkway School Greenwich Public Schools - Cordes George 290 Greenwich Ave Greenwich, CT 06830-6521	Sample ID#:	303837
		Sample Type:	Drinking Water
		Sample Source:	PS017
		Sampler:	PD
Sample Date:	1/4/2023 11:15 AM	PWS ID:	CT0570212
Receipt Date:	1/4/2023 11:45 AM	Client Sample ID:	Hot
Report Date:	1/10/2023		
Sample Site:	DISTRIBUTION SYSTEM		

Parameter	Sample Result	Units	MCL	Method	RL	Analysis Date/Time	Analyst
Metals							
Copper	0.23	mg/L	1.3	EPA 200.5	0.005	1/5/2023 17:57	BW
Iron	0.09	mg/L	0.3	EPA 200.5	0.005	1/5/2023 17:57	BW
Manganese	0.01	mg/L	0.05	EPA 200.5	0.005	1/5/2023 17:57	BW
Minerals							
Chloride	173	mg/L	250	EPA 300.0	10	1/9/2023 16:15	BW
Hardness	ND	mg/L	No Limit Set	EPA 200.5	5	1/5/2023 17:57	BW
Sodium	37.9	mg/L	100	EPA 200.5	5	1/5/2023 17:57	BW
Sulfate	23	mg/L	250	EPA 300.0	5	1/5/2023 15:50	BW
Nutrient							
Nitrate as N	1.3	mg/L	10	EPA 300.0	0.5	1/5/2023 15:50	BW
Nitrite as N	ND	mg/L	1	EPA 300.0	0.1	1/5/2023 15:50	BW
Physical							
Color, apparent	10	CU	15	SM 2120B-01	5	1/4/2023 15:30	LD
Odor	0	TON	3	SM2150B-2011	0	1/4/2023 15:30	LD
PH	7.59	pH	6.4 - 8.5	SM4500HB-2011	0	1/4/2023 11:45	PD
Turbidity	1.7	NTU	5	EPA 180.1	0.05	1/4/2023 15:30	LD

ND = Not Detected
 * = Above Specified Limit

Report Approved by: _____

Lab Director



CT Lic PH-0787

NY Lic 11706

AquaEnvLab.com
 YorkLab.com
 203 270 9973

MCL (MCL – Maximum Contaminant Level)

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.