



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

James Eberts
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

9/26/2022

Phone: (856) 205-1077
Fax: (856) 205-0413

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 8/26/2022. The results are tabulated on the attached data pages for the following client designated project:

Camden County ESC Office LIW

The reference number for these samples is EMSL Order #012212459. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

Report amended 09/26/2022 09:19:24 Replaces initial report from 09/13/2022 14:23:38 Report amended to change Project ID, per client's request.

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012212459

CustomerID: EPIC62

CustomerPO:

ProjectID:

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 8/26/2022 09:00 AM

Project: **Camden County ESC Office LIW****Analytical Results**

Client Sample Description CO-WC-01
Front hall water cooler
Collected: 8/26/2022
Lab ID: 012212459-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	1.20	1.00 ppb	9/9/2022 VD	9/9/2022 16:40 VD
-------	------	------	----------	-------------	-------------------

Client Sample Description CO-WC-02A
Back Wall Water Cooler - Right
Collected: 8/26/2022
Lab ID: 012212459-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	2.65	1.00 ppb	9/9/2022 VD	9/9/2022 16:47 VD
-------	------	------	----------	-------------	-------------------

Client Sample Description CO-WC-02B
Back Wall Water Cooler - Left
Collected: 8/26/2022
Lab ID: 012212459-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	2.77	1.00 ppb	9/9/2022 VD	9/9/2022 16:49 VD
-------	------	------	----------	-------------	-------------------

Client Sample Description CO-KIT-207
Rm 207 Sink
Collected: 8/26/2022
Lab ID: 012212459-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	1.47	1.00 ppb	9/9/2022 VD	9/9/2022 16:52 VD
-------	------	------	----------	-------------	-------------------

Client Sample Description CO-KIT-207F
Rm 207 Sink Flush
Collected: 8/26/2022
Lab ID: 012212459-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	1.00	1.00 ppb	9/9/2022 VD	9/9/2022 16:54 VD
-------	------	------	----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012212459

CustomerID: EPIC62

CustomerPO:

ProjectID:

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 8/26/2022 09:00 AM

Project: **Camden County ESC Office LIW****Analytical Results**

Client Sample Description CO-KIT-206
Rm 206 Sink **Collected:** 8/26/2022 **Lab ID:** 012212459-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.44	1.00 ppb	9/9/2022 VD	9/9/2022 17:01 VD

Client Sample Description CO-KIT-206F
Rm 206 Sink Flush **Collected:** 8/26/2022 **Lab ID:** 012212459-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.12	1.00 ppb	9/9/2022 VD	9/9/2022 17:03 VD

Client Sample Description FB-01
Field Blank **Collected:** 8/26/2022 **Lab ID:** 012212459-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	9/9/2022 VD	9/9/2022 17:05 VD

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results