

## **RADON RE- EVALUATION REPORT**

**CLIENT** Darien Public School  
Attn. Kevin Munrett  
30 Leroy Avenue  
Darien, CT 06820

**PROJECT #:** DRNPS22002

**SAMPLING DATES:** DECEMBER 5-8, 2022  
DECEMBER 19-22, 2022  
JANUARY 3-6, 2023

---

Attached are the laboratory results for the radon evaluation recently conducted at the below listed schools – **Darien Public Schools, CT.**

- Darien High School
- Middlesex Middle School
- Elementary Schools – Hindley, Tokeneke, Royle, Holmes

Testing was conducted in the occupied areas of each school. As reported in attached laboratory results, samples from the schools returned results below the Environmental Protection Agency action level of 4 pCi/l.

The radon samples were deployed and collected by a team from Hygenix, Inc, that was under my supervision. I am certified by the National Radon Safety Board (Certification Number 6SS0041), and listed on the Connecticut Department of Public Health list of “Radon Measurement Professional”. This testing program meets the requirements of Connecticut General Statute Section 10-220(d) for radon testing at public schools.

This letter should be kept in the facilities office and each school’s main office so it is available to parents, staff, and other interested parties. If you have any questions or require additional information, please call me at (203) 324-2222.

Regards,



Ted Tio, MS, CIEC  
Hygenix, Inc

LABORATORY ANALYSIS REPORT