

## **RADON INITIAL EVALUATION REPORT**

CLIENT Darien Public School  
Attn. Kevin Munrett  
30 Leroy Avenue  
Darien, CT 06820

PROJECT #: DRNPS22002

SAMPLING DATES: DECEMBER 5-8, 2022

---


Attached are the laboratory results for the radon evaluation recently conducted at **Ox Ridge Elementary school – Darien Public Schools, CT.**

Testing was conducted in the occupied areas of the school from December 5-8, 2022. As reported in attached laboratory results, samples from the school returned results below the Environmental Protection Agency action level of 4 pCi/l.

The radon samples were deployed and collected by a team from Hygenix, Inc, that was under my supervision. I am certified by the National Radon Safety Board (Certification Number 6SS0041), and listed on the Connecticut Department of Public Health list of “Radon Measurement Professional”. This testing program meets the requirements of Connecticut General Statute Section 10-220(d) for radon testing at public schools.

This letter should be kept in the facilities office and school’s main office so it is available to parents, staff, and other interested parties. If you have any questions or require additional information, please call me at (203) 324-2222.

Regards,



Ted Tio, MS, CIEC  
Hygenix, Inc

LABORATORY ANALYSIS REPORT  
OX RIDGE E.S