

28 December 2022

Frank Stefanelli  
Director of Facilities, Operations and Maintenance  
White Plains City School District  
580 North Street  
White Plains, NY 10595

**Re: Asbestos AHERA Six Month Periodic Surveillance Report  
White Plains, New York  
Langan Project No.: 170755407**

Dear Mr. Stefanelli:

Langan Engineering, Environmental, Surveying, Landscape Architecture and Geology, D.P.C. (Langan), completed a six-month periodic surveillance report throughout the district of White Plains, New York.

On October 30, 1987, the U.S. Government issued a final rule under Section 203 of Title II of the Toxic Substances Control Act (TSCA) entitled Asbestos Containing Materials in Schools, 40 CFR 763 (as amended through December 31, 2002). The Environmental Protection Agency (EPA) was charged with enforcing this ruling, which was the result of federal legislation known as the Asbestos Hazard Emergency Response Act (AHERA). This action represented a substantial expansion of the 1982 version of 40 CFR 763, and placed following additional burdens on the Local Education Agency (LEA):

- All local education agencies (LEAs) identify ACBM in their school buildings. Once doing so, the LEAs must submit a Management Plan to the State Education Department by October 12, 1988.
- At least once every **six** months after the Management Plan is in effect; the LEA Designee shall conduct a periodic surveillance in each school building containing ACBM. The surveillance requires that a visual inspection of all areas that have been identified in the Management Plan as ACBM be conducted and any changes in the condition of the ACBM be noted. This information shall be recorded as well as the date and the name of the person performing the surveillance. This information should be submitted to Designated Person to be included in the Management Plan.

Langan was tasked with performing the district's AHERA Six Month Periodic Surveillance and updating the district's periodic surveillance paperwork as per our approved proposal dated November 28, 2022. The scope of work as outlined in 763.92(b) was performed for each school. The following tasks were completed:

## Task I Field Inspection

The first task is the actual inspection of the materials assumed or confirmed to contain asbestos in the original management plan for each building. The inspector entered each space, which was shown to contain asbestos during the original inspection. The inspector determined if the ACBM(s) is still present in the room or if it has been abated. If the ACBM(s) is still present, the inspector confirmed the quantity of material(s), checks to see if the material(s) is friable and observes the condition of the material(s) for damage. The inspector continued the process throughout each school building.

On December 12,13 and 14, an AHERA Six Month Periodic Surveillance of the WPCSD was performed by the following NYS/AHERA accredited inspector(s).

Name	NYSDOL #	Exp. Date
Parthiban Munirathinam	11-21477	06/30/23

All materials were assessed and 6-month surveillance forms were signed, please see attached info. Please note that the attached sheets should be inserted into the books at your earliest convenience.

## Task II Update Six Month Periodic Surveillance Forms

The AHERA Six Month Periodic Surveillance was updated using the AHERA Six Month Periodic Surveillance forms. Information gathered during Task I was recorded on the periodic surveillance forms. Any ACBM which was not identified in the original AHERA Re-inspection but was discovered during the AHERA Six Month Periodic Surveillance was added to the existing management plan. Additionally, any information which may be used in updating the next management plan was noted.

If you have any questions or require additional information, please feel free to contact me at [cnapolitano@langan.com](mailto:cnapolitano@langan.com)

Very Truly Yours,

**Langan Engineering, Environmental, Surveying,  
Landscape Architecture and Geology, D.P.C.**



Craig Napolitano, CHMM  
Associate



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2001

**Space Description:** Office

**School District:** White Plains Public Schools

**School Name:** Education House

**Re-inspected By:** Jordan Wong

**Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	175 SF	0	Under 12"x12" Floor Tiles
					New Carpet Flooring
					(Assume below)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Muralidharan	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2002 **Space Description:** Office 111  
**School District:** White Plains Public Schools  
**School Name:** Education House  
**Re-inspected By:** Jordan Wong **Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	330 SF	0	Under 12"x12" Floor Tiles
					New Carpet Flooring
					(Assume below)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Mupirathiran	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2003 **Space Description:** Corridor  
**School District:** White Plains Public Schools  
**School Name:** Education House  
**Re-inspected By:** Jordan Wong **Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	150 SF	0	9"x9" Yellow
					Person type flooring
					(Addme below)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Paxhi Mueisathem	Unknown	no
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2004

**Space Description:** Office 107

**School District:** White Plains Public Schools

**School Name:** Education House

**Re-inspected By:** Jordan Wong

**Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	170 SF	0	Under Carpet <i>No change</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-12-2022</i>	<i>Parthi Munisathir</i>	<i>Unknown</i>	<i>NO</i>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2005

**Space Description:** Office 101

**School District:** White Plains Public Schools

**School Name:** Education House

**Re-inspected By:** Jordan Wong

**Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	305 SF	0	Under Carpet <i>No charge</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-12-2022</i>	<i>Pastor Munsathum</i>	<i>Unknown</i>	<i>No</i>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required**     **January 2025**

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2006 **Space Description:** Office

**School District:** White Plains Public Schools

**School Name:** Education House

**Re-inspected By:** Jordan Wong **Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	170 SF	0	Under Carpet <i>No change</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-12-2022</i>	<i>Parthi Munizathian</i>	<i>Unknown</i>	<i>ND</i>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** **January 2025**

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2007

**Space Description:** Office 105

**School District:** White Plains Public Schools

**School Name:** Education House

**Re-inspected By:** Jordan Wong

**Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	165 SF	0	Under Carpet <i>No change</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-12-2022</i>	<i>Pastor Munsathian</i>	<i>Unknown</i>	<i>NO</i>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2008 **Space Description:** Office 103  
**School District:** White Plains Public Schools  
**School Name:** Education House  
**Re-inspected By:** Jordan Wong **Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	170 SF	0	Under Carpet <i>No change</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-12-2022</i>	<i>Pantelis Mousathakis</i>	<i>Unknown</i>	<i>No</i>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2009 **Space Description:** Secretaries Area  
**School District:** White Plains Public Schools  
**School Name:** Education House  
**Re-inspected By:** Jordan Wong **Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	815 SF	0	9"x9" Gray w/Multicolor Specs and 9"x9" Green w/White Specs
					New Perfo flooring (Assure below)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parth Munnathir	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2010 **Space Description:** Vestibule

**School District:** White Plains Public Schools

**School Name:** Education House

**Re-inspected By:** Jordan Wong **Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	75 SF	0	9"x9" Green w/White Specs
					New Pergo flooring
					(Assume below)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munsathara	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2017 **Space Description:** Elevator Lobby  
**School District:** White Plains Public Schools  
**School Name:** Education House  
**Re-inspected By:** Jordan Wong **Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	75 SF	0	9"x9" Green w/White Specs
					New Perfo Floor
					Assume below

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munirathinam	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2018 **Space Description:** Conference Room 100  
**School District:** White Plains Public Schools  
**School Name:** Education House  
**Re-inspected By:** Jordan Wong **Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	425 SF	0	9"x9" Gray w/Multicolor Specs

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parth Muneer	Fair Condition	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**ASBESTOS CONTAINING BUILDING MATERIALS**  
**6 MONTHS PERIODIC SURVEILLANCE FORM**  
**AHERA 3 YEAR RE-INSPECTION AND**

**Space ID:** 2019  
**School District:** White Plains Public Schools  
**School Name:** Education House  
**Re-inspected By:** Jordan Wong

**Space Description:** Corridor  
**Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	200 SF	0	9"x9" Yellow
					New Perfo flooring
					(Assume below)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parghi Munrothoran	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**ASBESTOS CONTAINING BUILDING MATERIALS**  
**6 MONTHS PERIODIC SURVEILLANCE FORM**  
**ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2020 **Space Description:** Closet  
**School District:** White Plains Public Schools  
**School Name:** Education House  
**Re-inspected By:** Jordan Wong **Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	15 SF	0	9"x9" Yellow Metal Locker/Safe opened (Assume below)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Muniswathan	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2021 **Space Description:** Office 102  
**School District:** White Plains Public Schools  
**School Name:** Education House  
**Re-inspected By:** Jordan Wong **Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	150 SF	0	Under Carpet <i>NO change</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-12-2022</i>	<i>Partho Munisathian</i>	<i>Unknown</i>	<i>NO</i>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** **January 2025**

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 3010  
**School District:** White Plains Public Schools  
**School Name:** Education House  
**Re-inspected By:** Jordan Wong

**Space Description:** Main Stair Landing  
**Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	140 SF	0	9"x9" Gray w/Multicolor Specs
					no charge

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parkhi Manishankar	Good Condition	no
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** --

**Space Description:** Attic Storage

**School District:** White Plains Public Schools

**School Name:** Education House

**Re-inspected By:** Jordan Wong

**Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
02	Ceiling Material	Y	498 SF	0	Unable to Locate Ceiling Material
					(no change)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Patricia Muniz-Rodriguez	Unknown	—
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.

Ridgeway Elementary School





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1001

**Space Description:** Music Room 133

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong

**Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	740 SF	0	Under 12"x12" Floor Tiles (no charge)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Muneeratharan	Unknown	ND
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1002 **Space Description:** Art Room 134  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	670 SF	0	Under 12"x12" Floor Tiles
					12" FT cracked - 15 tiles

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Pavani Munisathirum	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1003 **Space Description:** Classroom 137  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	750 SF	0	Under 12"x12" Floor Tiles
					12" Ft. Cracked - 10 tiles

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parth M. Muralidharan	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1004 **Space Description:** Classroom 138B  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	730 SF	0	Under 12"x12" Floor Tiles
					No change 12" FT Minor Cracks

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munezathilam	Unchanged	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1005 **Space Description:** Classroom 139  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	740 SF	0	Under 12"x12" Floor Tiles
					No change - one 12" x 12" broken corner

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munsathibam	Un Known	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1006 **Space Description:** Classroom 140  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	1,330 SF	0	Under 12"x12" Floor Tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Muresathinam	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1007 **Space Description:** Storage 140A  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	80 SF	0	Under 12"x12" Floor Tiles
					no change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Muniyathirum	Unleaded	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1008 **Space Description:** Classroom 142  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	740 SF	0	Under 12"x12" Floor Tiles
					12" FT cracked - Filled

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munisathivan	Unknown	NO.
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1009 **Space Description:** Classroom 143  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	740 SF	0	Under 12"x12" Floor Tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Pastor Muniyathilom	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1010 **Space Description:** Classroom 144  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	740 SF	0	Under 12"x12" Floor Tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Muvirathilam	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1011 **Space Description:** Classroom 145  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	740 SF	0	Under 12"x12" Floor Tiles
					<i>NO charge</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-12-2022</i>	<i>Parthi Munirathilam</i>	<i>Unknown</i>	<i>NO</i>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1012 **Space Description:** Reading Room 146

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	435 SF	0	Under 12"x12" Floor Tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Muralitharan	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1013 **Space Description:** Corridor

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	1,450 SF	0	Under 12"x12" Floor Tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munezathilam	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**ASHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1021

**Space Description:** Corridor

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong

**Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	375 SF	0	Under 12"x12" Floor Tiles
					no change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munezathilam	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1022 **Space Description:** Corridor, 5<sup>th</sup> Grade  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	1,300 SF	0	Under 12"x12" Floor Tiles
					NO change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munioathiben	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1023 **Space Description:** Classroom 147  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	760 SF	0	Under 12"x12" Floor Tiles
					12" FT - 3 tiled damaged (entrance)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munnathiram	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1024 **Space Description:** Classroom 148  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	760 SF	0	Under 12"x12" Floor Tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munisathirani	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1025

**Space Description:** Classroom 149

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong

**Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	760 SF	0	Under 12"x12" Floor Tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munisathivan	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1026 **Space Description:** Classroom 150  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	765 SF	0	Under 12"x12" Floor Tiles
					NO change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munisatharan	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1027 **Space Description:** Classroom 151  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	755 SF	0	Under 12"x12" Floor Tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munsathikern	unknown	ND
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1028 **Space Description:** Classroom 152  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	755 SF	0	Under 12"x12" Floor Tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munizathirum	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1033 **Space Description:** Storage 100A  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	50 SF	0	Under 12"x12" Floor Tiles
					No Change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Farthi Muresathilam	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1036 **Space Description:** Corridor

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	330 SF	0	Under 12"x12" Floor Tiles
					No charge

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Pasthi Muvirathikern	Unknown	N
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1037 **Space Description:** Corridor at Room 101  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	330 SF	0	Under 12"x12" Floor Tiles
					<i>No change</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-12-2022</i>	<i>Parthi Munsatharam</i>	<i>Unknown</i>	<i>No</i>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1038 **Space Description:** Room 101  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	230 SF	0	Under 12"x12" Floor Tiles
					no change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi MunDathivan	unknown	no
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1048 **Space Description:** Corridor, K-1  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	1,850 SF	0	Under 12"x12" Floor Tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munothirani	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1049 **Space Description:** Nurse Office

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	230 SF	0	Under Carpet 12" Blue FT (Assume under)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munrothian	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1050 **Space Description:** Hallway  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	230 SF	0	<del>Under Carpet</del> 12" white Floor tile 5 tiled 12" F damaged (Assure underneath)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munidathilam	Unknown	ND
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1051 **Space Description:** Storage

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	70 SF	0	Under Carpet Person floor (Assume below)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munzathilam	Unknown	no
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1052 **Space Description:** Office

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	200 SF	0	Under Carpet
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Pasthi Munsathikar	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1053 **Space Description:** Work Room  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	65 SF	0	<del>Under Carpet</del> 12" white Floor tile (Assume below)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Pavali Muniyathir	Unknown	no
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1055 **Space Description:** Office

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	170 SF	0	Under Carpet
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Pastor Munezathir	Unknown	ND
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1056 **Space Description:** Copy Center

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	45 SF	0	Under Carpet 12" white Floor tiles (Assure below)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munirathnam	Unknown	ND
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1057 **Space Description:** Office

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	180 SF	0	Under Carpet
					no change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Mundaathikem	unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1058 **Space Description:** Mail Room & Vestibule  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	110 SF	0	Under Carpet 12" white Finish (Assume below)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Pavithra Muthusathiyam	Unknown	no
2				
3				
4				
5				
<b>Date Next 3 Year Re-inspection is Required</b>		<b>January 2025</b>		

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1059 **Space Description:** Main Office  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	600 SF	0	<del>Under Carpet</del> 12" white & blue Floor tile (Assume below)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Muniswamy	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1061 **Space Description:** Corridor, Main

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	1,500 SF	0	Under 12"x12" Floor Tiles
					No charge

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munisathian	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1062 **Space Description:** Room 120  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	200 SF	0	Under 12"x12" Floor Tiles
					No charge

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Pavithri Munisathirani	Unknown	N
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1064 **Space Description:** Corridor, at Gymnasium

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
1	9"x9" Floor Tile/Mastic	N	800 SF	0	Under 12"x12" Floor Tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Pasthi Mavisatharam	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1072 **Space Description:** Corridor, Main  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	820 SF	0	Under 12"x12" Floor Tiles
					NO charge

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parth Munsatliyan	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1073 **Space Description:** Corridor, Main

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	30 SF	0	Under 12"x12" Floor Tiles
					No charge

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Pasthi Munsathian	Unharmful	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1097 **Space Description:** Office 119  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	245 SF	0	9"x9" and 12"x12" Floor Tile
					12" FT patched & one tile chipped

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Muresathier	Unknown	NO
2				
3				
4				
5				
<b>Date Next 3 Year Re-inspection is Required</b>		<b>January 2025</b>		

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1099 **Space Description:** Classroom 123  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	710 SF	0	Under 12"x12" Floor Tiles
					No charge

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Partho Munozathilam	unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1100 **Space Description:** Classroom 125  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	715 SF	0	Under 12"x12" Floor Tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Patricia Munoz	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1101 **Space Description:** Classroom 127  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	710 SF	0	Under 12"x12" Floor Tiles
					<i>no charge</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-12-2022</i>	<i>Parth Muniasthavan</i>	<i>Unknown</i>	<i>ND</i>
2				
3				
4				
5				
<b>Date Next 3 Year Re-inspection is Required</b>		<b>January 2025</b>		

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1105 **Space Description:** Corridor, Art Wing  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	1,100 SF	0	Under 12"x12" Floor Tiles
					<del>Unknown</del> No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Pasthi Munez-Hernandez	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1109 **Space Description:** Classroom 128  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	710 SF	0	Under 12"x12" Floor Tiles
					NO change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Pavithra Muresath	Unknown	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1110 **Space Description:** Classroom 126  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	715 SF	0	Under 12"x12" Floor Tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Muralidharan	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1111 **Space Description:** Classroom 124  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	710 SF	0	Under 12"x12" Floor Tiles
					12" FT Cracked - 4 N/A

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Pavithri Murugathur	Unknown	ND
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1115 **Space Description:** Corridor, Main  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
27	Mastic assoc. with 12"x12" Floor Tile	N	1,100 SF	20 SF	No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munnathala	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1116 **Space Description:** Auditorium

**School District:** White Plains Public Schools

**School Name:** Ridgeway Elementary School

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	2,310 SF	0	Under 12"x12" Floor Tiles
					NO change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Pastor M. Muroghian	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1125 **Space Description:** Corridor  
**School District:** White Plains Public Schools  
**School Name:** Ridgeway Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	1,100 SF	0	Under 12"x12" Floor Tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parghi Munsathian	Unknown	NO
2				
3				
4				
5				
<b>Date Next 3 Year Re-inspection is Required</b>		<b>January 2025</b>		

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.

Church Street Elementary School



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1028 **Space Description:** P.E. Office

**School District:** White Plains City School District

**School Name:** Church Street Elementary School

**Re-inspected By:** Jordan Wong, Zachary Collins **Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	155 SF	0	9"x9" Brown and Light Brown
					no change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Pastri Munizathas	Fair	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1028A **Space Description:** P.E. Office Closet  
**School District:** White Plains City School District  
**School Name:** Church Street Elementary School  
**Re-inspected By:** Jordan Wong, Zachary Collins **Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	25 SF	0	9"x9" Beige under Carpet
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Partee Munizathian	Fair Condition	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1059 **Space Description:** Room 17 Storage  
**School District:** White Plains City School District  
**School Name:** Church Street Elementary School  
**Re-inspected By:** Jordan Wong, Zachary Collins **Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	80 SF	0	9"x9" Gray w/White Stripes
					2 tiles cracked

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Partho Muralidharan	Fair Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1061 **Space Description:** Auditorium (Back Wall)  
**School District:** White Plains City School District  
**School Name:** Church Street Elementary School  
**Re-inspected By:** Jordan Wong, Zachary Collins **Date:** January 20, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
13	Acoustical Wall Plaster (white)	Y	450 SF	0	No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-12-2022	Parthi Munisathien	Good Condition	ND
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.

Eastview Middle School



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1001  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong

**Space Description:** Boy's Toilet Girls Toilet  
Storage room  
**Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
83	AIRCELL PIPE INSULATION	Y	10 LF	0	Unable to Locate Material
84	TAR PAPER ASSOC. W./ WINDOW FRAME	N	10 SF	0	Unable to Locate Material
					10 MPIS Associated with Fa Pipes

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Muneerathian	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1002 **Space Description:** Boys Girls Toilet  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
84	TAR PAPER ASSOC. W./ WINDOW FRAME	N	10 SF	0	no change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Muralitharan	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1178 **Space Description:** Boiler Room  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
210	DUCT BREECHING INSULATION	Y	1,000 SF	0	Wrap missing 105F & Loose

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munisatharan	Fab 8	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

Space ID: ----

Space Description: Crawl Space

School District: White Plains Public Schools

School Name: White Plains Middle School Eastview Campus

Re-inspected By: Jordan Wong

Date: January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
-	CONTAMINATED SOIL	Y	500 SF	0	Unable to Locate Material
					No charge

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munozathilam	Unable to find	
2				
3				
4				
5				

Date Next 3 Year Re-inspection is Required

January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** ---- **Space Description:** Crawl Space

**School District:** White Plains Public Schools

**School Name:** White Plains Middle School Eastview Campus

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
-	CONTAMINATED SOIL	Y	1,200 SF	0	Unable to Locate Material
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munisatharam	Unable to locate	—
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** ---- **Space Description:** Crawl Space  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
-	CONTAMINATED SOIL	Y	6,000 SF	0	Unable to Locate Material
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munirathikan	Unable to locate	—
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2020 **Space Description:** Science Room 103  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
165	SINK UNDERCOATING/ BLACK	N	20 SF	0	Beige Sink Under Coating observed 7 years ago renovated

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munroathibans	Good Condition	NO.
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2034.5B **Space Description:** Fac. Lounge Storage  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
164	SINK UNDERCOATING/ BLACK	N	10 SF	0	Room Converted - No More SINK

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Muralitharan	Unknown	NA
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2037F **Space Description:** Meeting Room  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
112	12" X 12" FLOOR TILE/ TAN WITH BROWN STREAKS	N	105 SF	0	New vinyl Perfo flooring observed. (Assume below)
113	12" X 12" FT TAN W./ BROWN STREAKS MASTIC				

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parth Munisathirani	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2037I **Space Description:** Copy room  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
112	12" X 12" FLOOR TILE/ TAN WITH BROWN STREAKS	N	150 SF	0	Vinyl Pergo flooring installed on top of 12" FT
113	12" X 12" FT TAN W./ BROWN STREAKS MASTIC				

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munozathilam	Unknown	NU
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2037K **Space Description:** Closet  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
112	12" X 12" FLOOR TILE/ TAN WITH BROWN STREAKS	N	65 SF	0	Vinyl Perfo floor observed Installed over 12" FT
113	12" X 12" FT TAN W./ BROWN STREAKS MASTIC				

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Muvanthiran	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2042 **Space Description:** Auditorium  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
128	12"X12" FLOOR TILE/ PURPLE/ MASTIC	N	480 SF	0	No change (Loose, Auditorium PIT)

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munisathian	Fair Condition	N
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2045 **Space Description:** Checkroom  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
138	9" X 9" FLOOR TILE/ BEIGE WITH STREAKS	N	300 SF	0	No change 50% of room stored with Book/Materials
139	9" X 9" FLOOR TILE/ BEIGE WITH STREAKS/ MASTIC				

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Muvattukuzhy	Fair Condition	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2067

**Space Description:** Classroom

**School District:** White Plains Public Schools

**School Name:** White Plains Middle School Eastview Campus

**Re-inspected By:** Jordan Wong

**Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
51	9" X 9" FLOOR TILE/ OFF-WHITE WITH BROWN STREAKS	N	835 SF	0	Now 12" white FT observed custodian said Abated

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Muresathorem	NA	NA
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 3076  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong

**Space Description:** Classroom 232 / 235  
**Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
11	12" X 12" FT/ CLOUD WHITE W./ GREEN SPOTS & TURQUOISE W./ GRAY SPOTS MASTIC	N	870 SF	0	12" Beige & Tan floor filed & sealed As per Custodian
45	9" X 9" FLOOR TILE/ LIGHT BROWN MASTIC				
46	9" X 9" FLOOR TILE/ LIGHT BROWN				

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munirathien	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 3085 **Space Description:** Classroom 1226  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
16	12" X 12" FT/ DEEP RED W./ WHITE SPOTS & YELLOW W./ ORANGE SPOTS MASTIC	N	706 SF	0	Assumed Under 12"x12" Beige & Brown
					NO change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munisatharan	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 3086 **Space Description:** Teach. lounge 228  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
16	12" X 12" FT/ DEEP RED W./ WHITE SPOTS & YELLOW W./ ORANGE SPOTS MASTIC	N	320 SF	0	12" White & Tan Floor
67	SINK UNDERCOATING/ BLACK	N	10 SF	0	tiles Cigarette Sand
					Asbestos

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munisathirani	Good Condition	N
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 3107  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong

**Space Description:** Classroom ~~206~~ / 211  
**Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
122	12"X12" FLOOR TILE/ WHITE WITH SPECS/ MASTIC (Type II)	N	615 SF	0	200 SF abated on 02/16-18/16 (3001214).
					No change
					12 <sup>th</sup> beige floor fr
					observed

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munisathirani	Good Condition	No.
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 4140A  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong

**Space Description:** Office classroom 318  
**Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
183	CEILING PLASTER/ TEXTURED/ WHITE COAT	Y	125 SF	0	2x2 Ceiling Panel (Assume Above)
184	CEILING PLASTER/ TEXTURED/ BROWN COAT				
185	WALL PLASTER/ TEXTURED/ WHITE COAT	Y	350 SF	0	No change
186	WALL PLASTER/ TEXTURED/ BROWN COAT				

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Paxton Munoz-Garcia	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**ASHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 4140B **Space Description:** Storage classroom 316  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
183	CEILING PLASTER/ TEXTURED/ WHITE COAT	Y	475 SF	0	2x2 Ceiling Panel (Assume above)
184	CEILING PLASTER/ TEXTURED/ BROWN COAT				
185	WALL PLASTER/ TEXTURED/ WHITE COAT	Y	800 SF	0	NO change 4
186	WALL PLASTER/ TEXTURED/ BROWN COAT				

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munisatharam	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 4140C  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong

**Space Description:** ~~Classroom~~ 317 classroom  
**Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
183	CEILING PLASTER/ TEXTURED/ WHITE COAT	Y	600 SF	0	2x2 Ceiling Panel (Assume Above)
184	CEILING PLASTER/ TEXTURED/ BROWN COAT				
185	WALL PLASTER/ TEXTURED/ WHITE COAT	Y	1,000 SF	0	NO change
186	WALL PLASTER/ TEXTURED/ BROWN COAT				

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munirathinam	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

### AHERA 3 YEAR RE-INSPECTION AND 6 MONTHS PERIODIC SURVEILLANCE FORM

#### ASBESTOS CONTAINING BUILDING MATERIALS

Space ID: 4140D Space Description: ~~Office~~ classroom 318  
School District: White Plains Public Schools  
School Name: White Plains Middle School Eastview Campus  
Re-inspected By: Jordan Wong Date: January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
183	CEILING PLASTER/ TEXTURED/ WHITE COAT	Y	85 SF	0	2x2 Ceiling Panel (Assume Above) NO Change
184	CEILING PLASTER/ TEXTURED/ BROWN COAT				
185	WALL PLASTER/ TEXTURED/ WHITE COAT	Y	350 SF	0	
186	WALL PLASTER/ TEXTURED/ BROWN COAT				

#### 6 MONTHS PERIODIC SURVEILLANCES

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Muralitharan	GMA Gundiha	No
2				
3				
4				
5				

Date Next 3 Year Re-inspection is Required January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 4140E  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong

**Space Description:** ~~Office~~ class room 318  
**Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
183	CEILING PLASTER/ TEXTURED/ WHITE COAT	Y	250 SF	0	2x2 Ceiling Panel (Assume Above) NO change
184	CEILING PLASTER/ TEXTURED/ BROWN COAT				
185	WALL PLASTER/ TEXTURED/ WHITE COAT	Y	600 SF		
186	WALL PLASTER/ TEXTURED/ BROWN COAT				

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Manojathiran	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** | **January 2025**

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 4150 **Space Description:** Classroom 328  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
16	12" X 12" FT/ DEEP RED W./ WHITE SPOTS & YELLOW W./ ORANGE SPOTS MASTIC	N	670 SF	0	12" white & tan new floor tiles observed. Condition said Abated

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Muresathirani	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 4150A **Space Description:** Storage  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
16	12" X 12" FT/ DEEP RED W./ WHITE SPOTS & YELLOW W./ ORANGE SPOTS MASTIC	N	80 SF	0	new 12" white & tan ft observed one today said Asated

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Muniswamy	Good Condition	N
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 4152 **Space Description:** Classroom 330  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
47	9" X 9" FT/ LT. BROWN W./ DK. BROWN STREAKS & RED W./ BLACK STREAKS MASTIC	N	705 SF	0	Assumed Under 12"x12" Beige & Brown
48	9" X 9" FT/ LIGHT BROWN WITH DARK BROWN STREAKS				Assumed Under 12"x12" Beige & Brown
49	9" X 9" FLOOR TILE/ RED WITH BLACK STREAKS				Assumed Under 12"x12" Beige & Brown
					<i>no charge</i>

**6 MONTHS PERIODIC SURVEILLANCES**

*Custodian said Asbestos*

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-13-2022</i>	<i>Parthi Munirathiran</i>	<i>Good Condition</i>	<i>NO</i>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 4154 **Space Description:** Classroom 332  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Eastview Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
16	12" X 12" FT/ DEEP RED W./ WHITE SPOTS & YELLOW W./ ORANGE SPOTS MASTIC	N	890 SF	0	12" white & tan Floukley offered Crystalline Solid Alated.

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munisenthiran	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 4159 **Space Description:** Classroom

**School District:** White Plains Public Schools

**School Name:** White Plains Middle School Eastview Campus

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
24	12" X 12" FT/ SKY BLUE W./ WHITE STREAKS & WHITE WITH MULTI-COLOR SPOTS MASTIC	N	870 SF	0	12" white & tan floor tiles observed Custodian said Asbestos

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munisatharan	Good Condition	N/A
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.

George Washington Elementary School



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1032

**Space Description:** Southwest Hallway by Room 123

**School District:** White Plains Public Schools

**School Name:** George Washington Elementary School

**Re-inspected By:** Jordan Wong

**Date:** January 21, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
02	Pipe Insulation	Y	40 LF	0	No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Muvirathinem	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1040 **Space Description:** Room 117A  
**School District:** White Plains Public Schools  
**School Name:** George Washington Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 21, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	64 SF	0	9"x9" Beige Floor Tiles under new 12"x12" Floor Tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munisathirum	Fair Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.

Mamaroneck Avenue Elementary School



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1063

**Space Description:** Storage

**School District:** White Plains Public Schools

**School Name:** Mamaroneck Avenue Elementary School

**Re-inspected By:** Jordan Wong

**Date:** January 21, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	2 SF	2 SF	9"x9" Beige Floor Tile no longer there, only mastic visible
					Concrete Slab
					Dark Tan Mastic mlt

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munirathnam		
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

Space ID: --

Space Description: Office / Storage

School District: White Plains Public Schools

School Name: Mamaroneck Avenue Elementary School

Re-inspected By: Jordan Wong

Date: January 21, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	276 SF	0	Unable to Locate Space/Material
02	Wall Mastic	N	315 SF	0	Unable to Locate Space/Material
					NO charge

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Muvirathikam	Unknown	✓
2				
3				
4				
5				

Date Next 3 Year Re-inspection is Required January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2018  
**School District:** White Plains Public Schools  
**School Name:** Mamaroneck Avenue Elementary School  
**Re-inspected By:** Jordan Wong

**Space Description:** Gym

**Date:** January 21, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
07	2'x2' (1'x1' Design) Ceiling Tile	N	4,835 SF	0	Assumed ACM
					no charge
					2x2 tile missing & 1x1 tiles
					opened

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Muvattilhan	Fair Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2023 **Space Description:** Gym Hallway  
**School District:** White Plains Public Schools  
**School Name:** Mamaroneck Avenue Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 21, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	60 SF	0	9"x9" Tan
					no change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Partho Munoz-Rodriguez	Fair Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2024 **Space Description:** Gym Storage  
**School District:** White Plains Public Schools  
**School Name:** Mamaroneck Avenue Elementary School  
**Re-inspected By:** Jordan Wong **Date:** January 21, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	30 SF	0	9"x9" Tan
					No change, corner chipped 1 tile

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Pastor Munniruthan	Fair Condition	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**ASBESTOS CONTAINING BUILDING MATERIALS**  
**6 MONTHS PERIODIC SURVEILLANCE FORM**  
**ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** -- **Space Description:** SE Exit Under Stairs

**School District:** White Plains Public Schools

**School Name:** Mamaroneck Avenue Elementary School

**Re-inspected By:** Jordan Wong **Date:** January 21, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	900 SF	0	Unable to Locate Space/Material
					Stair Flight below
					NOT Accessible
					Assure

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Murogholm	Unknown	—
2				
3				
4				
5				
<b>Date Next 3 Year Re-inspection is Required</b>		<b>January 2025</b>		

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



Rochambeau Alternative High School



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1001 **Space Description:** Classroom A  
**School District:** White Plains Public Schools  
**School Name:** Rochambeau Alternative High School  
**Re-inspected By:** Jordan Wong **Date:** July 7, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	815 SF	0	Under Non-ACM 12"x12" Floor Tile
					2 tiles missing & 1 tile chipped

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Partho Mukherjee	Fair Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1005 **Space Description:** Vestibule  
**School District:** White Plains Public Schools  
**School Name:** Rochambeau Alternative High School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	70 SF	0	Under Non-ACM 12"x12" Floor Tile <i>No change</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Munrothian	Good Condition	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1022 **Space Description:** Dark Room

**School District:** White Plains Public Schools

**School Name:** Rochambeau Alternative High School

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	400 SF	200 SF	9"x9" Cream (Significantly Damaged)
					entire tiles abated
					50% Portland mastic observed

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Pastor Mwendathika	Fab	ND
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2011 **Space Description:** Hallway  
**School District:** White Plains Public Schools  
**School Name:** Rochambeau Alternative High School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	320 SF	0	Under Non-ACM 12"x12" Floor Tile
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Muneeratharan	Good Condition	NV
2				
3				
4				
5				

<b>Date Next 3 Year Re-inspection is Required</b>	<b>January 2025</b>
---	---------------------

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2012 **Space Description:** Classroom 107B  
**School District:** White Plains Public Schools  
**School Name:** Rochambeau Alternative High School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	425 SF	0	Under Non-ACM 12"x12" Floor Tile
					<i>No chase</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-13-2022</i>	<i>Parthi Munozathokan</i>	<i>Good Condition</i>	<i>NO</i>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2013 **Space Description:** Classroom 107A  
**School District:** White Plains Public Schools  
**School Name:** Rochambeau Alternative High School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	345 SF	0	Under Non-ACM 12"x12" Floor Tile
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parth Munsathikan	Fair	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2027 **Space Description:** Walnut Lounge  
**School District:** White Plains Public Schools  
**School Name:** Rochambeau Alternative High School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	500 SF	0	9"x9" Tan w/Brown Specs
					no change
					1 tile cracked & 1 chipped

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Pastor M. Mursathian	Fair Condition	N/A
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 3034 **Space Description:** Auditorium  
**School District:** White Plains Public Schools  
**School Name:** Rochambeau Alternative High School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
02	Wall Plaster	N	7,000 SF	0	No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Muralidharan	Good Condition	N
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 3035 **Space Description:** Stage

**School District:** White Plains Public Schools

**School Name:** Rochambeau Alternative High School

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
03	Wire Insulation	Y	15 LF	0	Unable to Locate Wire Insulation
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-13-2022	Parthi Mundaithan	Unable to find	—
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025


<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 3041 **Space Description:** Stairway next to Room 225  
**School District:** White Plains Public Schools  
**School Name:** Rochambeau Alternative High School  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
34	Aircell Pipe Insulation at Radiator	Y	3 LF	0	 Custodian said removed Abated.
35	Pipe Canvas Wrap at Radiator	N		0	
36	Radiator Insulation	Y	6 SF	0	

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<u>12-13-2022</u>	<u>Parthi Munsathian</u>	<u>Unknown</u>	<u>—</u>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.

Highlands Middle School



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1001

**Space Description:** Crawl Space

**School District:** White Plains Public Schools

**School Name:** White Plains Middle School Highland Campus

**Re-inspected By:** Jordan Wong

**Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
03	Contaminated Soil	Y	1,000 SF	0	No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munezathian	Fair	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**ASHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 1075

**Space Description:** Crawl Space

**School District:** White Plains Public Schools

**School Name:** White Plains Middle School Highland Campus

**Re-inspected By:** Jordan Wong

**Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
03	Contaminated Soil	Y	1,000 SF	0	NO change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parth Muralidharan	Fair Condition	N
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**ASHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2001 **Space Description:** Suspension Room 147  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Highland Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	360 SF	10 SF	9"x9" Brown w/Black & White Spots
					<i>No change</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-14-2022</i>	<i>Parthi Muniswamy</i>	<i>Good Condition</i>	<i>NO</i>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2001A **Space Description:** Room 147 Vestibule  
**School District:** White Plains Public Schools  
**School Name:** White Plains Middle School Highland Campus  
**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	30 SF	0	9"x9" Brown w/Black & White Spots
					3 <sup>new</sup> 9" tiles cracked/damaged

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munirathnam	Fair Condition	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2014 **Space Description:** Dining Room

**School District:** White Plains Public Schools

**School Name:** White Plains Middle School Highland Campus

**Re-inspected By:** Jordan Wong **Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	500 SF	0	9"x9" White w/Gray Spots
					10 tiles cracked & one tile chipped

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Paxton Munizantashem	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** 2093

**Space Description:** Auditorium

**School District:** White Plains Public Schools

**School Name:** White Plains Middle School Highland Campus

**Re-inspected By:** Jordan Wong

**Date:** January 24, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
02	Ceiling Plaster	Y	8,060 SF	0	12" Ø water stain/ damage observed Paint peeling

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Murugathala	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.

White Plains High School



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** A1027  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong

**Space Description:** M. Locker A002 A11

**Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	182 SF	0	3 cracked tiles @ 12" Repl tiles observed

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munisathirum	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**ASHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** A1029  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong

**Space Description:** W. Locker A001 / A12

**Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	182 SF	4 SF	4 Cracked Tiles
					1 MISSING tile @ 1 corner tile
					@ 12" Beige tile

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	PARTHI MUNI RATHNAM	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** A2005 **Space Description:** Classroom A122  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	561 SF	0	12" beige/red spots tiles observed everywhere

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	PARITHI MUNI NATHANAM	Good Condition	N
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** A2007 **Space Description:** Classroom A121  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	713 SF	5 SF	5 cracked tiles
					New 12" beige/red spots
					tile observed

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	PARATH MURUPATHY	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** A2008 **Space Description:** Classroom A120  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	713 SF	0	New 12" Deep / Red Spots tiles observed

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munozathilam	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** A2009 **Space Description:** Classroom A119  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	713 SF	0	12" Beige Floor Tiles/Red grout New Tiles ordered

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munisathiyam	Good Condition	no
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** A2010 **Space Description:** Classroom A118  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	630 SF	3 SF	3 cracked tiles
					new 12" beige/red spot tiles offered

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munsathiyem	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** A2023 **Space Description:** Classroom A113  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	618 SF	0	12" patch tiles 2x08 missing 9" tiles small chipped - 5 tiles

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munozathilam	Fair Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** A2025 **Space Description:** Classroom A112  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	745 SF	0	12 <sup>th</sup> patch filed as per

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munsathwary	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** A2028 **Space Description:** Classroom A111  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	745 SF	0	12" Beige patch tile 1 missing 9" tiles chipped & filed

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Pavithri Munirathnam	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** A2031 **Space Description:** Classroom A109  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	745 SF	0	12" Patch tiles observed 9" tiles > chipped

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munsenthiran	Good condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** B1028 **Space Description:** Classroom B119  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	793 SF	2 SF	3 cracked tiles 12" patch tiled observed

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Pavithri Muneerathilam	Fair Condition	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** B1028A **Space Description:** Classroom B119 Closet  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	45 SF	0	Not Accessible, Fully Stored Books etc

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munianthiran	Unknown	—
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** B1029 **Space Description:** Classroom B120  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	749 SF	0	9" patch tiles - 20 NOT Cracked 9" tan tiles 5 chipped 1

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Mundayilam	Fair Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** B1030 **Space Description:** Classroom B121  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	749 SF	3 SF	10 cracked tiles; 1 missing tile 12" patch holes observed

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Barthi Munisathilam	Fair Condition	N/D
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** B1031 **Space Description:** Classroom B122

**School District:** White Plains Public Schools

**School Name:** White Plains High School

**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	749 SF	10 SF	10 cracked tiles, <del>1 missing tile</del>
					Patch 12" fiber offset

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Muniswamy	Fair Condition	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** B1033 **Space Description:** Classroom B123  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	621 SF	3 SF	3 cracked tiles
					4" = 3 tiles corner missing/broken
					12" Patch tiles offset

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Muvattukuzhian	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** B2010 **Space Description:** Classroom B207  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	649 SF	10 SF	9" tiles - 10 cracked tiles 12" patch tiles - 2 Damaged

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munizathillem	Fair Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** B2012  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong

**Space Description:** Classroom B208 *Janitor closet B208*

**Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	50 SF	2 SF	2 cracked tiles ✓ <i>9 tiles 4 MISSING</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-14-2022</i>	<i>Parthi Munirathilam</i>	<i>Fair Condition</i>	<i>NO</i>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** **January 2025**

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** B2018 **Space Description:** Classroom B211  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	749 SF	0	No change 12" patch here observed

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Muthukrishnan	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** B2033 **Space Description:** Classroom B219  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	649 SF	2 SF	2 cracked tiles
					12" patch tiles JSform

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Partho Mousmtheken	Fair Condition	ND
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** B2034 **Space Description:** Classroom B220  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	749 SF	2 SF	2 cracked tiles, 2 missing tiles
					12 <sup>th</sup> patch tiles observed

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parvathi Muniswatharan	Good Condition	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** B2036 **Space Description:** Classroom B221  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	749 SF	1 SF	1 cracked tile
					12" patch tiled & sealed

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munirathnam	Fair Condition	N
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** B2037 **Space Description:** Classroom B222  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	749 SF	1 SF	2 cracked tile 4 tiles chipped 12" floor tiles patched

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Partho Mundayathil	Fair Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** B2038 **Space Description:** Classroom B223  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	649 SF	0	12 <sup>th</sup> patch filed Observed

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Muralidharan	Good Condition	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** C1005 **Space Description:** Janitor's Office C030  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
02	Transite Soffit	N	40 SF	2 SF	NOT ALL - 56

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Patricia M. Muroff	Unknown	—
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** C1008 **Space Description:** Teacher's Photo Copy

**School District:** White Plains Public Schools

**School Name:** White Plains High School

**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	793 SF	55 SF	10 tiles cracked

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Paras Munnathakern	Fair Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** C1024  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong

**Space Description:** Janitor's Closet A003A / CY

**Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	32 SF	5 SF	8 Missing Tiles
					NO change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munderthir	Fair Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** C1031 **Space Description:** Comp. Graph C006  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	420 SF	5 SF	3 missing tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Pamela Murawski	Fair Condition	NV
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** C1032 **Space Description:** Video C009  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	690 SF	10 SF	25 <del>10</del> cracked tiles 3 chipped tiles

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Pavithra Muralidharan	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** C2084 **Space Description:** Elec. C115  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	28 SF	2 SF	4 missing tiles ✓ NO change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Pavle Muroshnikov	Floor Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** C2087 **Space Description:** Classroom C110  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	743 SF	0	10 tiles chopped/cracked

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Mueenathibem	Fair Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**ASHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** C2088 **Space Description:** Classroom C111  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	750 SF	75 SF	13 tiles chipped

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Pavani Munzathilam	Fair Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** C2089 **Space Description:** Classroom C109  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	231 SF	0	2 tiles chipped corner

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parth Mundayathilam	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** C2090  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong

**Space Description:** Classroom C108  
**Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	736 SF	0	2 missing tiles
					1 tile chipped 12" patch tiles
					15 patch 9" beige tiles
					observed

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Muresath	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** C2092 **Space Description:** Classroom C107  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	693 SF	10 SF	10 cracked tiles
					Patch 12" white tiles
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Pavni Munsathikern	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** C2093  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong

**Space Description:** Classroom C105  
**Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	768 SF	2 SF	2 cracked tiles, 2 missing tiles 1 chipped tile

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Pamela Munoz-Rodriguez	Good Condition	No
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** C2095 **Space Description:** Classroom C104  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	770 SF	0	2 tiles damaged

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munozathilam	Good Condition	no
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** C2105 **Space Description:** Janitor's Closet C148A  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	30 SF	2 SF	7 missing tiles ✓
					no charge

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munozathilam	Fair Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** E2012  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong

**Space Description:** Office / E108

**Date:** January 19, 2022


Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	110 SF	0	no change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-16-2022	Parthi Muneeratharan	Good Condition	NU
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



## ASBESTOS CONTAINING BUILDING MATERIALS

**Space Description:** Office

**School Name:** White Plains High School

**Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	95 SF	0	<i>no charge</i>

## 6 MONTHS PERIODIC SURVEILLANCES

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Patric Munnaththirana	Good Condition	NO
2				
3				
4				
5				

<b>Date Next 3 Year Re-inspection is Required</b>	<b>January 2025</b>
---	---------------------

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** E2018 **Space Description:** Office  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	95 SF	0	No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Mundathil	Good Condition	N
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

E107

E203A

**Space ID:** E2022  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong

**Space Description:** Office

**Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	110 SF	0	1 tile chipped/cracked

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parker Munoz-Gonzalez	Good Condition	N
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** E3004 **Space Description:** Janitor's Closet  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	18 SF	0	2 missing tiles ✓ <i>no change</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-14-2022</i>	<i>Parthi Manjutha</i>	<i>Fair Condition</i>	<i>No</i>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** E3014  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong

**Space Description:** ~~Classroom E216~~ Exercise room

**Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	680 SF	0	Gym Matt flooring observed above below

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Pavithra Munisathir	Unknown	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.





500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

*Exercise room*

**Space ID:** E3015  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong

**Space Description:** ~~Classroom E217~~ *Exercise room*

**Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	675 SF	0	<i>Floor Matt observed Assume FT below</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-14-2022</i>	<i>Pamela Munoz-Holmes</i>	<i>Unchanged</i>	<i>NO</i>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required**     **January 2025**

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** E3017 **Space Description:** Office  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	100 SF	0	Good / no change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Paxhi Mawanthirani	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**ASHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** E3019  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong

**Space Description:** Office / E211A

**Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	60 SF	2 SF	2 cracked tiles ✓
					No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Pastor's Muniz	Good Condition	N
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** E3020 **Space Description:** Office  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	100 SF	0	No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Munozathil	Good condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** E3022 **Space Description:** Office  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	100 SF	0	No change

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Muresathian	Good Condition	NO
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** F2001 **Space Description:** Pool  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong **Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
16	Interior Vertical Expansion Joint Caulking at Brick Curtain Walls (grey)	No	120 LF	0	<i>No change</i>
56	Decorative Backboard	No	960 SF	0	Slated for abatement in summer 2022 - <i>unable</i>
					<i>to 10/6/22</i>

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	<i>12-14-2022</i>	<i>Patricia Munoz-thien</i>	<i>Fair Condition</i>	<i>NO</i>
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.



500 Summit Lake Drive, Suite 450  
Valhalla, New York 10595

**AHERA 3 YEAR RE-INSPECTION AND  
6 MONTHS PERIODIC SURVEILLANCE FORM  
ASBESTOS CONTAINING BUILDING MATERIALS**

**Space ID:** H1018  
**School District:** White Plains Public Schools  
**School Name:** White Plains High School  
**Re-inspected By:** Jordan Wong

**Space Description:** South Stairs

**Date:** January 19, 2022

Homogeneous Area #	Homogeneous Area Description	Friable (Yes/No)	Quantity	Damage Quantity	Notes <sup>1</sup>
01	9"x9" Floor Tile/Mastic	N	100 SF	0	NOT Accessible As per Custodian All New Flooring

**6 MONTHS PERIODIC SURVEILLANCES**

No.	Inspection Date	Name of Inspector	Asbestos Containing Building Materials Condition Notes	Fiber Release Episodes (Y/N)
1	12-14-2022	Parthi Muralidharan	—	—
2				
3				
4				
5				

**Date Next 3 Year Re-inspection is Required** January 2025

<sup>1</sup> Material Condition, Accessibility to Public, Warning Labels, etc.