

Lead in Water Testing Results
South Washington County Schools
District Service Center

On December 31st, 2020 the District Program Center's drinking water was tested for concentration of lead.

All water sources tested less than 20 parts-per-billion.

No action was taken at this time.

LOCATION	SOURCE	RESULTS (in ug/L)
Blueprint Room/Dining	SINK	5.5
Staff Dining by Admin	SINK	8.1
Hallway (left)	FOUNTAIN	1.5
Hallway (right)	FOUNTAIN	.58
Cafeteria	SINK	.21
Staff Workroom by HR/etc.	SINK	9.8
Grounds	SINK	3.4
Grounds	FOUNTAIN	8.2