

Lead in Water Testing Results  
South Washington County Schools  
Woodbury Elementary School

On December 29<sup>th</sup>, 2020 Woodbury Elementary School's drinking water was tested for concentration of lead.

**The following water sources tested less than 20 parts-per-billion.**

**No action was taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Cafeteria	FOUNTAIN	0
Cafeteria	BOTTLE FILLER	0
Kitchen	SINK	5.0
Kitchen	SPRAYER	6.0
Staff Room	SINK	5.5
Room 203	SINK	13.5
Room 206	SINK	17.1
Room 206	FOUNTAIN	8.0
Room 204	SINK	13.7
Room 204	FOUNTAIN	18.5
Room 202	FOUNTAIN	4.6
Room 207	FOUNTAIN	12.4
Room 205	SINK	8.4
Room 208	FOUNTAIN	7.9
Room 209	FOUNTAIN	10.1
Room 213	FOUNTAIN	14.4

Room 211	SINK	4.9
Room 216 (right)	SINK	12.9
Room 216 (left)	SINK	10.7
Room 218	SINK	5.1
Room 220	SINK	2.7
Room 221	SINK	16.4
Room 219	SINK	3.9
Room 215 (left)	SINK	12.4
Room 215 (right)	SINK	18.6
Media Center Work Room	SINK	5.8
Room 127	SINK	3.7
Room 127	FOUNTAIN	3.4
Room 128	SINK	6.5
Room 128	FOUNTAIN	1.4
Room 126	SINK	4.4
Room 126	FOUNTAIN	.66
Hallway (east, left)	FOUNTAIN	2.0
Hallway (east, right)	FOUNTAIN	1.9
Room 122	SINK	4.9
Room 122	FOUNTAIN	2.4
Room 120	SINK	3.7
Room 120	FOUNTAIN	5.1
Room 118	SINK	7.5
Room 118	FOUNTAIN	4.2
Room 116	SINK	7.7

Room 116	FOUNTAIN	5.9
Room 114	SINK	14.9
Room 112	SINK	5.4
Room 112	FOUNTAIN	6.5
Room 111	SINK	13.4
Room 110	SINK	17.2
Room 110	FOUNTAIN	14.8
Room 109	SINK	8.1
Room 108	SINK	9.6
Room 108	FOUNTAIN	7.2
Room 107	SINK	7.8
Room 107	FOUNTAIN	16.4
Room 106	SINK	8.0
Room 106	FOUNTAIN	10.9
Room 105	FOUNTAIN	11.1
Room 104	FOUNTAIN	16.0
Room 103	SINK	8.2
Room 103	FOUNTAIN	16.8
Hallway (north)	FOUNTAIN	12.0
Room 102	FOUNTAIN	17.5
Room 101	SINK	7.8
Room 101	FOUNTAIN	8.4

**The following water sources tested with results of the concentration to be over 20 parts-per-billion. The fixtures of these water sources have been replaced and a re-test was administered. Results of the initial test and retest are below. No water sources re-tested over 20 parts-per-billion, so no further action was taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>INITIAL RESULTS (in ug/L)</b>	<b>RE-TEST RESULTS</b>
Room 102	SINK	28.2	9.4
Room 104	SINK	19.9	15.1
Room 202	SINK	39.7	11.3
Room 207	SINK	32.0	13.9

The following water sources tested with results of the concentration to be over 20 parts-per-billion. These fixtures were replaced and a filter was added. Results of the initial and final retest are below. No water sources re-tested over 20 parts-per-billion, so no further action was taken at this time.

Nurse's Office	SINK	29.1	0
Room 105	SINK	24.1	0
Room 213	SINK	40.6	0
Room 209	SINK	22.7	0
Room 208	SINK	35.4	0
Room 210	SINK	50.4	0
Room 212	SINK	23.6	.4
Room 214C	SINK	39.3	0