

Lead in Water Testing Results  
South Washington County Schools  
Middleton Elementary

On December 28<sup>th</sup>, 2021 Middleton Elementary School's drinking water was tested for concentration of lead.

**The following water sources tested less than 20 parts-per-billion.**

**No action was taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Nurse's Office	SINK	.29
Office Workroom	SINK	.16
Staff Lounge	SINK	1.4
Kitchen (right)	SINK	11.7
Kitchen	SPRAYER	4.7
Hallway (outside gym)	FOUNTAIN	0
Hallway (outside gym)	BOTTLE FILLER	0
Gym A	FOUNTAIN	2.7
Room 189	SINK	3.3
Room 188	SINK	6.2
Room 187	SINK	2.6
Room 186	SINK	1.3
Room 185	SINK	2.4
Room 184	SINK	9.6
Room 183	SINK	1.3
Room 182	SINK	1.7
Hallway (SW)	FOUNTAIN	0

Hallway (SW)	BOTTLE FILLER	0
Room 137	SINK	19.2
Room 136	SINK	2.3
Hallway (outside 136)	SINK	3.8
Room 133	SINK	2.4
Room 127	SINK	4.1
Hallway (outside 129)	SINK	18.6
Room 130	SINK	1.9
Room 102	SINK	2.9
Room 102 (by bathroom)	SINK	8.8
Room 101 (by bathroom)	SINK	10.4
Room 100 (left)	SINK	1.3
Room 100 (right)	SINK	3.2
Room 100 (by bathroom)	SINK	.78
Room 99 (left)	SINK	2.0
Room 99 (right)	SINK	1.9
Room 99 (by bathroom)	SINK	.65
Hallway (NE)	FOUNTAIN	2.7
Room 115	SINK	2.9
Room 116	SINK	9.7
Room 117	SINK	3.1
Hallway (outside 117)	SINK	3.2
Hallway (outside 118)	SINK	3.6
Room 118	SINK	3.1
Room 119	SINK	.82

Room 120	SINK	1.2
Room 125	SINK	2.4
Hallway (outside 124)	SINK	4.6
Room 122	SINK	2.2
Room 121	SINK	2.0
Media Center Workroom (right)	SINK	7.6
Media Center Workroom (left)	SINK	15.3

The following water sources tested over 20.0 and a large water flush in the building was administered. Testing after this flush resulted in all tests under the action level of 20.0.

Kitchen (left)	SINK	27.1	13.3
Room 138	SINK	43.4	12.2
Hallway (outside 135)	SINK	23.1	7.6
Room 135	SINK	22.1	7.7
Room 134	SINK	29.3	10.2
Room 128	SINK	24.5	3.3
Room 129	SINK	24.0	1.3
Hallway (outside 130)	SINK	40.8	16.4
Room 131	SINK	24.7	3.3
Room 132	SINK	31.0	13.1
Room 101	SINK	25.6	13.3
Room 126	SINK	39.8	19.1
Room 124	SINK	27.0	10
Hallway (outside 123)	SINK	30.2	11.1
Room 123	SINK	34.1	11.3