

Lead in Water Testing Results  
South Washington County Schools  
Cottage Grove Elementary School

On December 28<sup>th</sup>, 2021 Cottage Grove Elementary School's drinking water was tested for concentration of lead.

**The following water sources tested less than 20 parts-per-billion.**

**No action was taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Nurse's Office	SINK	3.0
Kitchen (left)	SINK	3.8
Kitchen (right)	SINK	3.1
Kitchen (sprayer)	SPRAYER	6.3
Hallway (outside gym)	FOUNTAIN	0
Hallway (outside gym)	BOTTLE FILLER	0
Gym A	FOUNTAIN	1.6
Gym B	FOUNTAIN	.1.2
Gym C	FOUNTAIN	1.5
Staff	SINK	.30
Hallway (NE, left)	FOUNTAIN	1.4
Hallway (NE, right)	FOUNTAIN	1.0
Room E101	SINK	3.0
Hallway (outside E116)	SINK	4.5
Room E115	SINK	3.1
Room E114	SINK	3.3

Room E112	SINK	3.3
Room E119	SINK	8.9
Room E118	SINK	12.9
Room E103	SINK	3.4
Room E104	SINK	1.2
Room E111	SINK	4.0
Room E109	SINK	5.3
Hallway (outside E108)	SINK	18.5
Room E106	SINK	1.8
Hallway (SE, right)	FOUNTAIN	1.1
Hallway (SE, left)	FOUNTAIN	.93
Room D116 (by bathroom)	SINK	16.1
Room D108	SINK	8.1
Room D 108 (by bathroom)	SINK	13.6
Room D103	SINK	11.3
Room D103 (by bathroom)	SINK	7.7
Hallway (SW, girls)	FOUNTAIN	1.4
Hallway (SW, boys)	FOUNTAIN	1.4
Room C106	SINK	8.2
Hallway (outside C107)	SINK	15.7
Room C108	SINK	18.6
Room C111	SINK	1.2
Room C103	SINK	4.1
Room C112	SINK	7.6
Room C114	SINK	8.8

Room C115	SINK	4.4
Hallway (outside C115)	SINK	2.8
Room C116	SINK	3.4
Room C101	SINK	6.6
Hallway (NW, left)	FOUNTAIN	1.4
Hallway (NW, right)	FOUNTAIN	1.5
Media Center Workroom	SINK	8.0

**The following water sources tested with results of the concentration to be over 20 parts-per-billion. The fixtures of these water sources were flushed, and a re-test was administered. Results of the initial test and retest are below. No water sources re-tested over 20 parts-per-billion and no further action will be taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>INITIAL RESULTS (in ug/L)</b>	<b>RE-TEST RESULTS</b>
Room E116	SINK	42.9	2.1
Room E108	SINK	32.3	2.1
Room E107	SINK	28.0	6.0
Room D116	SINK	69.5	4.0
Room C107	SINK	53.7	3.1
Room C109	SINK	20.8	.47
Room C118	SINK	20.1	1.1
Room C119	SINK	28.2	.45
Room C104	SINK	20.2	.87