

Lead in Water Testing Results
South Washington County Schools
Pullman Elementary

On December 30th, 2018 Pullman Elementary School's drinking water was tested for concentration of lead.

All water sources tested less than 20 parts-per-billion.

No action was taken at this time.

LOCATION	SOURCE	RESULTS (in ug/L)
Nurse's Office	SINK	9.0
Staff Lounge	SINK	5.0
Hallway (outside gym)	FOUNTAIN	0
Hallway (outside gym)	BOTTLE FILLER	0
Cafeteria	FOUNTAIN	0
Cafeteria	BOTTLE FILLER	0
Kitchen	SINK	6.7
Kitchen	SPRAYER	7.9
Room 124	SINK	6.7
Room 123	SINK	8.3
Room 122	SINK	6.3
Room 121	SINK	10.5
Room 120	SINK	7.1
Room 119	SINK	7.7
Room KA	SINK	7.7
Room KB	SINK	8.9

Room 118	SINK	11.4
Room 116	SINK	8.1
Room 115	SINK	9.3
Room 114	SINK	9.7

The following water sources tested with results of the concentration to be over 20 parts-per-billion. The fixtures of these water sources were heavily flushed and a re-test was administered. Results of the initial test and retest are below. No water sources re-tested over 20 parts-per-billion and no further action will be taken at this time.

LOCATION	SOURCE	INITIAL RESULTS (in ug/L)	RE-TEST RESULTS
Room 117	SINK	48.4	4.5
Room 109	SINK	21.2	17.5
Room 110	SINK	22.7	17.7
Room 111	SINK	22.9	9.2
Room 112	SINK	26.4	12.9