

Churchville Elementary School - Churchville-Chili CSD
Lead Test Results 2021

Lead Testing 2021					
Location: Churchville Elementary					
Lab I D #	Locations	Collection Date	Description	Result	Action
012104407-0001	MAIN OFFICE	4/26/2021	WATER COOLER BOTTLE FILLER	0.00	N/A
012104407-0002	MAIN OFFICE	4/26/2021	FAUCET	1.11	N/A
012104407-0003	NURSE OFFICE	4/26/2021	FAUCET	1.44	N/A
012104407-0004	NURSE OFFICE	4/26/2021	WATER COOLER BOTTLE FILLER	0.00	N/A
012104407-0005	RM 303	4/26/2021	WATER COOLER BOTTLE FILLER	0.00	N/A
012104407-0006	RM 107	4/26/2021	WATER COOLER BOTTLE FILLER	0.00	N/A
012104407-0007	RM 107	4/26/2021	FAUCET	7.47	N/A
012104407-0008	RM 110	4/26/2021	FIRST FAUCET	2.41	N/A
012104407-0009	RM 110	4/26/2021	FAUCET BUBBLER	6.12	N/A
012104407-0010	RM 118	4/26/2021	WATER COOLER BOTTLE FILLER	0.00	N/A
012104407-0011	CAFÉ	4/26/2021	WATER COOLER BOTTLE FILLER	0.00	N/A
012104407-0012	KITCHEN	4/26/2021	PREP FAUCET F	3.04	N/A
012104407-0013	KITCHEN	4/26/2021	PREP FAUCET BUBBLER	5.76	N/A
012104407-0014	RM 121	4/26/2021	FAUCET	1.66	N/A
012104407-0015	RM 121	4/26/2021	BUBBLER	2.20	N/A
012104407-0016	RM 122	4/26/2021	FAUCET	2.10	N/A
012104407-0017	RM 122	4/26/2021	BUBBLER	2.43	N/A
012104407-0018	RM 123	4/26/2021	FAUCET	2.55	N/A
012104407-0019	RM 123	4/26/2021	BUBBLER	3.14	N/A
012104407-0020	RM 124	4/26/2021	FAUCET	2.86	N/A
012104407-0021	RM 124	4/26/2021	BUBBLER	3.39	N/A
012104407-0022	RM 125	4/26/2021	FAUCET	2.49	N/A
012104407-0023	RM 125	4/26/2021	BUBBLER	3.74	N/A
012104407-0024	RM 126	4/26/2021	FAUCET	2.99	N/A
012104407-0025	RM 126	4/26/2021	BUBBLER	4.39	N/A

