

Test Kit	Start Date	Start Time	End Date	End Time	Temperature	Facility	Building	Room	Project ID	Floor	Result	Variance	Analysis Notes	Analysis Date	%Moisture
9120234	12/17/2018	1:00 PM	12/20/2018	1:00 PM	70	FIR GROVE	MAIN	B112	DISTRICT RADON TESTING	1	5.3	0.5		12/24/2018	6.8
9120397	2/5/2019	3:00 PM	2/8/2019	2:00 PM	70	FIR GROVE 2	MAIN	ROOM B112	DISTRICT RADON TESTING	1	9.2	0.8		2/12/2019	4.4
9120304	1/29/2019	3:00 PM	2/4/2019	2:00 PM	70	FIR GROVE 2	MAIN	B112 MISSING	DISTRICT RADON TESTING	1					
02472	10/4/2021	9:20 AM	10/8/2021	3:20 PM		FIR GROVE 3	MAIN	B112		1	0.4		Short-Term post-mitigation diagnostic test, with duration of 101 hours.		

Kit #	Started	Ended	Facility	Room Id	pCi/L	Variance	Analyzed
9123293	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	CAFETERIA 1	1.6	0.4	2019-02-25
9123278	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	CAFETERIA 2	2.1	0.4	2019-02-25
9123285	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	CHAMBERLAIN OFF.	< 0.3	0.2	2019-02-25
9119940	2019-02-19 @ 5:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	CONF 2	1.1	0.3	2019-02-25
9119952	2019-02-19 @ 5:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	CONF. 2 DUP	1.1	0.3	2019-02-25
9123284	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	CONFERENCE RM 1	< 0.3	0.2	2019-02-25
9119943	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	CUSTODIAN BLANK	< 0.3	0.2	2019-02-25
9119942	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	CUSTODIAN DUP	2.7	0.4	2019-02-25
9123297	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	CUSTODIAN OFFICE	2.5	0.4	2019-02-25
9123296	2019-02-19 @ 4:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	GYM 1 DAMAGED	1.6	0.4	2019-02-25
9123282	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	GYM 2	1.9	0.4	2019-02-25
9123298	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	HEALTH ROOM	< 0.3	0.2	2019-02-25
9119950	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	LIBRARY 1	1.3	0.3	2019-02-25
9119958	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	LIBRARY 2	1.6	0.4	2019-02-25
9119948	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	LIBRARY OFFICE	1.5	0.4	2019-02-25
9123289	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	MAIN OFFICE	< 0.3	0.2	2019-02-25
9123287	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	MS CALLIE DUP	< 0.3	0.2	2019-02-25
9123283	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	MS. CALLIE OFF.	< 0.3	0.2	2019-02-25
9123245	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	OFFICE WORK ROOM	< 0.3	0.2	2019-02-25
9119944	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	P.E. OFFICE	1.7	0.4	2019-02-25
9123286	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	PLAY RM 1	1.3	0.4	2019-02-25
9123290	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	PLAY RM 2	2.7	0.4	2019-02-25
9123288	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	PRINCIPAL OFF.	< 0.3	0.2	2019-02-25
9119951	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	PRODUCTION RM	1.1	0.4	2019-02-25
9123295	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	RESOURCE CENTER	< 0.3	0.2	2019-02-25
9119961	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	RM C118 BLANK	< 0.3	0.2	2019-02-25
9119945	2019-02-19 @ 5:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	ROOM 100	< 0.3	0.2	2019-02-25
9119953	2019-02-19 @ 5:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	ROOM 102	0.7	0.3	2019-02-25
9123299	2019-02-19 @ 5:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	ROOM 104	0.6	0.3	2019-02-25
9123300	2019-02-19 @ 5:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	ROOM 106	< 0.3	0.2	2019-02-25
9123260	2019-02-19 @ 5:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	ROOM 108	0.6	0.3	2019-02-25
9119936	2019-02-19 @ 5:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	ROOM 114	3.3	0.5	2019-02-25
9119941	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM B108	1.3	0.4	2019-02-25
9119959	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM B110	< 0.3	0.2	2019-02-25
9119956	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM B112	1.1	0.3	2019-02-25
9119935	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM B114	3.5	0.5	2019-02-25
9119954	2019-02-19 @ 6:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM B116	< 0.3	0.2	2019-02-25
9119957	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM B118	< 0.3	0.2	2019-02-25
9119955	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM B120	< 0.3	0.2	2019-02-25
9119964	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM C104	1.5	0.4	2019-02-25
9119965	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM C106	3.5	0.5	2019-02-25
9119966	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM C108	0.7	0.3	2019-02-25
9119946	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM C110	1.2	0.4	2019-02-25
9119949	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM C112	1.1	0.4	2019-02-25
9119947	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM C114	< 0.3	0.2	2019-02-25
9119960	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM C116	< 0.3	0.2	2019-02-25
9119963	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM C118	< 0.3	0.2	2019-02-25
9119962	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	ROOM C118 DUP	< 0.3	0.2	2019-02-25
9123294	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	SPEECH ROOM	< 0.3	0.2	2019-02-25
9123292	2019-02-19 @ 4:00 pm	2019-02-22 @ 3:00 pm	RIDGEWOOD	STAFF BREAK RM	< 0.3	0.2	2019-02-25
9119969	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	PORT 1 DUP	< 0.3	0.2	2019-02-25
9119968	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	PORT. 1	< 0.3	0.2	2019-02-25
9119967	2019-02-19 @ 5:00 pm	2019-02-22 @ 4:00 pm	RIDGEWOOD	PORTABLE 2	< 0.3	0.2	2019-02-25