



**ROCKFORD BOARD OF EDUCATION  
INVITATION FOR BID ON SUPPLIES, MATERIALS, EQUIPMENT OR SERVICES  
FOR SCHOOL DISTRICT NO. 205  
ROCKFORD, ILLINOIS**

IFB No.        **23-37 Security Vestibules at Flinn, Guilford, Lincoln, Nashold & Summerdale Schools**

DATE:         **February 3, 2023**

RE:            **ADDENDUM NO. 2**

---

To All Bidders:

Included are modifications, clarifications and/or corrections for the Project Manual and are hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

**If you plan to hand deliver your IFB submission on the due date, please note you must check in on the 1st floor prior to coming to the bid opening. Please allow time for this as late submission will not be accepted.**

Refer all questions relative to the business aspect, Instructions to Bidders, Special Conditions, and questions concerning the technical aspect of the documents to the Director of Purchasing by email at [purchasingdeptstaff@rps205.com](mailto:purchasingdeptstaff@rps205.com).

**CLARIFICATIONS/MODIFICATIONS**

This addendum includes the pre-bid conference opening statement, sign-in sheet, and minutes, as well as revised specifications.

ROCKFORD BOARD OF EDUCATION

By: Dane Youngblood  
Director of Purchasing

## **ADDENDUM TWO**

RLJA Project No.: **22-052**  
RPS Bid #: **23-37**

Date: **February 2, 2023**

Subject: **CHANGES to the BIDDING DOCUMENTS**

Project: **SECURITY VESTIBULE AT  
VARIOUS SCHOOLS FOR  
ROCKFORD PUBLIC SCHOOL DISTRICT #205  
ROCKFORD, ILLINOIS**

Bids Due: **2:00PM, TUESDAY, FEBRUARY 14, 2023**


From: **ARCHITECT: RICHARD L. JOHNSON ASSOCIATES, INC.  
4703 CHARLES STREET  
ROCKFORD, IL 61108**

To: **ALL PROJECT DOCUMENT HOLDERS**

Please reproduce this Addendum as needed and attach to the Project Manuals for the above project.

Bidders shall indicate receipt of this and all Addenda in the space provided on the Bid Form. Failure to do so may be sufficient cause to reject the bid.

Sincerely,  
RICHARD L. JOHNSON ASSOCIATES, INC.

  
\_\_\_\_\_  
Scott R. Johnson, AIA, LEED AP

This Addendum consists of:  
Pages 1 thru 2.

**NOTE:** Wherein this Addendum conflicts with the original Project Manual and Drawings, this Addendum shall govern.

## **CHANGES to the PROJECT MANUAL**

### **1. GENERAL ITEMS**

- 1.1. Question: "Please verify if the concrete shown in detail 8 on page A119 for the floor hatch at Nashold E.C. is new or existing. Please also verify the extents of demolition and new work if it is indeed new work.

Answer: "The concrete shown in this detail is new concrete. Existing floor will need to be removed as required to install the new walls and floor. Contractor shall patch in the concrete floor as required. Contractor to dowel existing slab to new concrete work with 12" long #5 rebar 18" o.c."

**END ADDENDUM NUMBER 2**