Stohl ENVIRONMENTAL

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

December 15, 2020

Mr. Michael Bryniarski
Director of Facilities
Lancaster Central School District
177 Central Avenue
Lancaster, NY 14086

RE: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Bryniarski:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Lancaster Central School District, including:

- Court Street Elementary – 91 Court Street, Lancaster, New York.

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on October 17, 2020. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 *(Executive Summary)* of the accompanying report, based upon the sampling and analysis performed, 1 source of potable water in Court Street Elementary has been identified as having a lead concentration in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Lancaster Central School District.

Sincerely,
Stohl Environmental, LLC.



Eric Henderson Jr.
Senior Project Manager

Investigation and Sampling Of Sources of Potable Water For Lead Concentrations

Prepared for:

Lancaster Central School District

Prepared by:

Stohl ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Conditions as of October 17, 2020

Stohl ENVIRONMENTAL

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

Summary Tabulation

Lead in Drinking Water Investigation

1.1. Scope of Work and Sampling Protocol

1.2. Executive Summary of Sampling and Analysis

1.3. Response Actions Required Under NYS Regulations

1.4. Laboratory Analytical Reports by Building

1.5. Laboratory Certifications

1.6. Chains of Custody

Stohl ENVIRONMENTAL

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Lancaster Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Court Street Elementary – 91 Court Street, Lancaster, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Court Street Elementary. Outlets are defined in NYS regulations as: "a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets".

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***'3Ts for Reducing Lead in Drinking Water in Schools"***, Stohl Environmental's protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.

- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health's Environmental Laboratory Approval Program (ELAP).

Stohl ENVIRONMENTAL

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Court Street Elementary	10/17/2020	89	88	1	N/A	N/A

****** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
169.5-10	Cafeteria Kitchen Hallway	Bubbler	19.8

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

(a) Prohibit use of the outlet until:

(1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and

(2) test results indicate that the lead levels are at or below the action level;

(b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;

(c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and

(d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.4 Laboratory Analytical Reports by Building

Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 20-10-04904

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Received Date: 10/22/2020
Reported Date: 11/11/2020
Sampled By: Christine Schultz
Tech Certification #:

Project/Test Address: 2020L-169.5; Court Street Elementary; 91 Court St; Lancaster, NY 14086

Client Number: 33-5980

Laboratory Results

Fax Number: 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04904-001	169.5-1	10/17/2020	GYM OFFICE LAV	12.0	11/09/2020	
20-10-04904-002	169.5-2	10/17/2020	GYM CLASSROOM	9.62	11/09/2020	
20-10-04904-003	169.5-3	10/17/2020	KITCHEN SPRAYER	4.53	11/09/2020	
20-10-04904-004	169.5-4	10/17/2020	KITCHEN SINGLE BAY CENTER	4.59	11/09/2020	
20-10-04904-005	169.5-5	10/17/2020	KITCHEN LAV	5.67	11/09/2020	
20-10-04904-006	169.5-6	10/17/2020	KITCHEN HANDWASH	2.40	11/09/2020	
20-10-04904-007	169.5-7	10/17/2020	KITCHEN 3 BAY LEFT	4.29	11/09/2020	
20-10-04904-008	169.5-8	10/17/2020	KITCHEN 3 BAY RIGHT	4.10	11/09/2020	
20-10-04904-009	169.5-9	10/17/2020	CAFETERIA	7.04	11/09/2020	
20-10-04904-010	169.5-10	10/17/2020	CAFETERIA KITCHEN HALLWAY	19.8	11/09/2020	
20-10-04904-011	169.5-11	10/17/2020	GYM PASSAGE LEFT LAV	<1.00	11/09/2020	
20-10-04904-012	169.5-12	10/17/2020	GYM PASSAGE	1.92	11/09/2020	
20-10-04904-013	169.5-13	10/17/2020	GYM PASSAGE	<1.00	11/09/2020	

Client Number: 33-5980 Report Number: 20-10-04904

Project/Test Address: 2020L-169.5; Court Street Elementary; 91 Court St; Lancaster, NY 14086

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04904-014	169.5-14	10/17/2020	GYM PASSAGE RIGHT LAV	10.2	11/09/2020	
20-10-04904-015	169.5-15	10/17/2020	ROOM 179	4.05	11/09/2020	
20-10-04904-016	169.5-16	10/17/2020	FAC ROOM	2.63	11/09/2020	
20-10-04904-017	169.5-17	10/17/2020	ROOM 103	1.49	11/09/2020	
20-10-04904-018	169.5-18	10/17/2020	BOYS LAV LEFT	4.45	11/09/2020	
20-10-04904-019	169.5-19	10/17/2020	BOYS LAV CENTER	5.63	11/09/2020	
20-10-04904-020	169.5-20	10/17/2020	BOYS LAV RIGHT	4.84	11/09/2020	
20-10-04904-021	169.5-21	10/17/2020	FOUNTAIN BETWEEN LAVS	<1.00	11/09/2020	
20-10-04904-022	169.5-22	10/17/2020	GIRLS LAV LEFT	5.74	11/09/2020	
20-10-04904-023	169.5-23	10/17/2020	GIRLS LAV CENTER	8.31	11/09/2020	
20-10-04904-024	169.5-24	10/17/2020	GIRLS LAV RIGHT	4.25	11/09/2020	
20-10-04904-025	169.5-25	10/17/2020	ROOM 111	3.20	11/09/2020	
20-10-04904-026	169.5-26	10/17/2020	FAC LAV 1	4.26	11/09/2020	
20-10-04904-027	169.5-27	10/17/2020	FAC LAV 2	3.48	11/09/2020	
20-10-04904-028	169.5-28	10/17/2020	ROOM 105	8.78	11/09/2020	
20-10-04904-029	169.5-29	10/17/2020	ROOM 110	4.08	11/09/2020	
20-10-04904-030	169.5-30	10/17/2020	ROOM 106	4.51	11/09/2020	
20-10-04904-031	169.5-31	10/17/2020	ROOM 109	6.13	11/09/2020	
20-10-04904-032	169.5-32	10/17/2020	ROOM 107	<1.00	11/09/2020	
20-10-04904-033	169.5-33	10/17/2020	ROOM 108	6.44	11/09/2020	

Client Number: 33-5980 Report Number: 20-10-04904

Project/Test Address: 2020L-169.5; Court Street Elementary; 91 Court St; Lancaster, NY 14086

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04904-034	169.5-34	10/17/2020	MEDIA CENTER 102	3.35	11/09/2020	
20-10-04904-035	169.5-35A	10/17/2020	CAFE HALLWAY TOWARD PRINCIPAL	<1.00	11/09/2020	
20-10-04904-036	169.5-35B	10/17/2020	CAFE HALLWAY TOWARD PRINCIPAL	<1.00	11/09/2020	
20-10-04904-037	169.5-36	10/17/2020	PRINCIPAL LAV	8.89	11/09/2020	
20-10-04904-038	169.5-37	10/17/2020	MENS LAV BY PRINCIPAL LEFT	3.92	11/09/2020	
20-10-04904-039	169.5-38	10/17/2020	MENS LAV BY PRINCIPAL RIGHT	3.75	11/09/2020	
20-10-04904-040	169.5-39	10/17/2020	NURSE OFFICE LAV	5.44	11/09/2020	
20-10-04904-041	169.5-40	10/17/2020	NURSE OFFICE MAIN	7.99	11/09/2020	
20-10-04904-042	169.5-41	10/17/2020	GIRLS LAV BY OFFICE LEFT	6.68	11/09/2020	
20-10-04904-043	169.5-42	10/17/2020	GIRLS LAV BY OFFICE RIGHT	6.89	11/09/2020	
20-10-04904-044	169.5-43	10/17/2020	SINGLE LAV END OF NORTH WING	<1.00	11/09/2020	
20-10-04904-045	169.5-44A	10/17/2020	FOUNTAIN END OF NORTH WING	<1.00	11/09/2020	
20-10-04904-046	169.5-44B	10/17/2020	FOUNTAIN END OF NORTH WING	<1.00	11/09/2020	
20-10-04904-047	169.5-45	10/17/2020	ROOM 132 LAV	4.85	11/09/2020	
20-10-04904-048	169.5-46	10/17/2020	ROOM 132	7.10	11/09/2020	
20-10-04904-049	169.5-47	10/17/2020	ROOM 132	3.96	11/09/2020	
20-10-04904-050	169.5-48	10/17/2020	ROOM 131 LAV	3.52	11/09/2020	
20-10-04904-051	169.5-49	10/17/2020	ROOM 131	6.21	11/09/2020	
20-10-04904-052	169.5-50	10/17/2020	ROOM 131	1.26	11/09/2020	
20-10-04904-053	169.5-51	10/17/2020	ROOM 124 LAV	2.99	11/09/2020	

Client Number: 33-5980 Report Number: 20-10-04904

Project/Test Address: 2020L-169.5; Court Street Elementary; 91 Court St; Lancaster, NY 14086

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04904-054	169.5-52	10/17/2020	ROOM 124	6.38	11/09/2020	
20-10-04904-055	169.5-53	10/17/2020	ROOM 124	6.33	11/09/2020	
20-10-04904-056	169.5-54	10/17/2020	ROOM 130 LAV	2.11	11/09/2020	
20-10-04904-057	169.5-55	10/17/2020	ROOM 130	3.74	11/09/2020	
20-10-04904-058	169.5-56	10/17/2020	ROOM 130	4.64	11/09/2020	
20-10-04904-059	169.5-57	10/17/2020	ROOM 125 LAV	3.88	11/09/2020	
20-10-04904-060	169.5-58	10/17/2020	ROOM 125	4.33	11/09/2020	
20-10-04904-061	169.5-59	10/17/2020	ROOM 125	1.27	11/09/2020	
20-10-04904-062	169.5-60	10/17/2020	ROOM 129 LAV	3.44	11/09/2020	
20-10-04904-063	169.5-61	10/17/2020	ROOM 129	4.32	11/09/2020	
20-10-04904-064	169.5-62	10/17/2020	ROOM 129	8.88	11/09/2020	
20-10-04904-065	169.5-63	10/17/2020	ROOM 126 LAV	3.64	11/09/2020	
20-10-04904-066	169.5-64	10/17/2020	ROOM 126	5.32	11/09/2020	
20-10-04904-067	169.5-65	10/17/2020	ROOM 126	6.94	11/09/2020	
20-10-04904-068	169.5-66	10/17/2020	ROOM 128 LAV	2.71	11/09/2020	
20-10-04904-069	169.5-67	10/17/2020	ROOM 128	4.06	11/09/2020	
20-10-04904-070	169.5-68	10/17/2020	ROOM 128	10.3	11/09/2020	
20-10-04904-071	169.5-69	10/17/2020	ROOM 127 LAV	2.71	11/09/2020	
20-10-04904-072	169.5-70	10/17/2020	ROOM 127	10.5	11/09/2020	
20-10-04904-073	169.5-71	10/17/2020	ROOM 127	3.93	11/09/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980 Report Number: 20-10-04904

Project/Test Address: 2020L-169.5; Court Street Elementary; 91 Court St; Lancaster, NY 14086

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-04904-074	169.5-72	10/17/2020	ROOM 118 LAV	2.36	11/09/2020	
20-10-04904-075	169.5-73	10/17/2020	ROOM 118	2.37	11/09/2020	
20-10-04904-076	169.5-74	10/17/2020	ROOM 118	<1.00	11/09/2020	
20-10-04904-077	169.5-75	10/17/2020	ROOM 118B	13.4	11/10/2020	
20-10-04904-078	169.5-76	10/17/2020	ROOM 119 LAV	<1.00	11/10/2020	
20-10-04904-079	169.5-77	10/17/2020	ROOM 119	<1.00	11/10/2020	
20-10-04904-080	169.5-78	10/17/2020	ROOM 119	<1.00	11/10/2020	
20-10-04904-081	169.5-79	10/17/2020	ROOM 120 LAV	2.98	11/10/2020	
20-10-04904-082	169.5-80	10/17/2020	ROOM 120	6.30	11/10/2020	
20-10-04904-083	169.5-81	10/17/2020	ROOM 120	3.18	11/10/2020	
20-10-04904-084	169.5-82	10/17/2020	ROOM 121 LAV	1.60	11/10/2020	
20-10-04904-085	169.5-83	10/17/2020	ROOM 121 LAV	<1.00	11/10/2020	
20-10-04904-086	169.5-84	10/17/2020	ROOM 121 LAV	3.96	11/10/2020	
20-10-04904-087	169.5-85	10/17/2020	ROOM 122	4.40	11/10/2020	
20-10-04904-088	169.5-86	10/17/2020	ROOM 122	1.23	11/10/2020	
20-10-04904-089	169.5-87	10/17/2020	BASEMENT SHOP	2.80	11/10/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980 Report Number: 20-10-04904

Project/Test Address: 2020L-169.5; Court Street Elementary; 91 Court St; Lancaster, NY 14086

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID

Method: SM 3113B-2010
Analyst: Jennalee Hertzler
Accreditation #: NY 11714

Reviewed By Authorized Signatory: Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER

Expires 12:01 AM April 01, 2021
Issued April 01, 2020

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2003) for the category ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:

Metals I

Copper, Total	SM 19, 21-23 3113B (-04,-10)
Lead, Total	SM 19, 21-23 3113B (-04,-10)

NEW YORK STATE | Department of Health

Serial No.: 61514

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

NELAP RECOGNIZED TNI ACCREDITATION BODY

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.6 Chains of Custody

Chain of Custody Document

Stohl ENVIRONMENTAL
3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-169.5

Client: Lancaster CSD

Contact: Michael Bryniarski

Building: Court Street Elementary

Location: 91 Court St. Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
169.5-1	Gym Office Lav	Sink	14:30			
169.5-2	Gym Classroom	Sink	14:31			
169.5-3	Kitchen Sprayer	Sink	14:32			
169.5-4	Kitchen SIngle Bay Center	Sink	14:33			
169.5-5	Kitchen Lav	Sink	14:34			
169.5-6	Kitchen Handwash	Sink	14:35			
169.5-7	Kitchen 3 Bay Left	Sink	14:36			
169.5-8	kitchen 3 Bay Right	Sink	14:37			
169.5-9	Cafeteria	DF	14:38			
169.5-10	Cafeteria/Kitchen Hallway	Bubbler	14:39			
169.5-11	Gym Passage Left Lav	Sink	14:40			
169.5-12	Gym Passage	Sink	14:41			
169.5-13	Gym Passage	DF	14:42			
169.5-14	Gym Passage Right Lav	Sink	14:43			
169.5-15	Room 179	Sink	14:44			
169.5-16	Fac room	Sink	14:45			
169.5-17	Room 103	Sink	14:46			
169.5-18	Boys Lav Left	Sink	14:47			

20-10-04904

Due Date:
11/19/2020
(Thursday)
AE

Notes:
Please e-mail lab results to labs@stohlenv.com ☑ If checked, also e-mail results to: Ehenderson@StohlEnv.com

Sampled By:	Christine Schultz	Print Name	Stohl Env: Christine Schultz	Date:	10/17/2020
Relinquished By:	[signature]	Print Name	Stohl Env: Eric Henderson Jr.	Date:	10/19/2020
Received (Name / Lab):	KT HARRIS		Date: 10.22.20	Time:	1:27 pm
Sample Login (Name / Lab):	[signature]		Date: 11.4.20	Time:	12:36 pm
Analysis (Name / Lab):	J. Hertzler		Date: 11/10/20	Time:	9 am
QA/QC Review (Name / Lab):	[signature]		Date: 11/11/20	Time:	12pm
Archived / Released:		QA/QC InterLAB Use:	Date:	Time:	

Stohl ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-169.5

Client: Lancaster CSD

Contact: Michael Bryniarski

Building: Court Street Elementary

Location: 91 Court St. Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround
20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
169.5-19	Boys Lav Center	Sink	14:48			
169.5-20	Boys Lav Right	Sink	14:49			
169.5-21	Fountain Between Lavs	DF	14:50			
169.5-22	Girls Lav Left	Sink	14:51			
169.5-23	Girls Lav Center	Sink	14:52			
169.5-24	Girls Lav Right	Sink	14:53			
169.5-25	Room 111	Sink	14:54			
169.5-26	Fac Lav 1	Sink	14:55			
169.5-27	Fac Lav 2	Sink	14:56			
169.5-28	Room 105	Sink	14:57			
169.5-29	Room 110	Sink	14:58			
169.5-30	Room 106	Sink	14:59			
169.5-31	Room 109	Sink	15:00			
169.5-32	Room 107	Sink	15:01			
169.5-33	Room 108	Sink	15:02			
169.5-34	Media Center 102	Sink	15:03			
169.5-35A	Cafe Hallway Toward Principal	DF	15:04			
169.5-35B	Cafe Hallway Toward Principal	DFB	15:05			

Notes:
Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 10/17/2020

Relinquished By: [signature] Print Name Stohl Env: Eric Henderson Jr. Date: 10/19/2020

Received (Name / Lab): ICT HARRIS [signature] Date: 10.22.20 Time: 1:27 pm

Sample Login (Name / Lab): [signature] Date: 11.4.20 Time: 12:36 pm

Analysis (Name / Lab): [signature] Date: 11/10/20 Time: 9 am

QA/QC Review (Name / Lab): [signature] Date: 11/11/20 Time: 12pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

Stohl ENVIRONMENTAL
3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-169.5

Client: Lancaster CSD

Contact: Michael Bryniarski

Building: Court Street Elementary

Location: 91 Court St. Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
169.5-36	Principal Lav	Sink	15:06			
169.5-37	Mens Lav by Principal Left	Sink	15:07			
169.5-38	Mens Lav by Principal Right	Sink	15:08			
169.5-39	Nurse Office Lav	Sink	15:09			
169.5-40	Nurse Office Main	Sink	15:10			
169.5-41	Girls Lav by Office Left	Sink	15:11			
169.5-42	Girls Lav by Office Right	sink	15:12			
169.5-43	Single Lav End of North WIng	Sink	15:13			
169.5-44A	Fountain End of North Wing	DF	15:14			
169.5-44B	Fountain End of North Wing	DFB	15:15			
169.5-45	Room 132 Lav	Sink	15:16			
169.5-46	Room 132	Bubbler	15:17			
169.5-47	Room 132	Sink	15:18			
169.5-48	Room 131 Lav	Sink	15:19			
169.5-49	Room 131	Bubbler	15:20			
169.5-50	Room 131	Sink	15:21			
169.5-51	Room 124 Lav	Sink	15:22			
169.5-52	Room 124	Bubbler	15:23			

Notes:
Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 10/17/2020

Relinquished By: E. Henderson Print Name Stohl Env: Eric Henderson Jr. Date: 10/19/2020

Received (Name / Lab): K THARRIS K Thorris Date: 10.22.20 Time: 1:27 pm

Sample Login (Name / Lab): K Thorris Date: 11.4.20 Time: 12:30 pm

Analysis (Name / Lab): J. Hertzler Date: 11/10/20 Time: 9 am

QA/QC Review (Name / Lab): [illegible] Date: 11/11/20 Time: 12 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

Stohl ENVIRONMENTAL
3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-169.5

Client: Lancaster CSD

Contact: Michael Bryniarski

Building: Court Street Elementary

Location: 91 Court St. Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
169.5-53	room 124	Sink	15:24			
169.5-54	Room 130 Lav	Sink	15:25			
169.5-55	Room 130	Bubbler	15:26			
169.5-56	Room 130	Sink	15:27			
169.5-57	Room 125 Lav	Sink	15:28			
169.5-58	Room 125	Bubbler	15:29			
169.5-59	Room 125	Sink	15:30			
169.5-60	Room 129 Lav	Sink	15:31			
169.5-61	Room 129	Bubbler	15:32			
169.5-62	Room 129	sink	15:33			
169.5-63	Room 126 Lav	Sink	15:34			
169.5-64	Room 126	Bubber	15:35			
169.5-65	Room 126	Sink	15:36			
169.5-66	Room 128 Lav	Sink	15:37			
169.5-67	Room 128	Bubbler	15:38			
169.5-68	Room 128	Sink	15:39			
169.5-69	Room 127 Lav	Sink	15:40			
169.5-70	Room 127	Bubbler	15:41			

Notes:
Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 10/17/2020

Relinquished By: [signature] Print Name Stohl Env: Eric Henderson Jr. Date: 10/19/2020

Received (Name / Lab): KTHARRIS / [signature] Date: 10.22.20 Time: 1:27 pm

Sample Login (Name / Lab): [signature] Date: 11/4/20 Time: 12:36 pm

Analysis (Name / Lab): J. Hertzler Date: 11/10/20 Time: 9am

QA/QC Review (Name / Lab): [signature] Date: 11/11/20 Time: 12 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

Stohl ENVIRONMENTAL
3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-169.5

Client: Lancaster CSD

Contact: Michael Bryniarski

Building: Court Street Elementary

Location: 91 Court St. Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
169.5-71	Room 127	Sink	15:42			
169.5-72	Room 118 Lav	Sink	15:43			
169.5-73	Room 118	Bubber	15:44			
169.5-74	Room 118	Sink	15:45			
169.5-75	Room 118B	Sink	15:46			
169.5-76	Room 119 Lav	Sink	15:47			
169.5-77	Room 119	Bubbler	15:48			
169.5-78	Room 119	Sink	15:49			
169.5-79	Room 120 Lav	Sink	15:50			
169.5-80	Room 120	Bubbler	15:51			
169.5-81	Room 120	Sink	15:52			
169.5-82	Room 121 Lav	Sink	15:53			
169.5-83	Room 121 Lav	Bubbler	15:54			
169.5-84	Room 122 Lav	Sink	15:55			
169.5-85	Room 122	Bubbler	15:56			
169.5-86	Room 122	Sink	15:57			
169.5-87	Basement Shop	Sink	15:58			

Notes:
Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 10/17/2020

Relinquished By: [signature] Print Name Stohl Env: Eric Henderson Jr. Date: 10/19/2020

Received (Name / Lab): KT HARRIS [signature] Date: 10.22.20 Time: 1:27 pm

Sample Login (Name / Lab): [signature] Date: 11.4.20 Time: 12:36 pm

Analysis (Name / Lab): [signature] Date: 11/10/20 Time: 9 am

QA/QC Review (Name/Lab): [signature] Date: 11/11/20 Time: [signature]

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

BLANK

BLANK



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM