Stohl ENVIRONMENTAL

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

December 15, 2020

Mr. Michael Bryniarski
Director of Facilities
Lancaster Central School District
177 Central Avenue
Lancaster, NY 14086

RE: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Bryniarski:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Lancaster Central School District, including:

- District Office – 177 Central Avenue, Lancaster, New York.

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on October 24, 2020. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 *(Executive Summary)* of the accompanying report, based upon the sampling and analysis performed, 0 sources of potable water in the District Office have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Lancaster Central School District.

Sincerely,
Stohl Environmental, LLC.

Eric Henderson Jr.
Senior Project Manager

Investigation and Sampling Of Sources of Potable Water For Lead Concentrations

Prepared for:

Lancaster Central School District

Prepared by:

Stohl ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Conditions as of October 24, 2020

Stohl ENVIRONMENTAL

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

Summary Tabulation

Lead in Drinking Water Investigation

1.1. Scope of Work and Sampling Protocol

1.2. Executive Summary of Sampling and Analysis

1.3. Response Actions Required Under NYS Regulations

1.4. Laboratory Analytical Reports by Building

1.5. Laboratory Certifications

1.6. Chains of Custody

Stohl ENVIRONMENTAL

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Lancaster Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- District Office – 177 Central Avenue, Lancaster, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the District Office. Outlets are defined in NYS regulations as: "a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets".

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***'3Ts for Reducing Lead in Drinking Water in Schools"***, Stohl Environmental's protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.

- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health's Environmental Laboratory Approval Program (ELAP).

Stohl ENVIRONMENTAL

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
District Office	10/24/2020	9	9	0	N/A	N/A

****** Confirmatory samples are samples collected subsequent to “Step 1” First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

All of the locations sampled were analyzed at less than the NYS Action Level of 15 ppb, therefore no further response action is required.

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.4 Laboratory Analytical Reports by Building

Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 20-10-06106

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Received Date: 10/29/2020
Reported Date: 11/17/2020
Sampled By: R Stotz
Tech Certification #:

Project/Test Address: 2020L-169.8; District Office; 177 Central Ave; Lancaster, NY 14086

Client Number: 33-5980

Laboratory Results

Fax Number: 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
20-10-06106-001	169.8-1	10/24/2020	BASEMENT MEN'S LAV	5.40	11/16/2020	
20-10-06106-002	169.8-2	10/24/2020	BASEMENT WOMEN'S LAV	1.98	11/16/2020	
20-10-06106-003	169.8-3	10/24/2020	BASEMENT KITCHEN	4.55	11/16/2020	
20-10-06106-004	169.8-4A	10/24/2020	MAIN FLOOR FOUNTAIN	<1.00	11/16/2020	
20-10-06106-005	169.8-4B	10/24/2020	MAIN FLOOR FOUNTAIN	<1.00	11/16/2020	
20-10-06106-006	169.8-5	10/24/2020	SUPERINTENDENT'S OFFICE LAV	2.52	11/16/2020	
20-10-06106-007	169.8-6A	10/24/2020	SEOND FLOOR FOUNTAIN	<1.00	11/16/2020	
20-10-06106-008	169.8-6B	10/24/2020	SECOND FLOOR FOUNTAIN	<1.00	11/16/2020	
20-10-06106-009	169.8-7	10/24/2020	SECOND FLOOR LAV	1.23	11/16/2020	

Environmental Hazards Services, L.L.C

Client Number: 33-5980 Report Number: 20-10-06106

Project/Test Address: 2020L-169.8; District Office; 177 Central Ave; Lancaster, NY 14086

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID

Method: SM 3113B-2010
Analyst: Jennalee Hertzler
Accreditation #: NY 11714

Reviewed By Authorized Signatory: Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER

Expires 12:01 AM April 01, 2021
Issued April 01, 2020

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2003) for the category ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:

Metals I

Copper, Total	SM 19, 21-23 3113B (-04,-10)
Lead, Total	SM 19, 21-23 3113B (-04,-10)

NEW YORK STATE | Department of Health

Serial No.: 61514

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

NELAP RECOGNIZED TNI ACCREDITATION BODY

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

1.6 Chains of Custody

20-10-06106

Stohl ENVIRONMEN

3860 California Road, Orchard Park, New Yo
PHONE (716) 312-0070 FAX (716) 312-8
WWW.STOHLENVIRONMENTAL.CO

Due Date:
11/27/2020
(Friday)
AE

# of Custody Document

(Lab Name) EHS

STOHL Job # 2020L-169.8

SI

Client: Lancaster CSD

Contact: Michael Bryniarski

Building: District Office

Location: 177 Central Ave Lancaster, NY 14086

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

	Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
1	169.8-1	Basement Men's Lav	S	8:05			
2	169.8-2	Basements Women's Lav	S	8:06			
3	169.8-3	Basement Kitchen	S	8:06			
4	169.8-4A	Main Floor Fountain	DFA	8:10			
5	169.8-4B	Main Floor Fountain	DFB	8:10			
6	169.8-5	Superintendent's Office Lav	S	8:20			
7	169.8-6A	Second Floor Fountain	DFA	8:25			
8	169.8-6B	Second Floor Fountain	DFB	8:25			
9	169.8-7	Second Floor Lav	S	8:30			

Notes:

Please e-mail lab results to labs@stohlenv.com ☑ If checked, also e-mail results to: Ehenderson@StohlEnv.com

Sampled By: R.Stotz Print Name Stohl Env: R.Stotz Date: 10/24/2020

Relinquished By: [signature] Print Name Stohl Env: Eric Henderson Jr. Date: 10/26/2020

Received (Name / Lab): T.Mohammed Date: 10/29/20 Time: 4.45p

Sample Login (Name / Lab): Traci Blum Date: 11/3/20 Time: 9:28 Am

Analysis (Name / Lab): J. Hertzler Date: 11/16/20 Time: 9:37 pm

QA/QC Review (Name / Lab): [signature] Date: 11/17/20 Time: 11 am

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

BLANK

BLANK



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM