



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/28/2022
Received: 07/12/2022
Sampled By: C Spear
Work Order: 2195010

C
L
I
E
N
T
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Philo H/S
Project # : 2022044
Sample Type : Grab
PO # : 2022044

Sampling Location: Philomath H/S

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2195010-01	Sample Name: 1900 0022 - 134 NS 22A Sampled: 7/11/22 14:00 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/19/22 14:08
2195010-02	Sample Name: 1900 0022 - 135 SF 22A Sampled: 7/11/22 14:03 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/19/22 14:08
2195010-03	Sample Name: 1900 0022 - 136 BF 22A Sampled: 7/11/22 14:05 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/19/22 14:08
2195010-04	Sample Name: 1900 0022 - 137 SF 22A Sampled: 7/11/22 14:06 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	07/19/22 14:08
2195010-05	Sample Name: 1900 0022 - 138 BF 22A Sampled: 7/11/22 14:07 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/19/22 14:08
2195010-06	Sample Name: 1900 0022 - 139 KF 22A Sampled: 7/11/22 14:08 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-07	Sample Name: 1900 0022 - 140 CF 22A Sampled: 7/11/22 14:09 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-08	Sample Name: 1900 0022 - 141 DW 22A Sampled: 7/11/22 14:09 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-09	Sample Name: 1900 0022 - 142 DW 22A Sampled: 7/11/22 14:10 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-10	Sample Name: 1900 0022 - 143 DW 22A Sampled: 7/11/22 14:10 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/28/2022
Received: 07/12/2022
Sampled By: C Spear
Work Order: 2195010

C
L
I
E
N
T
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Philo H/S
Project # : 2022044
Sample Type : Grab
PO # : 2022044

Sampling Location: Philomath H/S

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2195010-11	Sample Name: 1900 0022 - 144 BF 22A Sampled: 7/11/22 14:11 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-12	Sample Name: 1900 0022 - 145 BF 22A Sampled: 7/11/22 14:11 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/26/22 16:04
2195010-13	Sample Name: 1900 0022 - 146 BF 22A Sampled: 7/11/22 14:12 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/26/22 16:04
2195010-14	Sample Name: 1900 0022 - 147 DW 22A Sampled: 7/11/22 14:12 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-15	Sample Name: 1900 0022 - 148 DW 22A Sampled: 7/11/22 14:13 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-16	Sample Name: 1900 0022 - 149 BF22A Sampled: 7/11/22 14:13 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/26/22 16:04
2195010-17	Sample Name: 1900 0022 - 150 BF 22A Sampled: 7/11/22 14:14 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	07/26/22 16:04
2195010-18	Sample Name: 1900 0022 - 151 BF 22A Sampled: 7/11/22 14:14 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	7	ppb	1	15 ppb	07/26/22 16:04
2195010-19	Sample Name: 1900 0022 - 152 BF 22A Sampled: 7/11/22 14:15 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	07/26/22 16:04
2195010-20	Sample Name: 1900 0022 - 153 BF 22A Sampled: 7/11/22 14:15 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	07/26/22 16:04



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/28/2022
Received: 07/12/2022
Sampled By: C Spear
Work Order: 2195010

C
L
I
E
N
T

Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Philo H/S
Project # : 2022044
Sample Type : Grab
PO # : 2022044

Sampling Location: Philomath H/S

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2195010-21	Sample Name: 1900 0022 - 154 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:16		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	8	ppb	1	15 ppb	07/26/22 16:04
2195010-22	Sample Name: 1900 0022 - 155 DW 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:16		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-23	Sample Name: 1900 0022 - 156 DW 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:17		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-24	Sample Name: 1900 0022 - 157 DW 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:17		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-25	Sample Name: 1900 0022 - 158 DW 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:18		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-26	Sample Name: 1900 0022 - 159 BF22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:18		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	07/26/22 16:04
2195010-27	Sample Name: 1900 0022 - 160 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:19		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/26/22 16:04
2195010-28	Sample Name: 1900 0022 - 161 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:19		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/26/22 16:04
2195010-29	Sample Name: 1900 0022 - 162 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:20		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/26/22 16:04
2195010-30	Sample Name: 1900 0022 - 163 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:20		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	07/26/22 16:04



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/28/2022
Received: 07/12/2022
Sampled By: C Spear
Work Order: 2195010

C
L
I
E
N
T
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Philo H/S
Project # : 2022044
Sample Type : Grab
PO # : 2022044

Sampling Location: Philomath H/S

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2195010-31	Sample Name: 1900 0022 - 164 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:21		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-32	Sample Name: 1900 0022 - 165 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:21		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-33	Sample Name: 1900 0022 - 166 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:22		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-34	Sample Name: 1900 0022 - 167 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:22		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-35	Sample Name: 1900 0022 - 168 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:23		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/26/22 16:04
2195010-36	Sample Name: 1900 0022 - 169 SF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:23		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/26/22 16:04
2195010-37	Sample Name: 1900 0022 - 170 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:24		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	07/26/22 16:04
2195010-38	Sample Name: 1900 0022 - 171 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:24		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	6	ppb	1	15 ppb	07/26/22 16:04
2195010-39	Sample Name: 1900 0022 - 172 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:25		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	07/26/22 16:04
2195010-40	Sample Name: 1900 0022 - 173 KF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:25		Sample Composition: Raw Single				
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	07/26/22 16:04



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/28/2022
Received: 07/12/2022
Sampled By: C Spear
Work Order: 2195010

C
L
I
E
N
T
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Philo H/S
Project # : 2022044
Sample Type : Grab
PO # : 2022044

Sampling Location: Philomath H/S

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2195010-41	Sample Name: 1900 0022 - 174 KF 22A Sampled: 7/11/22 14:25 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/26/22 16:04
2195010-42	Sample Name: 1900 0022 - 175 KF 22A Sampled: 7/11/22 14:25 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	6	ppb	1	15 ppb	07/26/22 16:04
2195010-43	Sample Name: 1900 0022 - 176 KF 22A Sampled: 7/11/22 14:26 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	11	ppb	1	15 ppb	07/26/22 16:04
2195010-44	Sample Name: 1900 0022 - 177 KF 22A Sampled: 7/11/22 14:22 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	07/26/22 16:04
2195010-45	Sample Name: 1900 0022 - 178 KF 22A Sampled: 7/11/22 14:27 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-46	Sample Name: 1900 0022 - 179 KF 22A Sampled: 7/11/22 14:28 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/26/22 16:04
2195010-47	Sample Name: 1900 0022 - 180 BF 22A Sampled: 7/11/22 14:28 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-48	Sample Name: 1900 0022 - 181 KF 22A Sampled: 7/11/22 14:29 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/26/22 16:04
2195010-49	Sample Name: 1900 0022 - 182 CF 22A Sampled: 7/11/22 14:30 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-50	Sample Name: 1900 0022 - 183 BF 22A Sampled: 7/11/22 14:30 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/28/2022
Received: 07/12/2022
Sampled By: C Spear
Work Order: 2195010

C
L
I
E
N
T
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Philo H/S
Project # : 2022044
Sample Type : Grab
PO # : 2022044

Sampling Location: Philomath H/S

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2195010-51	Sample Name: 1900 0022 - 184 BF 22A Sampled: 7/11/22 14:31 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/26/22 16:04
2195010-52	Sample Name: 1900 0022 - 185 BF 22A Sampled: 7/11/22 14:31 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/26/22 16:04
2195010-53	Sample Name: 1900 0022 - 186 BF 22A Sampled: 7/11/22 14:32 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/26/22 16:04
2195010-54	Sample Name: 1900 0022 - 187 BF 22A Sampled: 7/11/22 14:32 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/26/22 16:04
2195010-55	Sample Name: 1900 0022 - 188 BF 22A Sampled: 7/11/22 14:33 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/26/22 16:04
2195010-56	Sample Name: 1900 0022 - 189 BF 22A Sampled: 7/11/22 14:33 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/26/22 16:04
2195010-57	Sample Name: 1900 0022 - 190 BF 22A Sampled: 7/11/22 14:34 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/26/22 16:04
2195010-58	Sample Name: 1900 0022 - 191 BF 22A Sampled: 7/11/22 14:34 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/26/22 16:04
2195010-59	Sample Name: 1900 0022 - 192 BF 22A Sampled: 7/11/22 14:35 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/26/22 16:04
2195010-60	Sample Name: 1900 0022 - 193 DW 22A Sampled: 7/11/22 14:35 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/28/2022
Received: 07/12/2022
Sampled By: C Spear
Work Order: 2195010

C
L
I
E
N
T
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Philo H/S
Project # : 2022044
Sample Type : Grab
PO # : 2022044

Sampling Location: Philomath H/S

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2195010-61	Sample Name: 1900 0022 - 194 DW 22A Sampled: 7/11/22 14:36 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-62	Sample Name: 1900 0022 - 195 DW 22A Sampled: 7/11/22 14:36 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-63	Sample Name: 1900 0022 - 196 DW 22A Sampled: 7/11/22 14:37 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-64	Sample Name: 1900 0022 - 197 BF 22A Sampled: 7/11/22 14:37 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-65	Sample Name: 1900 0022 - 198 BF 22A Sampled: 7/11/22 14:38 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-66	Sample Name: 1900 0022 - 199 BF 22A Sampled: 7/11/22 14:38 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-67	Sample Name: 1900 0022 - 200 BF 22A Sampled: 7/11/22 14:39 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	07/26/22 16:04
2195010-68	Sample Name: 1900 0022 - 201 DW 22A Sampled: 7/11/22 14:39 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-69	Sample Name: 1900 0022 - 202 DW 22A Sampled: 7/11/22 14:40 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-70	Sample Name: 1900 0022 - 203 BF 22A Sampled: 7/11/22 14:40 Sample Composition: Raw Single						Matrix: Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/28/2022
Received: 07/12/2022
Sampled By: C Spear
Work Order: 2195010

C
L
I
E
N
T
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Philo H/S
Project # : 2022044
Sample Type : Grab
PO # : 2022044

Sampling Location: Philomath H/S

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2195010-71	Sample Name: 1900 0022 - 204 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:40		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	6	ppb	1	15 ppb	07/26/22 16:04
2195010-72	Sample Name: 1900 0022 - 205 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:40		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-73	Sample Name: 1900 0022 - 206 DW 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:41		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04
2195010-74	Sample Name: 1900 0022 - 207 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:42		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	07/26/22 16:04
2195010-75	Sample Name: 1900 0022 - 208 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:42		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	07/26/22 16:04
2195010-76	Sample Name: 1900 0022 - 209 BF 22A						Matrix: Drinking Water
	Sampled: 7/11/22 14:43		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	07/26/22 16:04

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director