

Report of Analysis

Name:	Parkway School Greenwich Public Schools - Cordes George 290 Greenwich Ave Greenwich, CT 06830-6521	Sample ID#:	306915
		Sample Type:	Drinking Water
		Sample Source:	PS017
Sample Date:	2/21/2023 11:30 AM	Sampler:	PD
Receipt Date:	2/21/2023 3:17 PM	PWS ID:	CT0570212
Report Date:	2/24/2023		
Sample Site:	DISTRIBUTION SYSTEM		

Parameter	Sample Result	Units	MCL	Method	RL	Analysis Date/Time	Analyst
Minerals Alkalinity	204	mg/L	No Limit Set	SM 2320B (-97)	5	2/22/2023 09:15	JK

ND = Not Detected
 * = Above Specified Limit

Report Approved by: Charles Weston CT Lic PH-0787 NY Lic 11706
 Lab Director

AquaEnvLab.com
 YorkLab.com
 203 270 9973

MCL (MCL – Maximum Contaminant Level)
 Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.