

WASTEWATER SYSTEM AND POTABLE WATER SUPPLY PERMIT**LAWS/REGULATIONS INVOLVED**

10 V.S.A. Chapter 64, Potable Water Supply and Wastewater System Permit
Wastewater System and Potable Water Supply Rules, Effective April 12, 2019

Permittee(s): Marion Cross School
22 Church Street
Norwich, VT 05055

Permit Number: WW-3-0026R1

This permit affects the following property/properties in Norwich, Vermont:

Lot	Parcel	SPAN	Acres	Book(s)/Page(s)#
25-238.000	20-238.000	450-142-12740	7.03	

This application consisting of the reallocation of flows for the student population under the current rules, with no increase in the overall design flow from the previous permit (per WW-3-0026-R) located at 22 Church Street in Norwich, Vermont is hereby approved under the requirements of the regulations named above subject to the following conditions. Any person aggrieved by this permit may appeal to the Environmental Court within 30 days of the date of issuance of this permit in accordance with 10 V.S.A. Chapter 220 and the Vermont Rules of Environmental Court Proceedings.

1. GENERAL

- 1.1 The permittee is responsible to record this permit in the Norwich Land Records within 30 days of issuance of this permit and prior to the conveyance of any lot subject to the jurisdiction of this permit.
- 1.2 The permittee is responsible to record the design and installation certifications and other documents that are required to be filed under these Rules or under a permit condition in the Norwich Land Records.
- 1.3 Each assign or successor in interest shall be shown a copy of the Wastewater System and Potable Water Supply Permit and the stamped plan(s) prior to the conveyance of a lot.
- 1.4 By acceptance of this permit, the permittee agrees to allow representatives of the State of Vermont access to the property covered by the permit, at reasonable times, for the purpose of ascertaining compliance with the Vermont environmental and health statutes and regulations, and permit conditions.
- 1.5 This permit does not relieve the landowner from obtaining all other approvals and permits from other State Agencies or Departments, or local officials prior to construction.
- 1.6 The Drinking Water and Groundwater Protection Division relied upon the Vermont Licensed Designer's certification that the design-related information submitted is true and correct and complies with the Wastewater System and Potable Water Supply Rules. This permit may be revoked if it is determined the design of the wastewater system or potable water supply does not comply with these rules.

2. PLANS AND/OR DOCUMENTS

- 2.1 The existing and proposed aspects of this project shall be completed as described in the application and on the document "Amendment for Marion Cross School Wastewater Permit WW-3-0026-R" dated 8/31/22, prepared by Jeffrey Goodrich, PE.

3. DESIGN FLOW

- 3.1 Lot use and design flows (gpd) shall correspond to the following, based on previously permitted design flow:

Lot	Building	Building Use / Design Flow Basis	Wastewater	Water
-----	----------	----------------------------------	------------	-------



25-238.000	Elementary School	410 students and staff - grades pre-school through grade 8 (grade 6 at MCS) without cafeteria or showers	5,460*	5,460*
------------	-------------------	--	--------	--------

* Previously permitted maximum design flow per the disposal system capacity

4. WASTEWATER SYSTEM

- 4.1 The landowner shall continue to the practice of “store and dose” per se, from December 1 through May 1 as warranted by weather conditions. There shall be the periodic removal and transportation (septage service) of the contents of the subject septic tank, to a point of discharge at an approved municipal wastewater treatment facility. The landowner shall maintain receipts for each instance of tank pumping, indicating the date of pumping and the volume of wastewater removed from the tank. Copies of all such notices shall be submitted with the/a licensed designer’s written inspection report.
- 4.2 A flow (gallons) reading shall be obtained, and a record maintained at the time of each pumping of the sewage holding tank. This record shall be included in the licensed designer’s report.
- 4.3 Annually during the months of February, March and April, the permittee shall perform a visual inspection of the of the wastewater disposal system areas. The inspection shall specifically look and test for signs of surfacing effluent. If surfacing is found, the Division shall be notified within 48 hours. The landowner shall have a report completed by Class 1 Designer and submitted to the Division, indicating such information as: frequency of septic tank pumping; and identification of any necessary repairs, adjustments, maintenance items, and the results from conditions #4.1 & #4.2. A written report shall be submitted to the Drinking Water and Groundwater Protection Division by June 30th of each year.

5. POTABLE WATER SUPPLY

- 5.1 The existing school is approved with an existing water service line and connection to the water supply system owned by the Norwich Fire District. Should the line fail and not qualify for the minor repair or replacement exemption, the landowner shall engage a Licensed Designer to evaluate the cause of the failure and to submit an amendment application to this office, and obtain approval thereof, prior to correcting the failure.

Julia S. Moore, Secretary
Agency of Natural Resources

By 

Dated October 31, 2022

Terry Shearer, Environmental Analyst VII
Springfield Regional Office
Drinking Water and Groundwater Protection Division

cc: Jeffrey Goodrich
Department of Public Safety, Division of Fire Safety