



Microbac Laboratories Inc., Pittsburgh Division
CERTIFICATE OF ANALYSIS

2084202

CHEMWAY

Laura Ryan
 880 Coal Valley Road
 Jefferson Hills, PA 15025

Project Name: Penn Hills School District

Maintenance Center
 Project / PO Number: N/A
 Received: 08/19/2022
 Reported: 08/26/2022

Analytical Testing Parameters

Client Sample ID:	Upstairs Locker Room Sink	Collected By:	STEVE VRANKA
Sample Matrix:	Drinking Water	Collection Date:	08/16/2022 8:00
Lab Sample ID:	2084202-01		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	7.16	15.0	0.400	ug/L		08/24/22 1515	08/24/22 1515	SEV

Client Sample ID:	Garage Water Fountain	Collected By:	STEVE VRANKA
Sample Matrix:	Drinking Water	Collection Date:	08/16/2022 8:00
Lab Sample ID:	2084202-02		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.87	15.0	0.400	ug/L		08/24/22 1517	08/24/22 1517	SEV

*Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.*

Definitions

RL: Reporting Limit
ug/L: Micrograms per Liter

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division
 02-00257

PA Department of Environmental Protection
 PADEP Accreditation by Rule

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.
 The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.**

Reviewed and Approved By:

Tina Sharer
 Administration
 Reported: 08/26/2022 12:03

Microbac Laboratories, Inc.

MICROBAC
 Pittsburgh Division
 100 Marshall Drive
 Warrendale, PA 15086
 724.772.0610 P

Erie Division
 5340 Frying Road, Suite 103
 Erie, PA 16510
 814.825.8533 P



2084202

TO BE COMPLETED BY MICROBAC
 CHEMWAY
 P.M. Carolyn Valentine

Lab Report Address
 Client Name: *CHEMWAY*
 Address: *P.O. Box 10913*
 City, State, Zip: *Rh, Pa 15336*
 Contact: *Steve Wanka*
 Telephone No.: *412-901-5171*

Invoice Address
 Client Name: *Some Chemway*
 Address:
 City, State, Zip:
 Contact:
 Telephone No.:

Turnaround Time
 Routine (5 to 7 business days)
 RUSH* (notify lab)
 (needed by)
 Report Type
 Results Only Level 1 Level 2 Level 3 Level 4 EDD
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Sand Report via: Mail Fax e-mail (address) *Wanka@verizon.net* Sand Invoice via: Mail Fax e-mail (address)

Project: *Penn Hills School District* Location: *Maintenance Center PO No.:*
 Sampled by (PRINT): *STEVE WANKA* Sampler Signature: *Steve Wanka* Sampler Phone No.: *412-901-5171*
 Compliance Monitoring? Yes No *AS per client*

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved
 REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional Notes
1	<i>UPSTAIRS Locker room sink</i>	<i>8/16/22</i>	<i>800</i>	<i>1</i>	<i>DW</i>	<i>G</i>	<i>U</i>	<i>Lead</i>
2	<i>Garage water fountain</i>	<i>8/16/22</i>		<i>1</i>	<i>DW</i>	<i>G</i>	<i>U</i>	<i>Lead</i>
								<i>AS per client</i>

HNO3 PI
 Date: *8/19/22*
 Time: *1:50*
 Initials: *SW*

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Sample Disposition Dispose as appropriate Return Archive

Comments
 Relinquished By (signature) *SW Wanka* Date/Time *8/19/22 1:20*
 Relinquished By (signature)
 Relinquished By (signature)
 Relinquished By (signature)
 Received By (signature) *AS* Date/Time *8/19/22 11:00*
 Received By (signature)
 Received By (signature)
 Received By (signature)
 Received By (signature)