



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2085606

CHEMWAY

Laura Ryan
880 Coal Valley Road
Jefferson Hills, PA 15025

Project Name: Penn Hills SD Linton Middle School

Project / PO Number: Penn Hills SD Linton Middle Sch
Received: 08/30/2022
Reported: 09/09/2022

Analytical Testing Parameters

Table with client sample details: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, and Collection Date.

Table with analytical results for Lead: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst.

Table with client sample details: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, and Collection Date.

Table with analytical results for Lead: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst.

Table with client sample details: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, and Collection Date.

Table with analytical results for Lead: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst.

Table with client sample details: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, and Collection Date.

Table with analytical results for Lead: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst.



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2085606

Client Sample ID: Room 114 Faucet	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-05	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	12.3	15.0	0.400	ug/L		09/06/22 1559	09/06/22 1559	SEV

Client Sample ID: Room 102 Faucet	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-06	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	18.0	15.0	0.400	ug/L		09/06/22 1601	09/06/22 1601	SEV

Client Sample ID: Room 161 Faucet Main Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-07	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.95	15.0	0.400	ug/L		09/06/22 1602	09/06/22 1602	SEV

Client Sample ID: Room 156 Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-08	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	42.6	15.0	0.400	ug/L		09/06/22 1604	09/06/22 1604	SEV

Client Sample ID: Room 147 Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-09	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	36.4	15.0	0.400	ug/L		09/06/22 1606	09/06/22 1606	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2085606

Client Sample ID: Room 153 Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-10	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	26.4	15.0	0.400	ug/L		09/06/22 1608	09/06/22 1608	SEV

Client Sample ID: Room 146 Faucet	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-11	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	54.0	15.0	0.400	ug/L		09/06/22 1615	09/06/22 1615	SEV

Client Sample ID: Room 144 across hall Bottle Filler	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-12	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		09/06/22 1622	09/06/22 1622	SEV

Client Sample ID: 1st FI Girls Rm 7th Grade Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-13	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	6.71	15.0	0.400	ug/L		09/06/22 1624	09/06/22 1624	SEV

Client Sample ID: 1st FI Faculty Mens Rm Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-14	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.58	15.0	0.400	ug/L		09/06/22 1626	09/06/22 1626	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2085606

Client Sample ID: 1st Floor Main Office	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-15	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.806	15.0	0.400	ug/L		09/06/22 1627	09/06/22 1627	SEV

Client Sample ID: Kitchen Middle Prep Sink Faucet	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-16	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	1.84	15.0	0.400	ug/L		09/06/22 1629	09/06/22 1629	SEV

Client Sample ID: Kitchen Dual Wash Sink Left	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-17	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	6.77	15.0	0.400	ug/L		09/06/22 1631	09/06/22 1631	SEV

Client Sample ID: Main Lobby Womens Room Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-18	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	8.33	15.0	0.400	ug/L		09/06/22 1633	09/06/22 1633	SEV

Client Sample ID: Nurses Station Examine Room Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-19	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	6.76	15.0	0.400	ug/L			09/06/22 1635	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2085606

Client Sample ID: Mens Gym Locker Room Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-20	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	6.41	15.0	0.400	ug/L		09/06/22 1636	09/06/22 1636	SEV

Client Sample ID: Director of Education Bathroom Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-21	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		09/06/22 1649	09/06/22 1649	SEV

Client Sample ID: Womens Room Gym Locker Room Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-22	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	18.6	15.0	0.400	ug/L		09/06/22 1656	09/06/22 1656	SEV

Client Sample ID: Mens Pool Locker Room Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-23	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	19.8	15.0	0.400	ug/L		09/06/22 1658	09/06/22 1658	SEV

Client Sample ID: Pool Lobby Womens Room Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-24	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	3.66	15.0	0.400	ug/L		09/06/22 1700	09/06/22 1700	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2085606

Client Sample ID: 2nd FI Mens Room Sink across 229	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-25	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	6.78	15.0	0.400	ug/L		09/08/22 1215	09/08/22 1215	SEV

Client Sample ID: 2nd FI Womens Room Sink across 231	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-26	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	10.2	15.0	0.400	ug/L		09/08/22 1217	09/08/22 1217	SEV

Client Sample ID: 226A Mens Room Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-27	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	10.8	15.0	0.400	ug/L		09/06/22 1705	09/06/22 1705	SEV

Client Sample ID: 226D Womens Room Slnk	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-28	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	22.9	15.0	0.400	ug/L		09/06/22 1707	09/06/22 1707	SEV

Client Sample ID: Room 241 Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-29	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	1.26	15.0	0.400	ug/L		09/06/22 1708	09/06/22 1708	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2085606

Client Sample ID: Room 243 Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-30	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	93.8	15.0	0.400	ug/L		09/06/22 1710	09/06/22 1710	SEV

Client Sample ID: Room 245 Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-31	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	114	15.0	0.800	ug/L		09/08/22 1204	09/08/22 1204	SEV

Client Sample ID: 2nd Fl 250 Ladies Faculty Restroom Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-32	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	5.91	15.0	0.400	ug/L		09/06/22 1725	09/06/22 1725	SEV

Client Sample ID: 2nd Fl Room 247 Bottle Filler	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-33	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		09/06/22 1727	09/06/22 1727	SEV

Client Sample ID: 2nd Fl Room 252 Mens Room Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-34	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.402	15.0	0.400	ug/L		09/06/22 1728	09/06/22 1728	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2085606

Client Sample ID: 2nd Fl Room 252 Womens Room Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-35	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	5.06	15.0	0.400	ug/L		09/06/22 1730	09/06/22 1730	SEV

Client Sample ID: Room 262 Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-36	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	24.8	15.0	0.400	ug/L		09/06/22 1732	09/06/22 1732	SEV

Client Sample ID: Lunchroom Staff Room 130 Faucet	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-37	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		09/06/22 1734	09/06/22 1734	SEV

Client Sample ID: Cafeteria Dish Room Sink 129A	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-38	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	1.35	15.0	0.400	ug/L		09/06/22 1735	09/06/22 1735	SEV

Client Sample ID: Team Room Locker Sink	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/26/2022 8:00
Lab Sample ID: 2085606-39	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	8.11	15.0	0.400	ug/L		09/06/22 1737	09/06/22 1737	SEV

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2085606

Definitions

RL: Reporting Limit
ug/L: Micrograms per Liter

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division
02-00257

PA Department of Environmental Protection
PADEP Accreditation by Rule

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at https://www.microbac.com/standard-terms-conditions.

Reviewed and Approved By:

Handwritten signature: Carolyn M. Vollentine

Carolyn Vollentine
Service Center Manager
Reported: 09/09/2022 11:17

Microbac Laboratories, Inc.

100 Marshall Drive | Warrendale, PA 15086 | 724-772-0610 p | www.microbac.com

MICROBAC*
 Pittsburgh Division
 100 Marshall Drive
 Warrendale, PA 15086
 724.772.0610 p

Erie Division
 5340 Frying road, Suite 103
 Erie, PA 16510
 814.825.8533 p

CHAIN OF CUSTODY RECORD
 Number 2085606
 Instructions on back

TO BE COMPLETED BY MICROBAC

Turnaround Time
 Routine (5 to 7 business days)
 RUSH* (notify lab)

Temperature Upon Receipt (°C) 21.3
 Therm ID 7436
 Holding Time
 Samples Received on Ice? Yes No
 Custody Seals Intact? Yes No

Lab Report Address
 Client Name: CHEMWAY
 Address: P.O. Box 10913
 City, State, Zip: Rich, Pa 15236
 Contact: STEVE WOLNICKO
 Telephone No.: 412-901-5171

HNO₃ Preserved
 Date: 9-1-22
 Time: 1155
 Initials: DET

Send Report via: Mail e-mail (address) Wolnicko@verizon.net Send Invoice via: Mail Fax e-mail (address)

Project: Penn Milk School District Location: Cinton Middle School PO No.:

Sampled by (PRINT): STEVE WOLNICKO Signature: [Signature] Sampler Signature: [Signature] Sampler Phone No.: 412-901-5171

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO₃, (2) H₂SO₄, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved



CHEMWAY
 PM: Carolyn Volentine

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional
SAMPLES #1 - #39 SEE ATTACHED								
* Samples taken on 08/26/22 between 8:00-10:00am								
* all samples are drinking water Grab samples								
* No samples preserved except #6, #9, #11, #15, #17, #18, #19, #21 and #22.								

Possible Hazard Identification	Sample Disposition	Archive
<input type="checkbox"/> Hazardous <input type="checkbox"/> Non-Hazardous	<input type="checkbox"/> Dispose as appropriate <input type="checkbox"/> Return <input type="checkbox"/> Archive	<input type="checkbox"/> Archive
Comments	Relinquished By (signature) <u>[Signature]</u> Date/Time <u>9/30/22 16:54</u>	Received By (signature) <u>[Signature]</u> Date/Time <u>9/30/22</u>
	Relinquished By (signature) <u>[Signature]</u> Date/Time	Received By (signature) <u>[Signature]</u> Date/Time
	Relinquished By (signature) <u>[Signature]</u> Date/Time	Received By (signature) <u>[Signature]</u> Date/Time

- ~~#53 Room 228 Sink~~
~~#54 Room 226 Sink~~
~~#55 Room 222 Sink~~
~~#56 Room 220 Sink~~
~~#57 Janitor 52 Boys Room Sink~~
~~#58 2nd floor Break Room Faucet~~
~~#59 Room 201 B Classroom B Faucet~~
~~#60 Room 205 Faucet~~
~~#61 Room 207 Faucet~~
~~#62 Room 209 Faucet~~
~~#63 Room 212 Faucet~~
~~#64 2nd floor 4th 5th Grade mixed Bathroom ~~Sink~~~~
~~#65 Room 210 Faucet~~
~~#66 Room 206 Faucet~~
~~#67 Room 204 Faucet~~

Linton School

- #1 Loading Dock Mens Room Sink
 #2 Room 124 Faucet
 #3 1st Floor ~~Mens Room Sink (Room 116)~~ Womens Room Sink (116)
 #4 1st Floor Womens Room (114) Bottle Filler
 #5 Room 114 Faucet
 #6 Room 102 Faucet
 #7 Room 161 faucet (main sink)
 #8 Room 157 Sink
 #9 Room 147 Sink
 #10 Room 153 Sink

#11 Room 146 faucet

#12 Room 144 (across Hall) Bottle Filler

#13 1st Floor Girls Room 7th Grade Sink

#14 1st Floor Faculty Memo Room Sink (134)

#15 1st Floor main office

#16 ~~16~~ kitchen middle prep sink faucet

#17 kitchen dual wash sink left

#18 ~~18~~ main lobby womens room sink

#19 nurses station examine room sink

#20 mens gym locker room sink

#21 Director of Education Botterson sink

#22 Womens room gym locker room sink

#23 mens pool locker room sink

#24 Pool lobby Womens Room Sink

#25 2nd floor Mens Room Sink (across 229)

#26 2nd floor Womens room sink (across 231)

#27 266A Mens Room sink

#28 266D Womens Room sink

#29 Room 241 Sink

~~#30 Room 246 Sink Room 248 Sink~~

#30 Room 243 Sink

#31 Room 245 Sink

#32 ~~Room 248 Sink~~ 2nd floor ⁽²⁵⁰⁾ Ladies Faculty Restroom Sink

#33 2nd floor (Room 247) Bottle Filler

#34 2nd floor (Room 252) Mens Room Sink

#35 2nd floor (~~Room 252~~ Room 252) Womens Room Sink

#36 Room 262 Sink

#37 Lunchroom Staff Room 130 Grease

#38 Cafeteria Dish Room Sink (1290)

#39 Team Room Locker Sink