

SPECS FOR replacing Compressor in WCHS gym unit

300 W. US HWY 150 BYP

Springfield, KY 40069

Bid Opening: March 15, 2023 2:15 PM @ Washington County BOE

- Quote is to purchase and install new compressor in 15 ton unit
- Quote is to include all necessary parts and labor.
- Quote shall include all delivery charges.
- Quote shall include installation and any other charges.
- Quote to include removing refrigerant from system.
- Remove the bad compressor and filter drier.
- Provide and install new compressor and liquid line drier.
- Pressure test the system to ensure there are no leaks.
- Evacuate the system to a minimum of 500 microns.
- Charge the system with 410A.
- Start the unit and chekc for proper operation
- Note:
 - Vendors who receives the bid must send a representative to confirm details and prior to any work starting to ensure no additional questions or modifications need to be made.
 - Vendor must contact Ray Kelty at (859) 481-2491 to see site to ensure proper parts are ordered
 - Vendor may be required to provide proof of background checks to the owner prior to work beginning
 - Vendor must provide proof of 1 million dollar liability insurance
 - Electronic submission of bids will not be accepted
 - Bids can be mailed to:
 - Washington County Board of Education
 - Attn: Judy Spalding
 - 120 Mackville Hill
 - Springfield, KY 40069