



# ADDENDUM NUMBER TWO

31 March 2023

**HAPGOOD SWITCHGEAR  
REPLACEMENT PROJECT  
BID B6-23**

Issued By:  
**Lompoc Unified School District**  
1301 North A St. Lompoc, CA 93436

To all respondents submitting proposal(s) for the captioned project: this Addendum is hereby made part of the Contract Documents to the same extent as though it was originally included therein and takes precedence over the original documents and any previous addenda.

## **Include this Form with Proposal as receipt of Addendum**

### **A. PRE-BID QUESTIONS**

---

**Q9: The job specs call for Arc resistant gear, but the plans do not reflect this. Please confirm that Arc resistant gear is required.**

**A9: ~~Provide Arc resistant switchgear, Type 2C, per project specification section 26-0341-2.3.C.~~**

**Revised Answer:**

It has been discovered that major manufacturers are not fabricating arc-resistant gear for outdoor applications (NEMA 3R cabinets), so the arc-resistant requirement is being waived.