

District Administration Office (DAO)

LOCATION_ID	SAMPLE_ID	DATE	LEAD RESULT (ppb)
3RD Floor Women's RR/Left Fountain	2243 – 001DW22A	12/9/2022	0.536
3RD Floor Women's RR/Right Fountain	2243 – 002DW22A	12/9/2022	2.12
Kitchenette 3.371	2243 – 003SF22A	12/9/2022	0.374
Kitchenette 3.371/Water Fill next to sink	2243 – 004WB22A	12/9/2022	ND
Kitchenette 3.371	2243 – 005WB22A	12/9/2022	ND
Kitchenette 3.337	2243 – 006SF22A	12/9/2022	0.79
Kitchenette 3.337/Water Fill next to sink	2243 – 007WB22A	12/9/2022	ND
Kitchenette 3.337	2243 – 008WB22A	12/9/2022	ND
2nd Floor Women's RR/Left Fountain	2243 – 009WB22A	12/9/2022	0.531
2nd Floor Women's RR/Right Fountain	2243 – 010WB22A	12/9/2022	0.669
Kitchenette 2.265	2243 – 011SF22A	12/9/2022	1.27
Kitchenette 2.265/Water Fill next to sink	2243 – 012WB22A	12/9/2022	ND
Kitchenette 2.265	2243 – 013WB22A	12/9/2022	ND
Prayer Room 2.255	2243 – 014SF22A	12/9/2022	0.257
2nd Floor Café/Break Rm	2243 – 015SF22A	12/9/2022	0.32
2nd Floor Café/Break Rm	2243 – 016WB22A	12/9/2022	0.28
Kitchenette 2.237	2243 – 017SF22A	12/9/2022	0.429
Kitchenette 2.237/Water Fill next to sink	2243 – 018WB22A	12/9/2022	ND
Kitchenette 2.237	2243 – 019WB22A	12/9/2022	ND
Kitchenette 1.193	2243 – 020SF22A	12/9/2022	1.54
1st Floor Women's RR/Left Fountain	2243 – 021DW22A	12/9/2022	0.582
1st Floor Women's RR/Right Fountain	2243 – 022DW22A	12/9/2022	0.988
Storage Room 1.139	2243 – 023SF22A	12/9/2022	ND