

SUMMARY OF LEAD IN DRINKING WATER SAMPLING RESULTS

SCHOOL	FIRST DRAW		SECOND DRAW		DATE/TIME LAST USED	FIXTURE TYPE	LOCATION/DESCRIPTION			RESULTS (PPB)	
							Level	Direction	Room/Corridor	First Draw (A)	Second Draw (B)
Apollo	2017-0276-A-01-	A	2017-0276-A-01-	B	11/10/2017 21:00	Drinking Fountain	1	E	Outside Main Office	ND	ND
Apollo	2017-0276-A-02-	A	2017-0276-A-02-	B	11/10/2017 21:00	Drinking Fountain	1	N	Outside Boys' Bathroom by Room 105	ND	ND
Apollo	2017-0276-A-03-	A	2017-0276-A-03-	B	11/10/2017 21:00	Drinking Fountain	1	S	Outside Room 104	ND	ND
Apollo	2017-0276-A-04-	A	2017-0276-A-04-	B	11/10/2017 21:00	Drinking Fountain	1	S	Outside Room 112	ND	1.24
Apollo	2017-0276-A-05-	A	2017-0276-A-05-	B	11/10/2017 21:00	Drinking Fountain	1	N	Outside Girls' Bathroom by Room 115	ND	ND
Apollo	2017-0276-A-06-	A	2017-0276-A-06-	B	11/10/2017 21:00	Drinking Fountain	1	W	Outside Custodian's Office	ND	ND
Apollo	2017-0276-A-07-	A	2017-0276-A-07-	B	11/10/2017 21:00	Drinking Fountain	1	E	Outside Art Room	ND	ND
Apollo	2017-0276-A-08-	A	2017-0276-A-08-	B	11/10/2017 21:00	Drinking Fountain	1	N	Gym	1.25	ND
Apollo	2017-0276-A-09-	A	2017-0276-A-09-	B	11/10/2017 21:00	Sink	1	C	Kitchen	ND	ND
Apollo	2017-0276-A-10-	A	2017-0276-A-10-	B	11/10/2017 21:00	Drinking Fountain	2	S	Outside Room 212	3.82	2.75
Apollo	2017-0276-A-11-	A	2017-0276-A-11-	B	11/10/2017 21:00	Drinking Fountain	2	E	Outside Room 209	ND	ND
Apollo	2017-0276-A-12-	A	2017-0276-A-12-	B	11/10/2017 21:00	Drinking Fountain	2	E	Outside Room 206	ND	ND
Apollo	2017-0276-A-13-	A	2017-0276-A-13-	B	11/10/2017 21:00	Drinking Fountain	2	S	Outside Room 204	ND	ND
Apollo	2017-0276-A-14-	A	2017-0276-A-14-	B	11/14/2017 21:00	Sink	2	S	Teachers' Lounge, South Wall East	1.08	ND
Apollo	2017-0276-A-15-	A	2017-0276-A-15-	B	11/14/2017 21:00	Sink	1	S	Teachers' Lounge, South Wall West	1.22	ND
Apollo	2017-0276-A-16-	A	2017-0276-A-16-	B	11/14/2017 21:00	Sink	1	W	Teachers' Lounge, West Wall South	18.6	4.1
Apollo	2017-0276-A-17-	A	2017-0276-A-17-	B	11/14/2017 21:00	Sink	1	W	Teachers' Lounge, West Wall Center	4.89	1.62
Apollo	2017-0276-A-18-	A	2017-0276-A-18-	B	11/14/2017 21:00	Sink	1	E	Art Room 119 East Wall	1.02	ND
Apollo	2017-0276-A-19-	A	2017-0276-A-19-	B	11/14/2017 21:00	Sink	1	CNW	Art Room 119 Center Island Northwest (#4)	3.29	ND
Apollo	2017-0276-A-20-	A	2017-0276-A-20-	B	11/14/2017 21:00	Sink	1	CSW	Art Room 119 Center Island Southwest (#5)	3.7	ND

RESULTS KEY:

Green = No Lead Detected;
 Yellow = ≤ 5ppb Lead Detected;
 Red = >5ppb Lead Detected

SUMMARY OF LEAD IN DRINKING WATER SAMPLING RESULTS

SCHOOL	FIRST DRAW		SECOND DRAW		DATE/TIME LAST USED	FIXTURE TYPE	LOCATION/DESCRIPTION			RESULTS (PPB)	
							Level	Direction	Room/Corridor	First Draw (A)	Second Draw (B)
Apollo	2017-0276-A-21-	A	2017-0276-A-21-	B	11/14/2017 21:00	Sink	1	W	Art Room 119 West	14.5	ND
Apollo	2017-0276-A-22-	A	2017-0276-A-22-	B	11/14/2017 21:00	Sink	1	S	Art Room 119 Small Room South	38.2	1.98
Apollo	2017-0276-A-23-	A	2017-0276-A-23-	B	11/14/2017 21:00	Sink	1	N	Art Room 119 Small Room North	148	2.56
Apollo	2017-0276-A-24-	A	2017-0276-A-24-	B	11/14/2017 21:00	Sink	1	W	Room 124	2.45	ND
Apollo	2017-0276-A-25-	A	2017-0276-A-25-	B	11/14/2017 21:00	Sink	1	W	Room 107	4.03	ND
Apollo	2017-0276-A-26-	A	2017-0276-A-26-	B	11/14/2017 21:00	Sink	1	N	Room 105	2.22	1.16
Apollo	2017-0276-A-27-	A	2017-0276-A-27-	B	11/14/2017 21:00	Sink	1	CNE	Art Room Center Island Northeast (#2)	ND	ND
Apollo	2017-0276-A-28-	A	2017-0276-A-28-	B	11/14/2017 21:00	Sink	1	CSE	Art Room 119 Center Island Southeast (#3)	ND	ND
Twain	2017-0276-T-01-	A	2017-0276-T-01-	B	11/10/2017 21:00	Drinking Fountain	1	W	Gym	1.08	2.70
Twain	2017-0276-T-02-	A	2017-0276-T-02-	B	11/10/2017 21:00	Sink	1	E	Gym	ND	ND
Twain	2017-0276-T-03-	A	2017-0276-T-03-	B	11/10/2017 21:00	Drinking Fountain	1	S	Offices	ND	ND
Twain	2017-0276-T-04-	A	2017-0276-T-04-	B	11/10/2017 21:00	Drinking Fountain	1	E	Bathroom by Room 203, Left	ND	ND
Twain	2017-0276-T-05-	A	2017-0276-T-05-	B	11/10/2017 21:00	Drinking Fountain	1	E	Bathroom by Room 203, Right	ND	ND
Twain	2017-0276-T-07-	A	2017-0276-T-07-	B	11/10/2017 21:00	Drinking Fountain	2	E	By Bathroom Outside Room 210A, Left	ND	ND
Twain	2017-0276-T-08-	A	2017-0276-T-08-	B	11/10/2017 21:00	Drinking Fountain	1	E	Outside Room 110, Left	ND	ND
Twain	2017-0276-T-09-	A	2017-0276-T-09-	B	11/10/2017 21:00	Drinking Fountain	1	E	Outside Room 110, Right	ND	ND
Twain	2017-0276-T-10-	A	2017-0276-T-10-	B	11/10/2017 21:00	Drinking Fountain	1	E	Outside Room 102, Left	ND	ND
Twain	2017-0276-T-11-	A	2017-0276-T-11-	B	11/10/2017 21:00	Drinking Fountain	1	E	Outside Room 102, Right	ND	ND
Twain	2017-0276-T-12-	A	2017-0276-T-12-	B	11/10/2017 21:00	Sink	1	W	Sensory Room	7.78	ND
Twain	2017-0276-T-13-	A			11/10/2017 21:00	Drinking Fountain	1	W	Sensory Room	9.65	

RESULTS KEY:

Green = No Lead Detected;
Yellow = ≤ 5ppb Lead Detected;
Red = >5ppb Lead Detected

SUMMARY OF LEAD IN DRINKING WATER SAMPLING RESULTS

SCHOOL	FIRST DRAW		SECOND DRAW		DATE/TIME LAST USED	FIXTURE TYPE	LOCATION/DESCRIPTION			RESULTS (PPB)	
							Level	Direction	Room/Corridor	First Draw (A)	Second Draw (B)
Twain	2017-0276-T-16-	A	2017-0276-T-16-	B	11/14/2017 21:00	Sink	1	N	Art Room, Left	ND	ND
Twain	2017-0276-T-17-	A	2017-0276-T-17-	B	11/14/2017 21:00	Sink	1	N	Art Room, Right	1.68	ND
Twain	2017-0276-T-18-	A	2017-0276-T-18-	B	11/14/2017 21:00	Sink	2	W	Teachers' Lounge	ND	ND
Stevenson	2017-0276-S-01-	A	2017-0276-S-01-	B	11/10/2017 21:00	Drinking Fountain	1	W	Outside Faculty Lounge	ND	ND
Stevenson	2017-0276-S-02-	A	2017-0276-S-02-	B	11/10/2017 21:00	Drinking Fountain	1	S	Outside Room 207, Left	1.72	ND
Stevenson	2017-0276-S-03-	A			11/10/2017 21:00	Drinking Fountain	1	S	Outside Room 207, Right	2.83	
Stevenson	2017-0276-S-04-	A	2017-0276-S-04-	B	11/10/2017 21:00	Sink	1	N	Room 207	ND	ND
Stevenson	2017-0276-S-05-	A	2017-0276-S-05-	B	11/10/2017 21:00	Drinking Fountain	1	N	Room 207	ND	ND
Stevenson	2017-0276-S-06-	A	2017-0276-S-06-	B	11/10/2017 21:00	Drinking Fountain	1	S	Outside Room 217A	ND	ND
Stevenson	2017-0276-S-07-	A	2017-0276-S-07-	B	11/10/2017 21:00	Drinking Fountain	1	N	Outside Room 117A, Left	2.69	ND
Stevenson	2017-0276-S-08-	A			11/10/2017 21:00	Drinking Fountain	1	N	Outside Room 117A, Right	1.27	
Stevenson	2017-0276-S-09-	A	2017-0276-S-09-	B	11/10/2017 21:00	Drinking Fountain	1	N	Outside Room 107	ND	ND
Stevenson	2017-0276-S-10-	A	2017-0276-S-10-	B	11/10/2017 21:00	Sink	1	S	Room 107	1.02	ND
Stevenson	2017-0276-S-11-	A	2017-0276-S-11-	B	11/10/2017 21:00	Drinking Fountain	1	S	Room 107	ND	ND
Stevenson	2017-0276-S-12-	A	2017-0276-S-12-	B	11/10/2017 21:00	Drinking Fountain	1	W	Outside Room 101	ND	ND
Stevenson	2017-0276-S-13-	A	2017-0276-S-13-	B	11/10/2017 21:00	Sink	1	N	Kitchen	ND	ND
Stevenson	2017-0276-S-14-	A	2017-0276-S-14-	B	11/14/2017 21:00	Sink	1	E	Teachers' Lounge	1.96	ND
Nelson	2017-0276-N-01-	A	2017-0276-N-01-	B	11/10/2017 21:00	Sink	1	S	Room 108	2.40	ND
Nelson	2017-0276-N-02-	A			11/10/2017 21:00	Drinking Fountain	1	S	Room 108	ND	
Nelson	2017-0276-N-03-	A	2017-0276-N-03-	B	11/10/2017 21:00	Drinking Fountain	1	E	Outside Room 105, Left	ND	ND

RESULTS KEY:

Green = No Lead Detected;
Yellow = ≤ 5ppb Lead Detected;
Red = >5ppb Lead Detected

SUMMARY OF LEAD IN DRINKING WATER SAMPLING RESULTS

SCHOOL	FIRST DRAW		SECOND DRAW		DATE/TIME LAST USED	FIXTURE TYPE	LOCATION/DESCRIPTION			RESULTS (PPB)	
							Level	Direction	Room/Corridor	First Draw (A)	Second Draw (B)
Nelson	2017-0276-N-04-	A	2017-0276-N-04-	B	11/10/2017 21:00	Drinking Fountain	1	E	Outside Room 105, Right	1.63	ND
Nelson	2017-0276-N-05-	A	2017-0276-N-05-	B	11/10/2017 21:00	Drinking Fountain	1	E	Offices	ND	ND
Nelson	2017-0276-N-06-	A	2017-0276-N-06-	B	11/10/2017 21:00	Sink	1	N	Kitchen	ND	ND
Nelson	2017-0276-N-07-	A	2017-0276-N-07-	B	11/10/2017 21:00	Drinking Fountain	1	E	Outside Room 127	ND	ND
Nelson	2017-0276-N-12-	A	2017-0276-N-12-	B	11/10/2017 21:00	Drinking Fountain	2	E	Outside Room 205, Left	ND	ND
Nelson	2017-0276-N-13-	A	2017-0276-N-13-	B	11/10/2017 21:00	Drinking Fountain	2	E	Outside Room 205, Right	1.49	ND
Nelson	2017-0276-N-15-	A	2017-0276-N-15-	B	11/10/2017 21:00	Drinking Fountain	2	S	Outside Room 214, Left	1.08	ND
Nelson	2017-0276-N-16-	A	2017-0276-N-16-	B	11/10/2017 21:00	Drinking Fountain	2	S	Outside Room 214, Right	1.53	ND
Nelson	2017-0276-N-17-	A	2017-0276-N-17-	B	11/10/2017 21:00	Drinking Fountain	1	S	Outside Room 112A, Left	ND	ND
Nelson	2017-0276-N-18-	A	2017-0276-N-18-	B	11/10/2017 21:00	Drinking Fountain	1	S	Outside Room 112A, Right	ND	ND
Nelson	2017-0276-N-19-	A	2017-0276-N-19-	B	11/14/2017 21:00	Sink	1	E	Room 127, Left	ND	ND
Nelson	2017-0276-N-20-	A			11/14/2017 21:00	Sink	1	E	Room 127, Center Left	ND	
Nelson	2017-0276-N-21-	A			11/14/2017 21:00	Sink	1	E	Room 127, Center Right	ND	
Nelson	2017-0276-N-22-	A			11/14/2017 21:00	Sink	1	E	Room 127, Right	ND	
Nelson	2017-0276-N-23-	A	2017-0276-N-23-	B	11/14/2017 21:00	Sink	2	N	Teachers' Lounge	ND	ND
Melzer	2017-0276-M-01-	A	2017-0276-M-01-	B	11/10/2017 21:00	Drinking Fountain	1	W	Outside Nurse's Office	ND	ND
Melzer	2017-0276-M-02-	A	2017-0276-M-02-	B	11/10/2017 21:00	Sink	1	S	Kitchen	1.42	ND
Melzer	2017-0276-M-03-	A	2017-0276-M-03-	B	11/10/2017 21:00	Drinking Fountain	1	N	Outside Room 105, Left	1.04	ND
Melzer	2017-0276-M-04-	A	2017-0276-M-04-	B	11/10/2017 21:00	Drinking Fountain	1	N	Outside Room 105, Right	1.15	ND
Melzer	2017-0276-M-05-	A	2017-0276-M-05-	B	11/10/2017 21:00	Sink	1	E	Room 101	1.51	ND

RESULTS KEY:

Green = No Lead Detected;
Yellow = ≤ 5ppb Lead Detected;
Red = >5ppb Lead Detected

SUMMARY OF LEAD IN DRINKING WATER SAMPLING RESULTS

SCHOOL	FIRST DRAW		SECOND DRAW		DATE/TIME LAST USED	FIXTURE TYPE	LOCATION/DESCRIPTION			RESULTS (PPB)	
							Level	Direction	Room/Corridor	First Draw (A)	Second Draw (B)
Melzer	2017-0276-M-06-	A	2017-0276-M-06-	B	11/10/2017 21:00	Drinking Fountain	1	W	Outside Room 115	1.17	ND
Melzer	2017-0276-M-07-	A	2017-0276-M-07-	B	11/10/2017 21:00	Sink	1	E	Room 115	3.26	ND
Melzer	2017-0276-M-08-	A	2017-0276-M-08-	B	11/10/2017 21:00	Sink	1	N	Room 120	ND	ND
Melzer	2017-0276-M-09-	A	2017-0276-M-09-	B	11/10/2017 21:00	Sink	1	N	Room 121	ND	ND
Melzer	2017-0276-M-10-	A	2017-0276-M-10-	B	11/10/2017 21:00	Drinking Fountain	1	W	Outside Room 116	2.84	1.81
Melzer	2017-0276-M-11-	A	2017-0276-M-11-	B	11/10/2017 21:00	Sink	1	E	Room 116	8.78	ND
Melzer	2017-0276-M-12-	A	2017-0276-M-12-	B	11/10/2017 21:00	Sink	1	S	Room 117	ND	ND
Melzer	2017-0276-M-13-	A	2017-0276-M-13-	B	11/10/2017 21:00	Sink	1	S	Room 118	ND	ND
Melzer	2017-0276-M-14-	A	2017-0276-M-14-	B	11/10/2017 21:00	Drinking Fountain	2	N	Outside Room 205, Left	1.24	ND
Melzer	2017-0276-M-15-	A	2017-0276-M-15-	B	11/10/2017 21:00	Drinking Fountain	2	N	Outside Room 205, Right	ND	ND
Melzer	2017-0276-M-16-	A	2017-0276-M-16-	B	11/10/2017 21:00	Drinking Fountain	2	W	Outside Room 209, Left	ND	ND
Melzer	2017-0276-M-17-	A	2017-0276-M-17-	B	11/10/2017 21:00	Drinking Fountain	2	W	Outside Room 209, Right	3.73	ND
Melzer	2017-0276-M-18-	A	2017-0276-M-18-	B	11/10/2017 21:00	Drinking Fountain	1	W	Outside Room 107, Left	ND	ND
Melzer	2017-0276-M-19-	A	2017-0276-M-19-	B	11/10/2017 21:00	Drinking Fountain	1	W	Outside Room 107, Right	ND	ND
Melzer	2017-0276-M-20-	A	2017-0276-M-20-	B	11/10/2017 21:00	Sink	1	N	Room 107	1.01	ND
Melzer	2017-0276-M-21-	A	2017-0276-M-21-	B	11/10/2017 21:00	Sink	1	N	Room 106	12.40	ND
Melzer	2017-0276-M-22-	A	2017-0276-M-22-	B	11/14/2017 21:00	Sink	2	N	Teachers' Lounge	ND	ND
Melzer	2017-0276-M-23-	A	2017-0276-M-23-	B	11/14/2017 21:00	Sink	2	S	Room 205	ND	ND
Washington	2017-0276-W-01-	A	2017-0276-W-01-	B	11/10/2017 21:00	Drinking Fountain	2	E	Outside Library	ND	ND
Washington	2017-0276-W-02-	A	2017-0276-W-02-	B	11/10/2017 21:00	Drinking Fountain	1	E	Outside Boiler Room	ND	ND

RESULTS KEY:

Green = No Lead Detected;
Yellow = ≤ 5ppb Lead Detected;
Red = >5ppb Lead Detected

SUMMARY OF LEAD IN DRINKING WATER SAMPLING RESULTS

SCHOOL	FIRST DRAW		SECOND DRAW		DATE/TIME LAST USED	FIXTURE TYPE	LOCATION/DESCRIPTION			RESULTS (PPB)	
							Level	Direction	Room/Corridor	First Draw (A)	Second Draw (B)
Washington	2017-0276-W-03-	A	2017-0276-W-03-	B	11/10/2017 21:00	Drinking Fountain	1	W	Gym	1.16	ND
Washington	2017-0276-W-04-	A	2017-0276-W-04-	B	11/10/2017 21:00	Sink	1	W	Kitchen	ND	ND
Washington	2017-0276-W-05-	A	2017-0276-W-05-	B	11/10/2017 21:00	Drinking Fountain	1	N	Outside Room 122	ND	ND
Washington	2017-0276-W-06-	A	2017-0276-W-06-	B	11/10/2017 21:00	Sink	1	N	Room 131	2.28	ND
Washington	2017-0276-W-07-	A	2017-0276-W-07-	B	11/10/2017 21:00	Sink	1	N	Room 129	5.86	ND
Washington	2017-0276-W-08-	A			11/10/2017 21:00	Drinking Fountain	1	N	Room 129	2.76	
Washington	2017-0276-W-09-	A	2017-0276-W-09-	B	11/10/2017 21:00	Sink	1	N	Room 127	2.76	1.01
Washington	2017-0276-W-10-	A			11/10/2017 21:00	Drinking Fountain	1	N	Room 127	1.11	
Washington	2017-0276-W-11-	A	2017-0276-W-11-	B	11/10/2017 21:00	Drinking Fountain	1	E	Office	ND	ND
Washington	2017-0276-W-12-	A	2017-0276-W-12-	B	11/14/2017 21:00	Sink	1	W	Teachers' Lounge 107	ND	ND
Washington	2017-0276-W-13-	A	2017-0276-W-13-	B	11/14/2017 21:00	Sink	2	N	Room 207, Left	2.84	ND
Washington	2017-0276-W-14-	A	2017-0276-W-14-	B	11/14/2017 21:00	Sink	2	N	Room 207, Right	3.42	ND

RESULTS KEY:

Green = No Lead Detected;
Yellow = ≤ 5ppb Lead Detected;
Red = >5ppb Lead Detected